

TABLE II - Test results for GBRA water supply to Port O'Connor Rural Water customers (As sampled in the customer distribution system)

Trihalomethanes (THM)

Year	Detected Constituent	Average of all Sampling Points	Range of Detected Levels	MCL	Unit of Measure	Source of Constituent
2007	Total Trihalomethanes	59.5	48.6 - 77.2	80	ppb	Byproduct of drinking water chlorination.

Haloacetic Acids (HAA5)

Year	Detected Constituent	Average of all Sampling Points	Range of Detected Levels	MCL	MCLG	Unit of Measure	Source of Constituent
2007	Total Haloacetic Acids	12.8	0 - 26.9	60	0	ppb	Byproduct of drinking water disinfection.

Unregulated Contaminants

Year	Constituent	Measured Concentration	No. of Analyses	Unit of Measure	Source of Constituent
2005	Chloroform	6.68	1	ppb	Byproduct of drinking water disinfection.
2005	Bromodichloromethane	3.12	1	ppb	Byproduct of drinking water disinfection.

Maximum Residual Disinfectant Level

Year	Disinfectant Level	Average Concentration	Minimum	Maximum	MRDL	Unit of Measure	Source of Constituent
2007	Chloramine Residual	1.85	1.1	2.7	4	ppm	Disinfectant used to control microbes.

Lead and Copper TESTING WAIVED

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Total Coliform bacteria are used as indicators of microbial contamination of drinking water because testing for them is easy. While not disease-causing organisms themselves, they are often found in association with other microbes that are capable of causing disease. Coliform bacteria are more hardy than many disease-causing organisms; therefore, their absence from water is a good indication that the water is microbiologically safe for human consumption.

Year	Constituent	Highest Monthly Number of Positive Samples	MCL	Unit of Measure	Source of Constituent
2007	Total Coliform	0	*	Presence/Absence	Naturally present in the environment.

* Two or more coliform found samples in any single month.

Fecal Coliform NOT DETECTED

Required Additional Health Information

In order to ensure that tap water is safe to drink, the USEPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

All drinking water, (including bottled water), may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

National Primary Drinking Water Regulation Compliance

This report was prepared with technical assistance from the Guadalupe-Blanco River Authority. GBRA will be happy to answer any questions about the Port Lavaca Water Treatment Plant or its water quality and treatment process. Please contact us at 361-552-9751 or through our website at www.gbra.org. Water quality data for community water systems throughout the United States is available at www.waterdata.com.

Contaminants that may be present in source water include:

(A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;

(B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

(C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, stormwater runoff, and residential uses;

(D) Organic chemical contaminants, including synthetic and volatile organics, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems;

(E) Radioactive contaminants, which can be naturally-occurring or the result of oil and gas production and mining activities.

WATER QUALITY '07

Port O'Connor Municipal Utility District

Public Water Supply No. 0290065

EXCELLENCE IN WATER QUALITY

Port O'Connor Utility District 361-983-2652

GBRA Water Treatment Plant 361-552-9751

Dear Customer:

The Port O'Connor Municipal Utility District is pleased to provide you with this 2007 Water Quality Report. We take all possible precautions to safeguard your water supply and hope you will be encouraged to learn about the high quality of water provided to you.

The federal Safe Drinking Water Act (SDWA) requires water utilities to issue an annual report to customers, in addition to other notices that may be required by law. This report explains where your drinking water comes from, what it contains, and the health risks our water testing and treatment are designed to prevent.

We are committed to providing you with information about your water supply because informed customers are our best allies in supporting improvements needed to maintain the highest drinking water standards.

We are proud to report that the Texas Commission on Environmental Quality (TCEQ) has assessed our system and determined that your drinking water, provided by the Guadalupe-Blanco River Authority's surface water treatment plant near Port Lavaca, Texas, meets or exceeds all federal and state established water quality standards.

The tables in this report list all substances that were detected in our treated water, and the highest level at which they were detected. The tables also reflect the highest levels allowed by federal regulatory agencies. Please read this information carefully and if you have questions, call the numbers listed in this report.

Customer Views Welcome

The Port O'Connor Municipal Utility District strongly supports the national primary drinking water regulation compliance process. If you are interested in learning more about the water department, water quality, or participating in the decision-making process, there are a number of opportunities available.

Questions about water quality can be answered by calling the Utility District at 361-983-2652 or the GBRA office at 361-552-9751 from 8 a.m. - 5 p.m., Monday through Friday. Inquiries about public participation and policy decisions should be directed to the District office in Port O'Connor at 39 Denman Dr., Box 375, Port O'Connor, Texas 77982. The District Directors hold their monthly meeting the second Thursday of each month.

En Español

Éste informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre éste informe en Español, favor de llamar al tel. 361-552-9751 para hablar con una persona bilingüe en español durante las horas regulares de oficina (8 a.m. - 5 p.m.).

Special Notice for the ELDERLY, INFANTS, CANCER PATIENTS, people with HIV/AIDS OR OTHER IMMUNE PROBLEMS:

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants, can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

United States Environmental Protection Agency (USEPA) and the Center for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Where Do We Get Our Drinking Water?

The Port O'Connor Municipal Utility District receives its water from surface water diverted from the Guadalupe River and treated at the Port Lavaca Water Treatment Plant, operated by the Guadalupe-Blanco River Authority (GBRA).

The TCEQ completed an assessment of your source water and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact the GBRA Port Lavaca WTP at 361-552-9751.

Trained operators monitor and test the water, including the addition of fluoride and chloramines, to ensure that our water meets or exceeds all state and federal drinking water standards. The treated water is delivered to the utility's ground storage and delivered through its distribution system to you.

What We Found

The following tables list the contaminants that have been found in your drinking water. USEPA requires water systems to test for more than 97 contaminants. The column marked "Highest Level at Any Sampling Point" shows the highest test results during the year. The "Source of Constituent" column shows where this substance usually originates.

DEFINITIONS:

Maximum Contaminant Level (MCL) - the highest level of the contaminant allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

NTU - Nephelometric Turbidity Units.

ppm - parts per million, or milligrams per liter (mg/L).

ppb - parts per billion, or micrograms per liter (ug/L).

TABLE I - Test results for the GBRA water supply to Port O'Connor (Sampled at the GBRA Water Treatment Plant)

Inorganics

Year	Detected Constituent	Measured Concentration	Number of Analyses Performed	MCL	MCLG	Unit of Measure	Source of Constituent
2002	Barium	0.074	1	2	2	ppm	Discharge of drilling wastes; erosion of natural deposits.
2007	Fluoride	0.56	1	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; runoff from fertilizer use.
2007	Nitrate	0.72	1	10	10	ppm	Runoff from fertilizer use; leaching from septic tanks; treated effluent.
2002	Chromium	1.49	1	100	100	ppb	Discharge from steel and pulp mills; erosion of natural deposits.
2004	Gross Beta Emitters	4.8	1	50	0	pCi/l	Decay of mineral and man-made deposits.

Organics

Year	Detected Constituent	Measured Concentration	Number of Analyses Performed	MCL	MCLG	Unit of Measure	Source of Constituent
2007	Atrazine	0.13	1	3	3	ppb	Runoff from herbicide used on row crops.

Unregulated Contaminants

We participated in gathering data under UCMR in order to assist EPA in determining the occurrence of possible drinking water contaminants. If any unregulated contaminants were detected, they are shown in the table below. This data may also be found on EPA's website at <http://www.epa.gov/safewater/data/ncod.html>, or call the Safe Drinking Water Hotline at 1-800-426-4791.

Year	Constituent	Average Concentration	Range of Detected Levels	Reason for Monitoring
Trihalomethanes				
2007	Chloroform	18.35	7.8 - 37.8	Monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.
2007	Bromoform	1.5	ND - 3.0	
2007	Bromodichloromethane	19.25	12.6 - 28.4	
2007	Chlorodibromomethane	12.9	10.8 - 17.7	
Haloacetic Acids				
2007	Chloroacetic acid	ND	ND	Monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.
2007	Dichloroacetic acid	7.2	ND - 16.0	
2007	Trichloroacetic Acid	9.2	3.0 - 19.2	
2007	Bromoacetic acid	4.75	ND - 9.7	
2007	Dibromoacetic acid	3.6	ND - 6.6	
2007	Bromochloroacetic acid	8.775	5.9 - 13.0	

Secondary and Other Constituents Not Regulated

No associated adverse health effects.

Year	Constituent	Measured	Number of	MCL	Unit of	Source of
2002	Aluminum	31.4	1	50	ppb	Abundant naturally occurring element.
2007	Bicarbonate	95	1	NA	ppm	Corrosion of carbonate rocks such as limestone.
2002	Calcium	66.9	1	NA	ppm	Abundant naturally occurring element.
2007	Chloride	66.4	1	300	ppm	Abundant naturally occurring element, used in water purification, byproduct of oil field activity.
2002	Copper	0.054	1	NA	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
2007	Hardness as Ca/Mg	200	1	NA	ppm	Naturally occurring calcium and magnesium.
2002	Magnesium	14.8	1	NA	ppm	Abundant naturally occurring element.
2007	pH	7.42	1	NA	units	Measure of corrosivity of water.
2002	Sodium	24.5	1	NA	ppm	Erosion of natural deposits; byproduct of oil field activity.
2007	Sulfate	87.9	1	300	ppm	Naturally occurring common industrial byproduct; byproduct of oil field activity.
2007	Total Alkalinity as CaCO3	95	1	NA	ppm	Naturally occurring soluble mineral salts.
2007	Total Dissolved Solids	321	1	1000	ppm	Total dissolved mineral constituents in water.

Disinfection Byproducts

Year	Constituent	Average Concentration	Minimum	Maximum	MCL	Unit of Measure	Source of Constituent
2007	Total Haloacetic Acids	24.75	13	41.8	60	ppb	Byproduct of drinking water disinfection.
2007	Total Trihalomethanes	52	33.6	78	80	ppb	Byproduct of drinking water disinfection.

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches. Turbidity is measured 4 times per day through grab samples and continuously through automatic on-line individual filter turbidity monitors.

Year	Detected Constituent	Highest Single Measurement	Lowest Monthly % of Samples Meeting Limits	Turbidity Limits	Unit of Measure	Source of Constituent
2007	Turbidity	0.28	100	0.3	NTU	Organic particles.

Total organic carbon (TOC) sampled from source water has no health effects. The disinfectant can combine with TOC to form disinfection byproducts. Disinfection is necessary to ensure that water does not have unacceptable levels of pathogens. Byproducts of disinfection include trihalomethanes (THMs) and haloacetic acids (HAA) which are reported elsewhere in this report.

Year	Constituent	Average Concentration	Minimum	Maximum	Unit of Measure	Source of Constituent
2007	Source Water TOC	4.32	2.98	8.36	ppm	Naturally occurring; no health effects directly associated with it.
2007	Drinking Water TOC	2.3892	2	2.96	ppm	Naturally occurring; no health effects directly associated with it.
2007	Removal Ratio	1.894833	1	2.854	NA	NA

Disinfectant Residuals

Year	Constituent	Highest Average	Range of Detects (low-high)	MRDL	Unit of Measure	Source of Constituent
2007	Chloramines	3.752	1.2 - 4.2	4	ppm	Disinfectant used to control microbes.

Cryptosporidium Monitoring Information

The EPA Long Term 2 Enhanced Surface Water Treatment Rule (LT2 Rule) requires that the water treatment plants monitor the source water (water prior to treatment plant) for Cryptosporidium, turbidity, and *E.coli*. Cryptosporidium is a microbial pathogen that may be found in water contaminated with feces. Monitoring results will be used to determine whether additional treatment is required and to refine the relationship established between *E.coli* and Cryptosporidium levels in the source water. Although treatment plant filters remove Cryptosporidium, filters cannot guarantee 100% removal nor can the analysis determine if the organisms are alive and capable of causing cryptosporidiosis, an abdominal infection causing nausea, vomiting, diarrhea and abdominal cramps that may occur after ingestion of contaminated water. Bimonthly sampling of the Guadalupe River, the source water for the Port Lavaca Water Treatment Plant, began in October 2006 and will continue until September 2008. The following table summarizes the source water data collected in 2007.

Year	Analysis of Source Water Prior to Treatment	No. of Analyses	Mean	Range of Analyses	Units
2007	Cryptosporidium	24	0.155	<0.089 - 0.364	Oocyst per Liter
2007	<i>E.coli</i>	24	8.55*	<1 - 690	Most Probable Number
2007	Turbidity	24	51.8	8.7 - 230	NTU

*geometric mean

2007 Total Coliform NOT DETECTED 2007 Fecal Coliform NOT DETECTED