
# CALDWELL COUNTY REGIONAL WATER AND WASTEWATER PLANNING STUDY



# Prepared for GUADALUPE-BLANCO RIVER AUTHORITY January 2010

klotz (associates consulting engineers 7550 IH 10 WEST, SUITE 300 SAN ANTONIO, TEXAS 78229

Texas P.E. Firm Registration No.F-929 Project No. 0972.000.000

# TABLE OF CONTENTS

		Page
EXECUTIVI	E SUMMARY	ES-1
SECTION 1	INTRODUCTION	
1.1	Background	1-1
1.2	Purpose and Scope	1-3
1.3	Project Task	1-4
1.4	Participants and Sponsors	1-5
SECTION 2	CALDWELL COUNTY CHARACTERISTICS	
2.1	City Limits and ETJ Boundaries	2-1
2.2	Land Use	2-3
2.3	Watersheds	<u>2</u> -3
2.4	Certificates of Convenience and Necessity (CCN)	2-7
	2.4.1 Water CCN Utilities	2-7
	2.4.2 Wastewater CCN Utilities	2-7
2.5	Climate	2-10
2.6	Topography	2-10
2.0	Transmission System	2-12
2.7	Impervious Cover	2-12
2.0		2-12
<b>SECTION 3</b>	DATA COLLECTION	
3.1	General	3-1
3.2	Survey	3-1
3.3	Regional Coordination	3-3
SECTION 4	GROUNDWATER	
4.1	Groundwater Sources	4-1
	4.1.1 Leona Formation	4-1
	4.1.2 Wilcox Formation	4-3
	4.1.3 Carrizo Formation	4-3
	4.1.4 Recklaw Formation	4-5
	4.1.5 Queen City Sands Outcrop	4-5
4.2	Groundwater Quality	4-5
4.3	Groundwater Conservation Districts	4-7
	4.3.1 Plum Creek Conservation District (PCCD)	4-7
	4.3.2 Gonzales County Underground Water Conservation	т <i>і</i>
	District (GCUWCD)	4-11
SECTION 5	SURFACE WATER	
5.1	General	5-1
5.2	Surface Water Supply Sources	5-1
0.2	5.2.1 Guadalupe River Basin	5-1
	caudanape tutter Dashi internet interne	$J^{-1}$

	5.2.2 Colorado River Basin	5-3
5.3	Surface Water Supply Uses	5-5
5.4	Surface Water Rights	5-5
SECTION 6	POPULATION	
6.1	Population Projections	6-1
6.2	Texas State Data Center	6-1
6.3	Texas Water Development Board	6-2
6.4	Population History and Growth Estimates	6-4
6.5	Population Consensus	6-5
SECTION 7	FACILITIES INVENTORY	
7.1	Water Facilities Inventory	7-1
	7.1.1 Aqua Water Supply Corporation	7-3
	7.1.2 City of Lockhart	7-4
	7.1.3 Creedmoor Maha Water Supply Corporation	7-4
	7.1.4 City of Luling	7-4
	7.1.5 County Line Water Supply Corporation	7-5
	7.1.6 Goforth Special Utility District	7-5
	7.1.7 Gonzales County Water Supply Corporation	7-6
	7.1.8 TriCommunity Water Supply Corporation	7-6
	7.1.9 Martindale Water Supply Corporation	7-7
	7.1.10 Maxwell Water Supply Corporation	7-7
	7.1.11 Polonia Water Supply Corporation	7-8
	7.1.12 City of San Marcos	7-8
7.2	Regional Water Wholesalers	7-8
	7.2.1 Canyon Regional Water Authority	7-8
	7.2.2 Guadalupe Blanco River Authority	7-9
7.3	Wastewater Facilities Inventory	7-10
110	7.3.1 The City of Lockhart/ GBRA	7-10
	7.3.2 The City of Luling	7-12
	7.3.3 Turner Crest Village Wastewater Company, LLC	7-13
	7.3.4     Mustang Plaza	7-13
	7.3.5 Sweetwater Utility, LLC	7-13
	7.3.6       Additional State Wastewater Permits	7-14
SECTION 8	WATER DEMANDS	
8.1	Historical Water Use	8-1
8.2	TWDB Water Use Projections	8-3
8.3	Development of Water Demands	8-7

8.3Development of Water Demands8-78.4Conservation Measures8-11

TOC-2



Page Page

# SECTION 9 WASTEWATER FLOWS

9.1	General	9-1
9.2	Wastewater Flow	9-1
9.3	Wastewater Loads	9-3

### **SECTION 10 WATER QUALITY**

10.1	General	10-1
10.2	City Ordinances	10-1
10.3	United States Environmental Protection Agency (USEPA)	10-2
	10.3.1 The National Pollutant Discharge Elimination System	
	(NPDES)	10-2
10.4	Texas Commission on Environmental Quality (TCEQ)	10-2
	10.4.1 The Texas 303(d) List	10-3
	10.4.2 Texas Pollutant Discharge Elimination System (TPDES)	10-3
	10.4.3 Source Water Protection	10-4
10.5	Total Maximum Daily Loads (TMDL) Program	10-4
10.6	Plum Creek Watershed Protection Plan	10-4
	10.6.1 E.coli Potential	10-6
10.7	Seasonal Loading Impacts	10-6

### SECTION 11 WATER SUPPLY OPTIONS

11.1	Regional Water Plans	11-1
	11.1.1 GBRA Mid-Basin Project	11-3
	11.1.2 Hays Caldwell Public Utility Agency Supply Project	
	(HCPUA)	11-4
	11.1.3 Lower Guadalupe Water Supply Project for GBRA	
	Needs	11-6
	11.1.4 Lockhart Reservoir	11-6
	11.1.5 Recycled Water Programs	11-6
	11.1.6 Surface Water Rights	11-7
	11.1.7 Local Carrizo	11-7
	11.1.8 Local Storage	11-8
	11.1.9 The Simsboro Aquifer	11-10
	11.1.10 Weather Modification	11-10
	11.1.11 Rainwater Harvesting	11-11
	11.1.12 Water Conservation Strategy	11-11
	11.1.13 Desalination	11-12
11.2	Conclusions	11-12

### SECTION 12 REGIONAL WATER PLANNING

12.1	General	12-1
12.2	Water Supply Sources	12-2



12.3	Conceptual Planning	12-4
	12.3.1 Source Development	12-4
	12.3.2 Distribution	12-7
12.4	Water System Cost Estimates	12-9
SECTION 13	3 REGIONAL WASTEWATER PLANNING	
13.1	Introduction	13-1
13.2	Existing Wastewater Collection Systems	13-1
13.3	Wastewater System Planning	13-3
13.4	Wastewater Collection System Service Areas	13-3
13.5	Wastewater Collection System Options	13-6
	13.5.1 On-Site Sewage Facilities (OSSF)/ Septic Systems	13-6
	13.5.2 Regional Treatment Facilities	13-7
	13.5.3 Decentralized Treatment Facilities	13-7
	13.5.4 Package Treatment Facilities	13-8
13.6	Proposed Wastewater Collection Facilities	13-10
	13.6.1 Option 1 – Regional Facilities	13-11
	13.6.2 Option 2 – Decentralized/ Package Treatment Systems	13-11
	13.6.3 Option 3 – Combined Facilities	13-12
13.7	Proposed Regional Wastewater Facilities	13-12
<b>SECTION 14</b>	<b>4 REGIONAL WATER QUALITY PROTECTION PLAN</b>	1 / 1
14.1	Introduction	14-1
14.2	Caldwell County Watersheds	14-1
14.3	Water Quality Concerns and Sources of Impairment	14-2
14.4	Water Quality Standards	14-3
14.5	Impairment Locations	14-5
14.6	Recommended Load Reductions	14-6
14.7	Proposed Management Measures	14-6
	14.7.1 Urban Stormwater Management Measures	14-7
	14.7.2 Water Quality Development Ordinances and Policy	14-8
14.8	Structural BMPs for Discharges from Developed Land	14-9
	14.8.1 Infiltration Systems	14-9
	14.8.2 Detention Sedimentation Basins	14-9
	14.8.3 Vegetative Filter Strips	14-10
	14.8.4 Vegetative Swales	14-10
	14.8.5 Riparian Buffers	14-10
	14.8.6 Rain Gardens	14-10
14.9	Agricultural Best Management Practices	14-11

TOC-4

Page

14.11	Municipal	Practices and Good Housekeeping	14-13
14.12	Implemen	tation Recommendations for the CCRWQPP	14-14
	14.12.1	Point Discharge Load Reductions	14-14
	14.12.2	Stormwater Filter Strips Along Streams	14-20
	14.12.3	Water Quality Remediation Associated with Impervious	
		Cover	14-21
	14.12.4	OSSF Annual Inspection and Certification	14-22

### SECTION 15 REGIONAL WATER QUALITY IMPLEMENTATION

15.1	General	15-1
15.2	Stormwater Management Implementation	15-1
15.3	Development of Ordinances	15-3
15.4	Regional Agreement	15-3
15.5	Funding	15-3

### SECTION 16 SUMMARY OF RECOMMENDATIONS FOR WATER AND WASTEWATER FACILITIES

16.1	Introduction	16-1
16.2	Recommended Regional Water Supply Facilities	16-1
16.3	Recommended Regional Wastewater Treatment Facilities	16-4

# **TABLES**

Table 2-1	Lockhart, Texas Monthly Average Temperatures and Precipitation
Table 4-1	Caldwell County Stratigraphy
Table 4-2	Plum Creek Conservation District Groundwater Permits
Table 4-3	PCCD Classification, Spacing, and Production Provisions
Table 6-1	Population Projection Estimates
Table 6-2	Planning Study Population Projections
Table 7-1	Water CCN Utilities
Table 7-2	TCEQ Water CCN Database Inventory
Table 7-3	Wastewater CCN
Table 7-4	TCEQ Permitted Wastewater Treatment Facilities
Table 8-1	Caldwell County – TWDB Historical Water Use Summary
Table 8-2	2006 Region L – Caldwell County Water Demand Projections
Table 8-3	2006 Region L – Caldwell County Municipal Water Demands in
	Acre-Feet
Table 8-4	2006 Region L – Caldwell County Water User Group (WUG)
	Population Projections
Table 8-5	TWDB – Water User Group Population Percentages
Table 8-6	TSDC Population Scenario 1.0 - Modified
Table 8-7	Developed Water User Group Population Projections for Caldwell
	County
Table 8-8	Municipal Average – Yearly Water Demands
Table 8-9	Municipal Average – Yearly Water Demands (Acft/yr)
Table 9-1	Wastewater Connections
Table 9-2	Wastewater Peak Day Flow Factors
Table 9-3	Wastewater Return Rate
Table 9-4	Caldwell County Projected Wastewater Flows
Table 9-5	Caldwell County Projected Wastewater Loads, (lbs/day)
Table 9-6	Caldwell County Projected Wastewater Loads, (lbs/year)
Table 10-1	Potential Pollution Sources

# klotz () associates

# **TABLES CONTINUED**

Table 10-2	Estimated Loadings from Lockhart Monitoring Station
Table 10-3	Estimated Loadings from Luling Monitoring Station
Table 10-4	Estimated Loadings from Uhland Monitoring Station
Table 12-1	Caldwell County 2006 SCTRWP Projected Shortages
Table 12-2	Caldwell County Water Supplies
Table 12-3	TWDB – County Water Demand Projections Based on Revised
	Municipal Demands
Table 12-4	Caldwell County Additional Water Need
Table 12-5	Project Cost Summary
Table 13-1	Caldwell County On-Site Sewage Facilities (OSSF)
	Certificates of Completion
Table 13-2	Service Areas Projected Wastewater Flows
Table 13-3	Regional Wastewater Collection and Treatment Plant Cost
	Estimates
Table 14-1	Pollution Reduction Needed
Table 14-2	Wastewater Treatment Plant Permit Parameters
Table 14-3	Reclaimed Water Quality Parameters
Table 14-4	Annual Pollutant Load to Streams for Upgraded Existing
	Wastewater Treatment Plants
Table 14-5	Annual Pollutant Load to Streams for Upgraded Existing
	Wastewater Treatment Plants with 50 Percent Reuse of Reclaimed
	Water
Table 14-6	Comparison of Future Changes to Annual Pollutant Load to
	Streams
Table 14-7	Vegetated Filter Strip Width Requirements
Table 14-8	Impervious Cover Filtration Requirements
Table 14-9	Frequency of OSSF Inspection and Recertification Program

TOC-7

# klotz () associates

### EXHIBITS

Exhibit 1-1	Caldwell County Location Map
Exhibit 2-1	Local Governments
Exhibit 2-2	Land Use Map
Exhibit 2-3	Watershed Map
Exhibit 2-4	Water CCN Utility Map
Exhibit 2-5	Wastewater CCN Utility Map
Exhibit 2-6	Elevation Range Map
Exhibit 2-7	Approximate Transmission Line Locations
Exhibit 2-8	Impervious Cover
Exhibit 4-1	Surface Geology
Exhibit 4-2	Thickness Geology
Exhibit 4-3	Texas Groundwater Conservation Districts
Exhibit 4-4	Groundwater Conservation Districts
Exhibit 5-1	Texas Precipitation Map
Exhibit 5-2	River Basin Boundary
Exhibit 7-1	Water Production Facilities
Exhibit 7-2	Wastewater Treatment Facilities
Exhibit 11-1	South Central Texas Region L
Exhibit 11-2	Potential ASR Locations
Exhibit 12-1	Regional Water Distribution
Exhibit 12-2	Water Source Locations
Exhibit 12-3	SCTRWP Proposed Projects
Exhibit 13-1	Wastewater Planning Areas
Exhibit 13-2	Regional Facility Locations
Exhibit 13-3	Decentralized Systems
Exhibit 13-4	Recommended Regional Wastewater Facilities
Exhibit 14-1	Total Average Daily Potential E.coli Loads

TOC-8



# **EXHIBITS CONTINUED**

Exhibit 16-1	Recommended Regional	Water Facilities
--------------	----------------------	------------------

Exhibit 16-2 Recommended Regional Wastewater Facilities

# GRAPHS

Graph 2-1	Lockhart, Texas Monthly Average Temperatures
Graph 2-2	Lockhart, Texas Monthly Average Precipitation
Graph 5-1	TWDB - Caldwell County Total Surface Water Use Summary
Graph 5-2	TWDB - Caldwell County Historic Water Use Summary by River
	Drainage Basin
Graph 5-3	Caldwell County Yearly Surface Water Use Percentages
Graph 6-1	TWDB Population Projections for Caldwell County
Graph 6-2	Caldwell County Population by Decade
Graph 6-3	Texas State Data Center Population Scenarios for Caldwell County
Graph 6-4	Caldwell County Population Projection Comparison
Graph 8-1	Caldwell County Historic Water Use
Graph 8-2	Caldwell County Water Demands by Use Category
Graph 8-3	Caldwell County Survey Results of Per Capita Values
Graph 8-4	Caldwell County Yearly Water Demands with 10% Water
	Conservation
Graph 13-1	Caldwell County OSSF Certificates of Completion

**TOC-10** 

# klotz () associates

# APPENDICES

Appendix A	Caldwell County Utility Survey
Appendix B	Stakeholder Sign In Sheets
Appendix C	Water Quality Standards
Appendix D	TWDB Groundwater Quality Report
Appendix E	Groundwater Conservation Districts Rules
Appendix F	TWDB Water Use Summary Reports
Appendix G	Caldwell County Water Rights and Database Dictionary
Appendix H	Water Conservation Measures
Appendix I	Plum Creek Watershed Protection Plan BMPs
Appendix J	Plum Creek Watershed Protection Plan Management Measures and
	Outreach Activities
Appendix K	Regional Compact
Appendix L	Comments on Report and Responses to Comments
Appendix M	Regional Water Cost Estimates
Appendix N	Texas Water Development Board Comment Letter Regarding
	Draft Report and Response to Comments

TOC-11

# LIST OF ABBREVIATIONS

ASR	Aquifer Storage and Recovery
BOD	Biochemical Oxygen Demand
BMP	best management practices
CCEFN	Consensus Criteria for Environmental Flow Needs
CCWQCS	Central Carrizo-Wilcox, Queen City and Sparta
CWA	Clean Water Act
CAPCOG	Capital Area Council of Governments
CCN	Certificate of Convenience and Necessity
EPA	Environmental Protection Agency
ERCOT	Electric Reliability Council of Texas
EST	elevated storage tanks
ETJ	Extra Territorial Jurisdiction
GBRA	Guadalupe-Blanco River Authority
GCUWCD	Gonzales Ground Water Conservation District
GCD	Groundwater Conservation District
GAM	Generalized Additive Models
GST	ground storage tank
HCPUA	Hays Caldwell Public Utility Agency
HB	House Bill
LDC	Load Duration Curve
LLC	Limited Liability Company
MUD	Municipal Utility District
NRCS	National Resource Conservation Service
NPDES	National Pollutant Discharge Elimination System
OSSF	On-site sewage facility
O&M	Operation and Maintenance
PCCD	Plum Creek Conservation District
PUA	Public Utility Agency

# klotz () associates

# LIST OF ABBREVIATIONS CONTINUED

SAWS	San Antonio Water System
SCTRWP	South Central Texas Regional Water Plan
SB	Senate Bill
SELECT	Spatially Explicit Load Enrichment Calculation Tool
SSLGC	Schertz-Seguin Local Government Corporation
SUD	Special Utility District
TCEQ	Texas Commission on Environmental Quality
TMDL	Total Maximum Daily Loads
TxDOT	Texas Department of Transportation
TSDC	Texas State Data Center
TSS	Total Suspended Solids
TWDB	Texas Water Development Board
US	United States
USGS	United States Geologic Survey
USDA	United States Department of Agriculture
WWTP	Wastewater Treatment Plant
WWTF	Wastewater Treatment Facility
WUD	Water Utility District

### UNITS OF MEASUREMENT

TOC-13

gpm	gallons per minute
ppm	parts per million
MGD	million gallons per day
ac-ft	acre – feet
gpcd	gallons per capita per day
mg/l	milligrams per liter

#### **EXECUTIVE SUMMARY**

Meeting the challenges of developing, managing, conserving and protecting precious water resources requires proactive leadership that understands the problems, identifies the solutions and empowers implementation. Completion of a regional water and wastewater planning study is one of the first steps to meet the challenges.

The study examines population projections, projected water supply needs, existing water resources, proposed water plans, and proposed cost estimates. The study also examines the current availability and viability of the proposed projects in the 2006 South Central Texas Regional Water Plan (Region L Plan) developed under guidance from the Texas Water Development Board (TWDB) to meet the water supply needs of Caldwell County. Potential regional water and wastewater projects were identified for consideration to meet the needs of the county.

In addition, management strategies are identified that could be considered for implementation to reduce potential non-point pollution loads into the surface water and groundwater resources of Caldwell County

Caldwell County, located in South Central Texas, is poised to grow at an increasing rate with a population estimate of 35,843 in 2008 to over 100,000 by the year 2040. The addition of over 64,000 citizens to Caldwell County will pose new demands on local resources for basic services including potable water for consumption. In addition, new strategies will be needed to protect the quality of surface water and groundwater.

These increased demands are occurring at a time when the availability of surface water and groundwater to serve new growth is limited. Surface waters in Caldwell County have been appropriated and only innovative strategies that scalp flood flows without impacting environmental stream flows can be considered to develop additional surface water supplies. There is no additional "run-of-the-river" surface water available for permitting in Caldwell County.

Groundwater that is suitable for use with minimal treatment is available in Caldwell County from the Carrizo-Wilcox Aquifer. Studies completed by the Plum Creek Conservation District (PCCD) estimate that about 23,000 acre-feet (ac-ft) of water per year is the sustainable yield from the Carrizo-Wilcox Aquifer for Caldwell County. However, groundwater laws, developing groundwater regulations and a limited amount of groundwater are creating a permitting frenzy as potential users try to secure water for their needs. Water suppliers from outside the county and river basin have come to the Carrizo-Wilcox Aquifer in Caldwell and Gonzales Counties as a source for inexpensive high quality water. There may be little groundwater remaining to be permitted for increasing local demands because the water has been permitted to others for use out of the county or river basin. According to PCCD, as of February 2009, 16,514 ac-ft per year of groundwater withdrawals have been permitted in Caldwell County. Other large permits are pending.

Groundwater in the Carrizo/Wilcox Aquifer in Gonzales County is also subject to intense permitting pressure. Water modeling studies in Gonzales County indicate that a sustainable yield of about 13,600 ac-ft per year of water can be withdrawn on the east side of the county with a 100-foot drawdown and a sustainable yield of about 15,400 ac-ft of water can be withdrawn on the western side of the county. Permits totals of more than 15,400 ac-ft per year have been applied for on the western side of Gonzales County. The Gonzales County Underground Water Conservation District (GCUWCD) is refining its groundwater management plan for Gonzales County and it appears that permits will be granted with terms and conditions that curtail use when drawdown limits are reached. Pending permit applications are for the Hays/Caldwell Public Utility Agency and the San Antonio Water System.

The planning horizon for this study was selected as the period through the year 2040. Based on input from the Stakeholders and the State Demographer, during the approximate 30 year period, the population is projected to increase approximately 180% from 35,843 in 2008 to 100,000 in the year 2040. When a per capita demand of 150 gallons per day per person is applied, the yearly demand for municipal water will increase from 6,164 ac-ft to 16,803 ac-ft. Adding demands identified for mining, manufacturing, irrigation and livestock indicate a total current demand of 8,155 ac-ft per year in 2008 increasing to 18,495 ac-ft in the year 2040.

The population and water demand projections developed and adopted for this study are higher than the population and water demand values adopted for the 2006 Region L Plan. The 2006 Region L Plan estimated that the year 2040 population of Caldwell County would be 83,250 (compared to 100,000 adopted for this plan). The 2006 Region L Plan estimated the year 2040 total water demand for all uses would be 12,247 acre-feet per year (compared to 18,695 acre-feet developed for this plan). The larger population projections result from a higher migration rate to the county for this plan compared to the Region L population projections. The larger future water demands result from larger population projections and the adoption of larger per capita consumption rates for this plan than those adopted for the 2006 Region L Plan.

Over the planning horizon, a total of 8,432 ac-ft of water supply must be developed to meet projected water needs. Other types of water uses will collectively diminish and result in no need for additional water to supply mining, manufacturing, livestock or irrigation needs.

The proposed water management strategies contained in the 2006 South Central Texas Regional Water Plan were reviewed for applicability to meet the needs of Caldwell County. The only strategies identified in the 2006 Plan that are still viable for Caldwell County are water conservation, additional development of the Carrizo/Wilcox, the Hays/Caldwell PUA and purchase from other wholesale water providers such as GBRA and CRWA.

Water conservation is a viable option. Public education, water use restrictions and inverse water rates are tools to implement water conservation. An aggressive water conservation program could reduce municipal water consumption from 150 gallons per capita per day to as low as 120 gallons per capita per day. The amount conserved would be 3,361 ac-ft on an annual basis and the new water required would be 5,071 ac-ft per year.

Carrizo/Wilcox groundwater can be developed in southeast Caldwell County or in Gonzales County. This is the approach taken by the Hays/ Caldwell PUA. However, uncertainty regarding the long-term availability of this water is questionable as groundwater conservation districts adopt policies that will grant permits for all requests for water and limit future drawdown conditions. A regional water supply project yielding 8,432 ac-ft of water per year could be developed from the Carrizo/Wilcox aquifer. However, the possibility of future curtailment exists if groundwater district rules require reducing consumption when water table drawdown limits are reached.

Purchase of water from wholesale water providers is a viable option if there is water available. All surface water rights are currently appropriated and there are no viable strategies in the 2006 Water Plan that bring water to Caldwell County. Thus, regional development of a new conjunctive use groundwater/surface water project would appear to be a possible solution to meet future needs.

A conjunctive use project that combines storing water ordinarily lost in excessive flood flows with groundwater for firming up the project yield appears to be an option for developing a water supply project to serve a region larger than Caldwell County. It has been estimated by the Guadalupe-Blanco River Authority that 20,000 ac-ft - 25,000 ac-ft per year could be developed out of a conjunctive use project with surface water diversions occurring on the Guadalupe River at Gonzales (Mid-Basin Project). This water could be diverted, treated and piped through Caldwell County up to Comal and Hays County. The water providers in Caldwell, Hays and Comal Counties could benefit from this project.

The cost of development of water from the local Carrizo/Wilcox Aquifer to serve Caldwell County using a regional approach is estimated as \$34 million including collection, treatment and transmission to a regional distribution point. If a total of 8,432 ac-ft of water is developed by the project, the cost per ac-ft is estimated as \$4,032. The estimated unit cost of treated water at the regional water delivery point is estimated as \$3.46 per 1,000 gallons.

A main distribution system to disperse treated water from the regional distribution point near Lockhart along US Highway 183 and State Highway 130 is estimated as \$29 million.

Development cost for the Gonzales Mid-Basin Project has not been published but the total project cost will be spread over a larger annual water yield.

These water supply projects appear to be most reasonable to meet the long term needs of Caldwell County. Other opportunities may occur in the future but moving forward with these projects is a reasonable course of action.

Wastewater treatment in Caldwell County is currently accomplished with two centralized systems and numerous on-site sewage facilities (OSSF). As growth and densification occurs and subdivisions are constructed in the northern part of the county, the entities providing wastewater treatment and disposal will be faced with using a centralized, regional approach with a limited number of plants or a de-centralized approach with numerous plants each plant having its own operating parameters and needs. For purposes of this plan, the centralized treatment plant approach was analyzed with plants located in the Martindale area, the Lockhart area and the Luling area. A fourth plant would be placed in the Peach Creek Basin once sufficient development has occurred in this area. These plants will provide service generally within topographic basins and be managed by public utilities to ensure proper operation and maintenance.

The total wastewater flow estimated for 2040 is 10.2 million gallons per day with total project development cost of the plants estimated as \$39 million. The cost is only associated with developing the treatment facilities and the network for collecting the sewage is not included in this number.

The new wastewater treatment plants would be permitted and constructed to enable reuse of the plant effluent for non-potable purposes. The reuse water would offset a portion of the need for development of new water. Water reuse systems generally require extensive piping networks to take the water to its point of use. For this reason, it is not cost-effective to retrofit current facilities, but rather incorporate into new systems.

Growth often results in degradation of surface water quality and can result in pollution of groundwater. Return wastewater plant discharges to streams can degrade water quality. Pollutant wash-off from impervious cover is a large contributor to increased pollution of streams but recent studies have shown that runoff from fields, pastures and lawns can add significant non-point pollutant loads. Inefficient and failing OSSF systems can add to pollutant loads in streams. The Plum Creek Watershed Protection Plan has identified point-source and non-point pollutant contributors which have impaired Plum Creek.

The following measures are recommended for consideration to assist in protecting water quality in streams:

- Reuse water from treatment plants without discharge to streams
- Implement water quality protection requirements for new impervious cover
- Review and if warranted, revise the OSSF permitting rules for setbacks from water bodies and increase separation distance
- Require periodic inspections and reports for all OSSF systems
- Develop and carry out an urban-oriented water quality protection education program that targets pollutants normally generated in urban areas
- Develop and carry out an agriculture-based water quality education program that targets pollutants ordinarily generated in rural areas
- Work with leaders in the county to make water quality protection an everyday concern

The limited depth of the study results in many generalizations and assumptions. Some opportunities have been identified for further consideration as additional planning and implementation work is done.

In the course of the study, the energy and interest of the leaders and citizens of Caldwell County were clearly identified. Water and water quality is important to Caldwell County and its citizens. Working together as a group, water needs can be met and long term, costeffective solutions can be developed. Lack of water should not be the limiting factor that prevents the citizens of Caldwell County from realizing their potential.

### **SECTION 1**

### **INTRODUCTION**


#### 1.1 Background

Caldwell County, located in South Central Texas, was established by the Texas Legislature in 1848 by partitioning land from Gonzales County. Subsequent land additions to Caldwell County in 1850 from Bastrop and Gonzales Counties resulted in a total area of 545 square miles.

Caldwell County, as shown in *Exhibit 1-1*, is bordered on the northwest by some of the fastest growing counties in the United States. Travis and Hays Counties are to the northwest with Guadalupe County on the southwest side. Gonzales County is on the southeast side of Caldwell County while Bastrop County is on the northeast side. Fayette County just touches the eastern corner of Caldwell County.

Located adjacent to fast-growing counties and with significant growth and development pressure from within its own boundaries, Caldwell County will almost triple its current population within 30 years while the availability of water is diminishing. The volume of wastewater produced in the county will grow with the population and new treatment facilities will be required to serve an increasingly dense population. Without controls, stormwater discharges will increase in volume as impervious cover increases and water quality degradation will occur with more non-point pollutants washed into streams and rivers.

Meeting the challenges of developing, managing, conserving and protecting precious water resources requires proactive leadership that has the vision and will to understand the problems, identify the solutions and empower implementation. Completion of a regional water and wastewater planning study is one of the first steps to meet the challenge.



A Grant Application for a Regional Water Supply and Wastewater Planning Study for Caldwell County, Texas, was submitted to the Texas Water Development Board (TWDB) in December 2007 by the Guadalupe-Blanco River Authority (GBRA) and Caldwell County. The request for a study was influenced by continued development along the Interstate Highway 35 (I-35) corridor and the anticipated growth upon completion of State Highway (SH) 130 in 2012. The SH 130 corridor will provide easy and fast access to both Austin and San Antonio, two of the fastest growing cities in Texas. Caldwell County is included in the five-county region that the Austin Chamber of Commerce advertises for living and working.

Planning was considered important for this region not only to GBRA and Caldwell County but also the TWDB. The TWDB agreed that planning was necessary by participating in the funding of the "Caldwell County Water & Wastewater Regional Planning Study." After grant approval in October of 2008, GBRA awarded Klotz Associates, Inc. (Klotz Associates) a contract to provide professional services for the Caldwell County Regional Water and Wastewater Planning Study.

### **1.2** Purpose and Scope

The Caldwell County Regional Water and Wastewater Planning Study will serve as a guide and living document to assist in the planning and development of the region. Regional planning is an efficient and cost effective way to meet future water and wastewater needs. The Regional Water and Wastewater Planning Study joined the county, cities, towns, water supply corporations, groundwater districts, local departments and agencies, governmental entities, environmental groups, planners, developers, and other interested individuals together to participate, interact, and develop ideas. The regional approach for Caldwell County creates a synergy that captures the resources of numerous entities, focuses them on problems to be mutually solved and enables efficient and cost-effective solutions. The energy spent when communities compete for resources is focused on mutual solutions for the benefit of all.

The study examines population projections, projected water supply needs, existing water resources, proposed water plans, and proposed cost estimates. The study also examined the current availability and viability of the proposed projects in the Region L plan to meet the water supply needs of Caldwell County. Region L is one of the 16 regional water planning groups in Texas.

In addition, management strategies were identified that could be considered for implementation to reduce potential non-point pollution loads into the surface water and groundwater resources of Caldwell County

### **1.3 Project Task**

The tasks included in the Caldwell County Regional Water and Wastewater Planning Study were as follows:

<u>Task</u>	Title
I.	Development of Baseline Information
II.	Public Participation
III.	Developing Consensus on Objectives
IV.	Formulation of Development Scenarios
V.	Analyze Water Quality Options
VI.	Develop Regional Water Supply and Quality Protection Plan
VII.	Recommendations for Watershed Management Practices
VIII.	Reports
IX.	Public Meetings

### **1.4 Participants and Sponsors**

The Caldwell County Regional Water and Wastewater Planning study was sponsored by the following entities:

Guadalupe Blanco-River Authority Caldwell County Texas Water Development Board

The following individuals served as an Advisory Group to assist in guiding the study and providing feedback as the study progressed.

### Members:

The Honorable H.T. Wright, County Judge, Caldwell County, Texas

Mr. Vance Rodgers, City Manager, City of Lockhart, Texas

Mr. Bobby Berger, City Manager, City of Luling, Texas

- Mr. Johnie Halliburton, Executive Manager, Plum Creek Conservation District
- Mr. Bob Richards, Project Director, Cooper Land Development
- Ms. Nikki Dictson, Extension Program Specialist, Texas AgriLife Extension Service
- Mr. Paul Pitman, Manager, Polonia Water Supply Corporation
- Ms. Joyce Buckner, Community Representative for Lockhart, Bluebonnet Electric Cooperative

### Ex-Officio:

- Mr. Matt Nelson, Manager, Regional Water Planning, Texas Water Development Board
- Ms. Debbie Magin, Director of Water Quality Services, Guadalupe-Blanco River Authority

Three Stakeholder Meetings were held as an important part of collecting data, receiving input from the community and developing solutions for regional water supply, wastewater treatment, and non-point pollution controls.

The stakeholder meetings were held on the dates listed below and sign-in sheets are included in **Appendix A**.

Stakeholder Meeting 1:	September 25, 2008
Stakeholder Meeting 2:	January 8, 2009
Stakeholder Meeting 3:	August 3, 2009 (Public Meeting)

GBRA staff provided valuable oversight and assistance as the study progressed and their contribution is hereby acknowledged:

- Ms. Debbie Magin, Director of Water Quality Services, Guadalupe-Blanco River Authority
- Ms. Liz Sedlacek, Administrative Assistant, Guadalupe-Blanco River Authority

### **SECTION 2**

### CALDWELLL COUNTY CHARACTERISTICS

### 2.1 City Limits and ETJ Boundaries


The name Caldwell was given to the county in recognition of an Indian Fighter named Matthew Caldwell, who led a group of militia against the Comanches at Plum Creek in 1840. The county seat was named for Byrd Lockhart who owned the land over which the town of Lockhart would be established. Lockhart was incorporated in 1852. Luling, the other large city in Caldwell County, was incorporated in 1884 and is a significant center for railroads, cattle, cotton and oil.

Martindale is an incorporated city within Caldwell County. Mustang Ridge, Niederwald, and Uhland are incorporated cities that straddle the Caldwell County line with either Hays or Travis Counties.

Dale, Fentress, Lytton Springs, McMahan and Prairie Lea are some of the larger unincorporated communities in Caldwell County. *Exhibit 2-1* illustrates the location of the cities and more populated communities in Caldwell County.

There are numerous other settlements in the County that are recognized geographically and include Brownsboro, Delhi, Elm Grove, Joilet, Maxwell, McNeil, Mendoza, Pettytown, Reedville, Saint Johns Colony, Seawillow, Soda Springs, Stairtown, Taylorsville, Tilman and Watts.

Major roadways that cross the county include United States (US) Highway 90 (east-west), US Highway 183 (north-south), SH 21, SH 80 and future SH 130 (northeast-southwest). Numerous other state and county roadways exist in the county that will provide easy connection to SH 130 and enable easy and fast travel to San Antonio, Austin and other destinations along the central Texas "I-35 corridor".



Construction for segments 5 and 6 of SH 130 is underway and completion is scheduled for the year 2012. Segment 5 will begin in Mustang Ridge and continue to north of Lockhart while Segment 6 will pick up at the southern end of Segment 5 and exit Caldwell County between Martindale and Fentress on the way to the intersection of SH 130 with I-10 near the City of Seguin in Guadalupe County. Approximately 40 miles of roadway will be constructed for these segments of SH 130.

SH 130 will be a four lane divided highway. It will have direct connection to interchanges and provide ramps for access to non-toll lanes. SH 130 will be a toll road and it is anticipated that tolls may remain to fund maintenance and future local transportation projects.


### 2.2 Land Use

Current land use within Caldwell County is illustrated by *Exhibit 2-2* and was obtained from the United States Department of Agriculture (USDA). Land in Caldwell County is mostly undeveloped and is used as pastureland, grassland, forestland or cropland. The developed areas are primarily located along US Highway 183, SH 21 and SH 80. Current population density is greatest in the northwest and north central portions of the county because of the area's proximity to San Marcos, Austin and the I-35 corridor.

The southern and southeast portions of the county, with the exception of Luling, remain largely rural in character in nature. The oil and gas industry has been an important part of the economy in Caldwell County but its footprint and impact on land use is relatively small.

### 2.3 Watersheds

Land in Caldwell County drains primarily to the Guadalupe River Basin. Regional watersheds in the basin include the San Marcos Watershed, Plum Creek




Klotz Associates Project No. 0972.000.000 January 2010 Watershed and Peach Creek Watershed. *Exhibit 2-3* illustrates the major watershed boundaries in the county.

A 58 square mile area in the northeastern corner of the county drains to the Colorado River Basin. The 58 square miles represents about 11 percent of the area of Caldwell County with the remaining 487 square miles draining to the Guadalupe River Basin.

Plum Creek is the largest watershed in Caldwell County. Plum Creek rises in Hays County and enters Caldwell County near Niederwald. It then flows from north to south through the heart of Caldwell County and enters the San Marcos River at the Caldwell/Gonzales County line. At its mouth, Plum Creek has a drainage area of 397 square miles and a stream length of 52 river miles. Approximately 80 percent (319 square miles) of the Plum Creek Watershed is in Caldwell County. The 319 square miles of the Plum Creek Watershed in Caldwell County comprises about 59 percent of the total area within Caldwell County. Plum Creek is an important surface water feature in Caldwell County and the citizens of the county have a vested interest in protecting the character and health of this historic and highly-valued water course.

The area within Caldwell County draining to the San Marcos River Watershed is 88 square miles or about 16 percent of the county. The San Marcos River flows south from the San Marcos city limits until it joins the Guadalupe River approximately 75 miles downstream near Gonzales, Texas. At its confluence with the Guadalupe River, the San Marcos River Basin has a total drainage area of 522 square miles. The San Marcos River is the western boundary of Caldwell County with a length along this boundary of 43 stream miles.

The Peach Creek Watershed has a total drainage area of 480 square miles at its mouth with approximately 81 square miles (about 14 percent of the county) of the watershed in Caldwell County. Peach Creek joins the Guadalupe River near the community of Harmon in Gonzales County.



### 2.4 Certificates of Convenience and Necessity (CCN)

In Caldwell County, there are twelve (12) water and four (4) wastewater utilities that hold a Certificate of Convenience and Necessity (CCN). A CCN is obtained by utilities for the purpose of defining a service area for municipal and public utility providers. A municipal utility defines a city, village or township and a public utility or water supply corporation (WSC) identifies a corporation or individual has ownership and responsibility.


### 2.4.1 Water CCN Utilities


Caldwell County has twelve (12) water providers that serve portions of Caldwell County. *Exhibit 2-4* outlines the areas within the CCN in Caldwell County that is held by the water service providers. The Texas Commission on Environmental Quality (TCEQ) provided the geographic information system (GIS) data through the Water Utility District (WUD) database. Luling and Lockhart are municipal utilities and the other providers are water supply corporations and special utility districts.

### 2.4.2 Wastewater CCN Utilities

Wastewater utilities in the county are limited due to the largely rural land use in the county. Undeveloped areas rely on on-site sewage facilities (OSSF) for treatment and disposal of sewage. The TCEQ discharge permits that were identified are shown in *Exhibit 2-5*.

Although Turner Crest Village LLC has obtained a wastewater discharge permit, the wastewater facilities have not been constructed. The intended service area is a large subdivision that will be developed based on demand for residential lots grows.






The City of Lockhart has two wastewater treatment plants that are operated and maintained by GBRA to serve the city residents. The facilities are located to the east of Lockhart.


The City of Luling also has two municipal facilities each to serve the city. The facilities in Luling are located to the northeast and southwest of the city limits.

#### 2.5 Climate

The climate in Caldwell County is sub-tropical and humid. Low temperatures (40 degrees Fahrenheit (°F)) occur in the months of January and December and high temperatures (95 °F) occur in July and August. Average annual rainfall is approximately 37 inches per year and average the monthly precipitation varies from 1.8 inches in July to 4.4 inches in May. *Table 2-1* presents the average temperatures, precipitation with record lows and highs as measured in the county at Lockhart, Texas. *Graph 2-1* and *Graph 2-2* graphically presents the information provided in the tables.

TABLE 2-1           Lockhart, Texas Monthly Average Temperatures and Precipitation						
Month	Average High	Average Low	Mean	Average Precipitation	Record High	Record Low
January	61°F	37°F	49	2.27	89°F (1975)	-3°F (1949)
February	66°F	41°F	54	2.2	99°F (1996)	4°F (1951)
March	74°F	48°F	61	2.22	100°F (1971)	17°F (2002)
April	80°F	55°F	67	3.06	100°F (1939)	26°F (1971)
May	86°F	64°F	75	5.44	105°F (1967)	40°F (1903)
June	92°F	70°F	81	4.29	108°F (1934)	50°F (1919)
July	96°F	72°F	84	1.7	110°F (1954)	58°F (1967)
August	96°F	71°F	84	2.32	109°F (1943)	56°F (1992)
September	91°F	66°F	79	3.7	110°F (2000)	41°F (1981)
October	83°F	56°F	70	4.36	99°F (1937)	26°F (1993)
November	72°F	47°F	59	3	92°F (1969)	19°F (1911)
December	64°F	39°F	51	2.3	88°F (1955)	4°F (1989)





#### 2.6 Topography


The topography of Caldwell County is comprised of flat to rolling terrain with elevations ranging from 310 feet to approximately 750 feet above sea level. The highest elevations are in the northern part of the county and are in the range of 750 feet above mean sea level along the ridges that divide the San Marcos and Plum Creek watersheds. The lowest elevations are found in the southern portion of the county at the confluence of the San Marcos River and Plum Creek. The lowest elevation at the confluence is approximately 310 feet. *Exhibit 2-6* illustrates elevation variances in the county. The elevation at Lockhart is about 515 feet and the elevation at Luling approximately 410 feet.


# 2.7 Transmission System


The Transmission System in Caldwell County consist of a 345 KV transmission line with one Substation North of Lockhart, some138 KV transmission lines with 4 substations and several 69 KV transmission lines with 9 substations. *Exhibit 2-7* illustrates the approximate line locations and identifies the northern area of the county with the most activity. The map was prepared using the ERCOT 2008 Texas Transmission Map.

#### 2.8 Impervious Cover

Impervious cover data obtained for Caldwell County indicates that the overall impervious cover percentage is approximately 0.6%. High impervious cover percentages are found in cities and near state roadways. *Exhibit 2-8* illustrates impervious cover locations in the county. The red color in the map identifies the areas with a high value of impervious cover while the predominantly blue color symbolizes the most pervious areas. The impervious cover data was obtained from USGS spatial data.







#### **SECTION 3**

# DATA COLLECTION

#### 3.1 General

Information for the study was obtained through interviews, meetings, surveys, and existing reports and studies. The data collected was specific to water use, population estimates, water quality issues and concerns. The information obtained from surveys regarding existing facilities was used to analyze current systems and develop recommendations for future systems.

# 3.2 Survey

The survey for this study was prepared in January 2009 and sent by fax and email to participants. The questionnaire was prepared for water and wastewater utilities that held CCNs in Caldwell County. The information requested in the survey was classified as general information, population information, water quality, water conservation and plans to meet future needs. The survey provided an opportunity for respondents to provide additional information the respondent believed to be pertinent to the study. A copy of the survey can be found in **Appendix B**.

The information requested from water utilities related to the groundwater sources, usage and water quality. Questions included; source of the water supply, CCN number and year granted, average daily water use, historic peak volume for water delivery and year, volume of water pumped into the system, volume of water billed, customer data on type of meters, future planning projections on meters use, description of water production facilities, population estimates for past five years and projections for next 30 years, and a list of top water users and amount. National Pollutant Discharge Elimination System (NPDES) permit information was also requested as well as any issues with water sources and concerns regarding point source discharges and non-point source pollution that may impact

water quality in the county. Finally, water conservation measures and future efforts were listed.

Wastewater collection utilities were requested to indicate whether they owned and operated a wastewater collection system, treatment plant, or if others operated the facility. Information requested included CCN number(s) and date granted, average daily wastewater flow for plants, historic peak day volume for wastewater treatment, volume of water treated, volume of water billed, sewer connection types, future projections for sewer connections, type of treatment plant and rated capacity, top wastewater producers, and a list of NPDES permits held by facility. Lastly, inquiries were also made about re-use of treated wastewater, plans to support future growth, and description of changes/upgrades for treatment facilities. The survey requested additional comments that the respondents believed to be pertinent to the study.

The survey was completed by eleven (11) of the twelve (12) water providers and three (3) of the four (4) wastewater CCN permit holders. The task of gathering the information requested in the survey did require time and effort from the respondents and the information provided was valuable in understanding the current conditions in the county and developing potential solutions.

The entities participating in the survey were contacted by phone to schedule times, if preferred, to visit with and clarify any questions about the survey and the information being requested. These surveyed participants included:

Aqua Water Supply Corporation	County Line WSC
City of Lockhart	City of Luling
Creedmoor Maha	Goforth WSC
Gonzales County WSC	Martindale WSC
Maxwell WSC	Polonia WSC
Tri Community WSC	Turner Crest Village

Throughout the planning study three meetings were held at the Caldwell County Annex in Lockhart, Texas to gather input from the community. Updates and presentations were held on the progress of the study and input was received on the draft report. Sign in sheets for the stakeholder meetings have been included in **Appendix A.** 

# 3.3 Regional Coordination

Exchanging information with local government entities, groundwater districts, water authorities, and state agencies was considered necessary as a part of the study. Interviews were conducted with Canyon Regional Water Authority, Gonzales County Groundwater Conservation District, Hays/Caldwell Public Utility Agency (PUA), San Antonio River Authority, and the Texas State Data Center (TSDC). Other information was obtained from Capital Area Council of Governments, TWDB, TCEQ, the Texas Department of Transportation (TxDOT), Caldwell County Appraisal District (CCAD), and the Electric Reliability Council of Texas (ERCOT).

The following participants were represented in the Stakeholder Meetings for this study:

Bluebonnet Electric Cooperative	Texas Water Development Board				
Crystal Clear Water Supply Corporation	Envision Central Texas				
Caldwell County	Hays Caldwell Public Utility Agency				
Canyon Regional Water Authority	City of Lockhart				
Luling Foundation	Lockhart I.S.D				
Edwards Aquifer Authority	Plum Creek Conservation District				
Guadalupe-Blanco River Authority County Landowner					
Plum Creek Watershed Partnership					
Gonzales County Groundwater Conservation District					
Texas State Soil & Water Conservation Board					

# **SECTION 4**

# GROUNDWATER


#### 4.1 Groundwater Sources

Groundwater in Caldwell County remains the primary source of potable water. Most water utilities have wells that pump water from local aquifers. Groundwater in the region is produced by aquifer formations that include the Leona, Carrizo, and Wilcox Aquifers. The formations vary from the Cretaceous to Quaternary time period as listed in *Table 4-1*. The table and *Exhibit 4-1* were provided by Feathergail Wilson, Professional Geologist. Mr. Wilson also provided valuable details and information regarding the groundwater resources in the region.

TABLE 4-1           Caldwell County Stratigraphy					
PERIOD EPOCH FORMATION/GROUP MAP SYMBOL LITHOLOGY					
Quaternary	Holocene	Undesignated	Qal, Qt	alluvium sand, silt, clay	
	Pleistocene	Leona	Qle	gravel	
		Weches	Ew	glauconitic fossiliferous clay	
Paleogene Eocene		Queen City	Eqc	sand and clay	
		Reklaw	Er	clay and sand	
		Carrizo	Ec	sand	
		Wilcox	Ewi	sand and clay	
	Paleocene	Midway	Emi	clay	
Cretaceous	Late	Navarro	Kknm	expanding clay	
		Pecan Gap	kpg	chalk	

# 4.1.1 Leona Formation

The Leona Formation is an alluvial outcrop formation that extends from Kyle to about 10 miles southeast of Lockhart. It is primarily gravel stratified with some sands, clay and silt. "In some locations the gravel is so well cemented that the end result is a hard compact conglomerate resembling concrete." (Follet, 1966) Lockhart's water supply was completely provided for by the Leona Formation



before 1953. Deterioration in water quality from the Leona Formation has made this source of water unsuitable for potable water use unless the water is treated. The extensive use of chemicals in agricultural production is a likely reason for high nitrate levels in the Leona Formation. The water from this shallow formation is used primarily used for irrigation.

The Leona aquifer has an approximate thickness of about 40 feet and can yield small to large quantities of water. It has a gradient that averages 10 feet per mile. The hydraulic conductivity, which describes the movement of water through pores spaces, is expected to range from  $10^0$  to  $10^{-7}$  centimeters per second (cm/sec). Flow is generally to the southeast and is believed to recharge the underlying Wilcox.


#### 4.1.2 Wilcox Formation

The Wilcox Formation is another water bearing unit in Caldwell County. The formation outcrops in the central part of the county, as shown in the Caldwell County Surface Geology Map, *Exhibit 4-1*. The Wilcox Group, from youngest to oldest formations, includes the Hooper, Simsboro, and Calvert Bluff. The geological label for the Wilcox outcrop label, Ewi, is shown in *Table 4-1*.

The outcrop width range is approximately 8 to 10 miles. It then slopes steeply downward at about 150 feet per mile. The thickness of the formation increases as the depth increases and is mostly composed of sand and clay. Maximum thickness in the study area is approximately 2,000 feet and occurs in the southeastern portion of the county as shown in *Exhibit 4-2*. Fresh to saline water can be found at depths of 50 feet to 2,800 feet in the southeastern area.

#### 4.1.3 Carrizo Formation

The overlying formation on the Wilcox Formation is the Carrizo Formation. In Caldwell County, the Carrizo Formation is generally white, coarser-grained and



loose sand. The sand tends to be free of finer clays. The Carrizo outcrop is located in the southeastern part of the county. The cement-like characteristics of the Carrizo at the outcrop cause a rise in elevation. The stratum of the Carrizo dips downward from the outcrop at about 140 feet per mile with a general thickness of about 400 feet. The overlying sands have a higher hydraulic conductivity than the Wilcox. In some parts of the county a clay liner acts as a seal to separate the two water-bearing units.

#### 4.1.4 Recklaw Formation

The Recklaw Formation overlays the Carrizo and crops out at the southeast corner of the county. It is about 2 to 3 miles wide and with a maximum thickness at approximately 400 feet. It dips downward at about 140 feet every mile. Sand and silt define the lower portion of the formation and clay with thin beds of sandstone classifies the upper portion.

# 4.1.5 Queen City Sands Outcrop

The Queen City Sands outcrop is approximately 3 to 4 miles in width. The formation dips southeast at about 120 feet per mile. The thickness increases to approximately 500 feet. The formation includes fine to medium sands and clay.

The water in this formation was reported to have total dissolved solids that ranged from about 500 parts per million (ppm) near Bastrop and Fayette Counties to 3,000 ppm near the Gonzales county line.

# 4.2 Groundwater Quality

The water quality of the region varies depending on the aquifer and the depth at which it is found. The chemical constituents in ground water originate primarily from the soil and rocks it seeps through. As depth increases so does the chemical and sodium content while hardness decreases. The suitability of the water depends largely on the chemical quality.

Chemical constituents found in water are compared to water quality standards developed by states. The state standards have to be approved by the Environmental Protection Agency (EPA) for implementation. Current drinking water standards for Texas are listed in the Texas Administrative Code (TAC) 209 Subchapter F. A list of the water quality standards has been placed in **Appendix C.** Various requirements have been imposed to regulate maximum contaminant levels in drinking water. Some of the most common contaminants include total dissolved solids (TDS), chloride (Cl), fluoride (F), iron (Fe), manganese (Mn), nitrate (NO<sub>3</sub>), and sulfate (SO<sub>4</sub>).

A Water Quality Publication Report prepared by the TWDB lists wells and the water quality testing results in Caldwell County. A page of the report has been included in **Appendix D** for review. The report list the constituents found and their respective contaminant levels.

Due to the high quality of groundwater in the Wilcox-Carrizo formation, it is the most desired source for developing wells. TDS in the southeast and southwest corner of the county are less than 500 ppm. However, TDS increase significantly in between these corners. Well monitoring and observations indicate an arch in the formation which degrades the water quality in this area.

There are few areas in the Wilcox-Carrizo formation near Caldwell County that exceed the sulfate and chloride drinking water standards of 300 ppm. In the southeast corner of the county sulfate was found to exceed 300 ppm in areas where total dissolved solids were under 1000 ppm. Chloride constituents were not reported to exceed the standards.

#### 4.3 Groundwater Conservation Districts


Groundwater conservation districts (GCD) were first created by the Texas Legislature in 1949. They are charged with developing and implementing comprehensive management plans that conserve and protect groundwater resources. *Exhibit 4-3* illustrates the GCD that have been established in Texas. The districts plan for the future, work to collect data, educate consumers about water conservation, and prevent waste of water. A board of directors oversees the districts with guidance from the TWDB.


In Caldwell County the management districts are the Plum Creek Conservation District (PCCD), the Gonzales County Underground Water Conservation District (GCUWCD), and the Edwards Aquifer Authority (EAA). These boundaries of these districts are illustrated in *Exhibit 4-4*. The PCCD and the GCUWCD currently have some overlapping areas that have created uncertainty about the rules that apply for the land owners in the overlapping area.

Rules for developing wells and issuing permits by the PCCD and the GCUWCD are similar at times but generally defined and managed differently. In general, the approach to manage groundwater are established in Management Plans and Rules established by each district.

# 4.3.1 Plum Creek Conservation District

PCCD is currently working with other districts within groundwater management area (GMA) 13 develop and adopt a desired future condition (DFC) for the aquifers within the management area. Once adopted, the DFC of the aquifers will establish quantified conditions of available groundwater resources based on hydrological studies and modeling. Due to the current status of the DFC not being established, PCCD has potentially issued more permits for groundwater than is currently available. Current laws require GCD to permit to the extent possible of





the managed available groundwater. The groundwater permits that have been approved by PCCD are shown in *Table 4-2*. In addition to the listed permits in Table 4-2, PCCD received an application from the Plum Creek Group (prepared by Murfee Engineering Company) requesting 15,000 acre feet per year from the 4,384 acres that PCCD annexed on March 25, 2008 in the Southeastern part of Caldwell County.

TABLE 4-2         Plum Creek Conservation District Groundwater Permits					
Type of Permit	Name	Number of Wells	Quantity (acft/year)	Date Permitted	
Agriculture- Irrigation Permits	Joe Smith	2	400	2/21/06	
Agriculture- Irrigation Permits	Brenda Horton	1	43	6/21/07	
Agriculture- Irrigation Permits	Ben Tidwell	1	168	12/18/07	
Agriculture- Irrigation Permits	Giacomel	1	22	9/12/07	
Agriculture- Irrigation Permits	Joe Wells	1	31	6/2004	
Agriculture- Irrigation Permits	Martin Pratka	1	43	9/12/06	
Agriculture- Irrigation Permits	A.E. Nicholson	4	4,000	2/17/09	
Public Supply Permits	City of Lockhart	7	5,475	7/15/08	
Public Supply Permits	Dale WSC	1	269	6/17/08	
Public Supply Permits *Public Supply	Polonia WSC	5	2,283	6/17/08	
Permits	Polonia WSC	1	1,343	-	
*Public Supply Permits Public Supply Permits	Hazelette Luling	1	200 1,612	- 8/19/08	
Public Supply Permits	Aqua Water	3	625	11/20/07	
Total 16,514					

PCCD has established a Groundwater Management Plan & Protection Rules (adopted December 16, 2003) in effort to protect, preserve, enhance, and insure the beneficial resources within its jurisdiction. A Groundwater Management Plan, which is a separate document, has also been prepared and was adopted in 2007 to support the efforts of PCCD. The district rules attempt to regulate groundwater by means of well spacing based on production rates. *Table 4-3* provides a list of the spacing production provisions.

TABLE 4-3           PCCD Classification, Spacing, and Production Provisions					
Actual Pumping Capacity of Proposed Well (GPM) Classification of Proposed Well		Minimum Distance from Newest Existing Well on Authorized Well Site			
Less than 25 GPM	Domestic	None			
25 - 100	А	600 Feet			
101 - 250	В	1,500 Feet			
251 - 500	С	3,000 Feet			
501 - 1,000	D	6,000 Feet			
1,001 GPM and over	Е	12,000 Feet			

Note:

Wells drilled after December 31, 2003 shall either perform a hydrologic study approved by the District designed to demonstrate the impact of the permitted well on wells located within a one-half mile radius, or comply with the District's spacing requirements. Wells are classified according to actual pumping capacity in gallons per minute (GPM) under normal operating conditions.

# 4.3.2 Gonzales County Underground Water Conservation District

The GCUWCD was created on an order of the Texas Natural Resource conservation Commission number 101692-Do4 and is charged specifically with managing the Sparta, Queen City, and the Carrizo-Wilcox aquifers in Gonzales County. The goals of the Management Plan and Rules established by the district are to conserve, preserve, protect and prevent waste for the future of Gonzales County.

The goals of the district are carried out through the GCUWCD Rules and Management Plan. The plan defines spacing requirements and pumping production limitation to manage the groundwater. Although the DFC has not been developed, a drawdown of 100 feet in the Carrizo will curtail pumping. A list of tables and rules from the PCCD and the GCUWCD has been included in **Appendix E**.

The GCUWCD is also working with other districts in GMA 13 to develop DFC which will revise the current Management Plan to reflect the managed available groundwater (MAG). The GCUWCD is in the same situation as PCCD with possible over permitting of the Carrizo-Wilcox Aquifer.

In February 2009, the GCUWCD stated that the only permitted public transporter was the Schertz-Seguin Local Government Corporation (SSLGC) for 12,900 acrefeet per year. The length of the transport permit is 30 years. The SSLGC supplies water to the cities of Schertz and Seguin. Permits under review were submitted by CRWA and SAWS. Aqua WSC also has wells that were established before the creation of the GCUWCD and have been grandfathered on the east side of Gonzales County. Those existing wells remain operational under the grandfather provision and do not need to adhere to the current rules of the district.

# **SECTION 5**

#### SURFACE WATER

#### 5.1 General


Surface water in Texas is owned by the state and permission to use the water is granted through a "water right". When a water right is acquired, water may then be diverted from its natural channel for use. However, a water right does not guarantee that water will be available. Water availability is determined by many factors but the most important are precipitation and subsequent water recharge. Average annual precipitation in Texas is illustrated in *Exhibit 5-1* with average annual precipitation in Caldwell County ranging from about 32 inches to 38 inches. Water rights permit allow the holder to divert stream flow for municipal, industrial, irrigation, mining, hydropower, and recreational use provided water is available and the use is not wasteful.


# 5.2 Surface Water Supply Sources

Surface water use for Caldwell County has ranged annually depending on availability from the Guadalupe and Colorado River Basins. Data obtained from the TWDB indicates that historic annual surface water use for Caldwell County ranged from 2,500 ac-ft to about 3,500 ac-ft. The surface water use illustrated in *Graph 5-1* depicts the total of the Guadalupe and Colorado River Basins from 1974 to 2004. The TWDB reports that provided the data are in **Appendix F**.

# 5.2.1 Guadalupe River Basin

The Guadalupe River Basin serves as the primary source of surface water for Caldwell County. The Guadalupe River Basin is entirely in Texas and is largely within the statutory district of the GBRA as shown in *Exhibit 5-2*. The Guadalupe River Basin is a valued source of water to local and regional suppliers.







Approximately 66% of the water vendors surveyed indicated that they use surface water purchased from GBRA.

Water (surface water and groundwater) used in Caldwell County from within the boundaries of the Guadalupe River Basin has historically averaged about 6,500 ac-ft per year. The Guadalupe Basin remains the primary source of water for the county. *Graph 5-2* illustrates the historical water in Caldwell County by basin of origin.

# 5.2.2 Colorado River Basin

The Colorado River Drainage basin has reportedly provided less than 6.5% of the reported water use in Caldwell County. The portion of the drainage basin in the






county has yielded an average of 350 ac-ft annually. The Colorado River Basin is managed by the Lower Colorado River Authority (LCRA).

# 5.3 Surface Water Supply Uses

Municipal use is the county's major use of surface water. Based on historical data from 1990 to 2004, municipal water use has accounted for between 65% and 80% of the total water used in the county. *Graph 5-3* illustrates historical percentages of surface water use for typical categories. Although irrigation and livestock water use have decreased, they still account for about 20%. Mining, steam electric and manufacturing account for less than 0.5% of the water used in the County.

#### 5.4 Surface Water Rights

Currently, surface water is accessed and obtained through a water rights permitting process prescribed by the TCEQ. Anyone desiring to use surface water



needs a permit from the State of Texas. Exemptions from this requirement are available for (1) domestic and livestock use, (2) wildlife management, (3) emergency use, and (4) other specified uses listed in the Texas Water Code.

Through these appropriated rights users are allowed to divert and store water for use. However, a priority date is assigned to each right granted. The priority date determines the order of water to be used. It is a pecking order for water use. In drought conditions and when stream flows are lowered and reduced, the TCEQ administers water rights on a priority basis known as "first in time, first in right."

A list of water rights for Caldwell County can be found in **Appendix G**. This data was obtained from a TCEQ water rights database. Most of the water rights listed for Caldwell County are associated with the San Marcos River. The largest permitted volumes are owned by GBRA and Hydraco Power, Inc.

# **SECTION 6**

#### POPULATION

#### 6.1 **Population Projections**

Population projections are necessary planning tools to prepare for future growth and development. Preparing for future growth can prevent overburdening current infrastructure and help identify systems and resources that are necessary to successfully handle an increase in population.

The science of predicting future population is at best, an estimate. Projections use existing data estimate available for births, deaths, migration, age/sex, and ethnicity to develop rates and run population scenarios that are plausible for future growth patterns. The US Census Bureau and the Texas State Data Center (TSDC) are two agencies that provide these estimates to be used or further analyzed by local communities for planning purposes.

The US Census Bureau and TSDC estimates vary due to accessible, updated, and available information. For example, the US Census Bureau uses the income tax data that is not available to other agencies to do the estimates. The TSDC uses current birth and death data not readily accessible to the US Census Bureau. The US Census Bureau also performs analysis at a national level with no regard to annexation and boundary changes that the TSDC considers.

# 6.2 Texas State Data Center

Population projection estimates developed by the TSDC incorporate migration patterns of ethnic groups by sex, age, standard birth and death rates to produce four scenarios of expected growth. The four common migration scenarios considered for Caldwell County are as follows:


- 1. Zero Net Migration (0) Assumes immigration and migration rates are equal
- Net Migration Equals One-Half 1990-2000 (0.5) Average of Zero and 1990-2000 Net Migration rates. Assumes rates of onehalf of the 1990's.
- Net Migration Equal to 1990-2000 (1.0) High growth alternative based on high growth rates on 1990's.
- 4. Net Migration Equal to 2000-2007 (200-2007) Post 2000 population trends with reduced levels of migration.

According to the State Demographer, who develops the projections at the TSDC, the recommendation for most cases is the 0.5 scenario, where Net Migration is equal to one-half 1990-2000. The 0.5 scenario predicts the most practical growth scenario. However, after further review and consideration of SH 130, the State Demographer suggested that Caldwell County consider Scenario 1.0 for planning purposes.

Population projections for scenario 1.0 may be more practical with the change SH 130 will bring in connecting two of fastest growing cities. A population projection estimate at a micro-level can reveal that factors such as transportation, land use, development planning, density in adjacent counties and other local level data would cause a wave of growth for Caldwell County. The limitation of forecasting for projected population estimates at a micro-level is acknowledged by the TWDB.

# 6.3 Texas Water Development Board

The population projections that were developed by the TWDB and adopted into the State Water Plan on September 13, 2003 are presented in *Graph 6-1*. The projection for Caldwell County assumes that the population growth rate will be the same in the future as it was in 1990 and 2000. The growth rate estimates were




calculated using the most probable scenario from the Texas State Data Center (Scenario 0.5) for migration. The information from the Texas State Data Center was used as a baseline in establishing population projections.

The projections established by the TWDB are limited at forecasting the microlevel growth. The estimates do not account for events and moments that alter the demographics of a county. An event such as the completion of SH 130 can not be measured. The result in population change due to this event is considered to be underestimated. Historic patterns have not described the implications of new routes to population growth waves.


The population projections are presented in Volume II, Appendix 4.1, of Water for Texas dated January 2007.

#### 6.4 **Population History and Growth Estimates**

Historically, a change in population due to events is noticeable in the acquisition of data. For example, in 1922 a man by the name of Edgar B. Davis discovered oil in what is now Luling, Texas. The "oil boom" was an event that impacted and changed Caldwell County. Only historic data, shown in *Graph 6-2*, can accurately illustrate the change.



As the future of Caldwell County is being planned, it is recommended to plan for the most conservative scenario as stated by the State Demographer. As shown in *Graph 6-3*, the fastest growth case scenario from the data available is provided by the Texas State Data Center, scenario 1.0.



The TWDB estimates the population to be at 83,250 by the year 2040 and the Texas State Data Center estimates the population at 111,210 by the year 2040, as shown *Graph 6-4*. The individuals that will populate Caldwell County vary in opinion by as much as 25%. The TWDB does project population estimates in the hundred thousandths but it is not until the year 2060.

# 6.5 **Population Consensus**

The population projections were presented to the Caldwell County Technical Advisory Committee and Stakeholders in meetings. Although Caldwell County did not dispute the population projections developed by the TWDB in the SCTRWP, there was disagreement about the estimate. Through a consensus it was agreed to proceed with the estimates from the TSDC (Scenario 1.0) with a revision. The revision was to decrease the population projection in the year 2040

to a value that was within the values of the TSDC and the TWDB. *Table 6-1* has been prepared to list the estimated population values developed by the TSDC and the TWDB. It was agreed to proceed with an estimate of 100,000 in 2040 for the purpose of this study. Accordingly, population projections used for this study are listed in *Table 6-2*.




TABLE 6-1 Population Projection Estimates						
Year	Voon Texas State Data Center Population Scenarios					
	0.0	0.5	1	2000-2007	TWDB	
2010	34,844	40,289	46,308	38,724	45,958	
2020	37,355	49,975	65,057	45,622	59,722	
2030	39,258	60,127	86,902	51,469	71,459	
2040	40,677	70,593	111,210	55,752	83,250	

TABLE 6-2 Planning Study Population Projections				
Year Population				
2010	46,308			
2020	65,057			
2030	86,902			
2040	100,000			


# **SECTION 7**

# FACILITIES INVENTORY

#### 7.1 Water Facilities Inventory

Caldwell County is supplied water by 12 CCN and numerous private wells. The information provided below is a compilation of data obtained from the TCEQ database and surveys. *Table 7-1* provides a list of the CCNs for water. The 12 CCN holders, production wells, and water treatment plants are shown in *Exhibit 7-1*. Although water is primarily produced through the allocation of groundwater well permits, 66% of the water providers obtain additional water through surface water rights. The CCN holders in the county are Municipal, Water Supply Corporations (WSC), and Special Utility Districts (SUD).

TABLE 7-1 Water Supply CCN					
Utility Name	Ownership Type	Primary County	Serving Counties		
Aqua	WSC	Bastrop	Caldwell, Lee, Travis		
City of Lockhart	Municipality	Caldwell	None		
City of Luling	Municipality	Caldwell	None		
County Line	WSC	Hays	Caldwell		
Creedmoor Maha	WSC	Travis	Caldwell, Bastrop, Hays		
Goforth	WSC	Hays	Caldwell, Travis		
Gonzales County	WSC	Gonzales	Caldwell, Dewitt, Guadalupe		
Martindale	WSC	Caldwell	Guadalupe, Hays		
Maxwell	WSC	Caldwell	Hays		
Polonia	WSC	Caldwell	Bastrop		
San Marcos	Municipal	Hays	Caldwell, Comal, Guadalupe		
Tri-Community	WSC	Caldwell	Guadalupe		



An inventory of the information to be presented in this section below has been prepared in *Table 7-2*.

TABLE 7-2 TCEQ Water CCN Database Inventory									
Water User Group	Total Storage (MG)	Elevated Storage (MG)	Total Production (MGD)	Average Daily Consumption (MGD)					
Aqua WSC	12.12	5.64	24.71	4.97					
City of Lockhart WSC	3.65	1.05	8.298	1.8					
City of Luling	1.65	0.9	2.5	1.99					
Creedmoor Maha	1.511	1.325	5.083	0.61					
Martindale WSC	0.344	0.28	0.378	0.205					
Maxwell WSC	1.238	1.238	2.67	0.431					
Polonia WSC	0.961	0.475	1.845	0.367					
TriCommunity WSC	0.338	0.12	0.713	0.125					
County Line WSC	1.5	1.37	0.864	0.47					
Goforth WSC	1.992	1.068	6.192	0.936					
San Marcos	6.941	3.161	36.850	6.507					
Gonzales County WSC	1.44	0.459	3.37	1.229					

# 7.1.1 Aqua Water Supply Corporation

Aqua Water Supply Corporation (CCN# 10294 est. 1969) produces groundwater from the Carrizo Aquifer. The service area includes Bastrop, Caldwell, Lee and Travis Counties. Aqua WSC currently services the southeast area of Caldwell County.

It is reported to have a total storage capacity of 12.12 million gallons (MG) with an elevated storage capacity of 5.640 MG. Production of Aqua WCS is 24.71 million gallons per day (MGD) with an average daily consumption of 4.970 MGD for the service area. In Caldwell County, the uses are primarily for residential.

Klotz Associates Project No. 0972.000.000 January 2010

### 7.1.2 City of Lockhart

The City of Lockhart (CCN# 10295 est. 1952) is a municipality that provides groundwater from the Carrizo Aquifer. Surface water is supplied by GBRA through run-of-river rights. Surface water currently accounts for more than half of the water supply. The service area for Lockhart is entirely in Caldwell County.

The total storage capacity is 3.650 MG with an elevated storage capacity of 1.050 MG. The total production is 8.298 MGD with a maximum purchase capacity noted to be 4.0 MGD and a service pump capacity of 4.896 MGD. Average daily consumption is 1.818 MGD. The meter count was 3,865 and uses in Caldwell County were classified as residential, commercial/industrial and other.

## 7.1.3 Creedmoor Maha Water Supply Corporation

Creedmoor Maha (CCN# 11029 est. 1965) produces groundwater from the Edwards (Barton Springs) Aquifer and purchases groundwater from Aqua WSC. Creedmoor Maha obtains treated and raw surface water from Austin. The service area extends into Bastrop, Caldwell, Hays, and Travis with the latter being the primary county. Creedmoor Maha services Mustang Ridge which has city limits inside Caldwell County.

The total storage capacity is 1.511 MG with an elevated storage capacity of 1.325 MG and pressure tank capacity of 0.01420 MG. The total production is 5.083 MGD with a service pump capacity of 3.154 MGD and an average daily consumption of 0.610 MGD. A total meter count was listed to be 2,244 in 2008. Customer base in Caldwell County is presently residential and commercial.

# 7.1.4 City of Luling

The City of Luling (CCN# 10291) is a municipality that provides surface water from run-of-river rights from GBRA. In addition, the City has one well that can, if

needed, supply groundwater from the Carrizo Aquifer. Caldwell is the only county listed in the service area of the City of Luling.

The total storage capacity is 1.650 MG with an elevated storage capacity of 0.900 MG. The total production was not listed but a maximum purchase capacity was noted at 2.50 MGD and a service pump capacity at 2.304 MGD. Average daily consumption is 1.990 MGD. The meter count was 2,169 and uses were classified as residential, commercial/industrial, and other.

## 7.1.5 County Line Water Supply Corporation

County Line Water Supply Corporation (CCN# 10292) produces groundwater from the Edwards Aquifer and obtains surface water from GBRA and CRWA. The service area is in Hays and Caldwell County with Hays County listed as the primary county. County Line WSC services Uhland, which has city limits in northwest Caldwell County. Uhland is southwest of Neiderwald and northeast of Maxwell WSC.

The total storage capacity is 1.500 MG with an elevated storage capacity of 1.370 MG. It has a total production capacity of 0.864 MGD with a maximum purchase capacity of 2.040 MGD. The average daily consumption is 0.470 MGD with 1,977 meters in service. Residential meters are the primary use in Caldwell County.

# 7.1.6 Goforth Special Utility District

Goforth Special Utility District (CCN# 11356) produces groundwater from the Edwards (Barton Springs) Aquifer and purchases surface from CRWA and GBRA. Surface water, approximately 90%, is the primary source of water supply. The counties this utility serves include Caldwell, Hays, and Travis. The primary county for the utility is Hays. Goforth Special Utility District supplies water to

Neiderwald. The service area in Caldwell County is located northwest of Lockhart. The area borders Polonia WSC to the north and west.

The total storage capacity is 1.992 MG with an elevated storage capacity of 1.068 MG and pressure tank capacity of 0.01 MG. The total production is 6.192 MGD with a maximum purchase capacity noted to be 0.90 MGD and a service pump capacity of 9.446 MGD. Average daily consumption is 0.936 MGD. The meter count was 4,002 and uses in Caldwell County were classified as residential and commercial/industrial.

## 7.1.7 Gonzales County Water Supply Corporation

Gonzales County Water Supply Corporation (CCN# 10704) produces groundwater from the Carrizo Aquifer and surface water is supplied from the Canyon Reservoir. The service area includes the counties of Caldwell, Dewitt, Gonzales, and Guadalupe. Gonzales County is the primary county of service.

The total storage capacity is listed to be 1.440 MG with an elevated storage capacity of 0.459 MG and pressure tank capacity of 0.06580 MG. Total production is 3.370 MGD with a maximum purchased capacity of 0.666 MGD. The service pump capacity is 16.013 MGD. Average daily consumption is 1.229 MGD with 2,293 meters in service. Caldwell County meters currently obtain water for residential use.

### 7.1.8 TriCommunity Water Supply Corporation

Tri Community Water Supply Corporation (CCN# 10313) produces groundwater from the Carrizo Aquifer. The service area includes the counties of Caldwell and Gonzales. Caldwell County is listed as the primary county. Tri Community WSC is located to the southwest of Lockhart and services the unincorporated areas of Fentress and Prairie Lea in Caldwell County.

The total storage capacity is listed to be 0.338 MG with an elevated storage capacity of 0.120 MG. Total production is 0.713 MGD with a service pump capacity of 1.872 MGD. Average daily consumption of 0.125 MGD is provided to 536 meters in service. Caldwell County meters primarily obtain water for residential use.

### 7.1.9 Martindale Water Supply Corporation

Martindale Water Supply Corporation (CCN#10312 est. 1965) produces groundwater from alluvial wells and obtains surface water from CRWA and GBRA. The Martindale WSC service area extends into Hays, and Guadalupe County. Caldwell County is listed as the primary service area. Martindale WSC provides water for all types of uses to the city of Martindale.

The total storage capacity is listed to be 0.344 MG with an elevated storage capacity of 0.280 MG and pressure tank capacity of 0.00200 MG. Total production is 0.648 MGD with a maximum purchased capacity of 0.378 MGD. The service pump has a capacity of 0.864 MGD. Average daily consumption is 0.205 MGD. Total service meter count is 838. Caldwell County meters currently obtain water for residential and commercial/industrial use.

### 7.1.10 Maxwell Water Supply Corporation

Maxwell Water Supply Corporation (CCN#10293 est. 1979) produces groundwater from the Edwards Aquifer and obtains surface water from GBRA and CRWA. The service area for Maxwell WSC lies in Hays and Caldwell counties. Caldwell County is listed as the primary service area. Maxwell WSC services the unincorporated area of Maxwell and Reedville. The service area lies in between the Martindale WSC area and the Lockhart Municipality territory.

The total storage capacity is 1.238 MG with an elevated storage capacity of 1.238 MGD. It has a total production capacity of 2.670 MGD with a maximum

purchase capacity of 6.0 MGD. The average daily consumption is 0.431 MGD with 1,437 meters in service. The majority of use is for residential use and some in commercial/industrial.

## 7.1.11 Polonia Water Supply Corporation

Polonia Water Supply Corporation (CCN#10420) produces groundwater from the Carrizo Aquifer and can purchase water from the City of Lockhart when needed. The Polonia WSC service area is primarily in Caldwell County with a portion extending into Bastrop County.

The total storage capacity is listed to be 0.961 MG with an elevated storage capacity of 0.475 MG and pressure tank capacity of 0.00400 MG. Total production is 1.845 MGD with a service pump capacity of 3.686 MGD. Average daily consumption is 0.367 MGD with a total of 1,884 meters in service for residential use.

# 7.1.12 City of San Marcos

The City of San Marcos Municipality (CCN # 10298) has the smallest service area extending into Caldwell County. Out of the 9,500 plus meters, only about 24 are located in Caldwell County for commercial use at the airport.

# 7.2 Regional Water Wholesalers

Regional water wholesalers for the county include Canyon Regional Water Authority (CRWA) and the Guadalupe-Blanco River Authority (GBRA).

# 7.2.1 Canyon Regional Water Authority

Canyon Regional Water Authority was created by the Texas Legislature in 1989 to supply cities and districts with potable water. The water they distribute is

treated before being routed to water supply corporations. CRWA currently serves Bexar, Wilson, Guadalupe, Comal, Hays and Caldwell Counties.

CRWA has operational responsibilities for two water treatment plants, Lake Dunlap Water Treatment Plant (WTP) and the Hays Caldwell WTP. The Lake Dunlap Water Treatment Plant is rated at 16.4 MGD and receives water from Canyon Lake. The Hays Caldwell WTP receives water from the San Marcos River and Guadalupe River (Lake Dunlap) and is rated at 6 MGD.

The water supply corporations that currently receive water from CRWA are Martindale WSC, Maxwell WSC, and County Line WSC.

## 7.2.2 Guadalupe Blanco River Authority

The GBRA (CCN# 20892, 12977) was established by the Texas Legislature in 1933 and reauthorized in 1935 as the Guadalupe-Blanco River Authority. GBRA serves the counties of Kendall, Comal, Hays, Caldwell, Guadalupe, Gonzales, DeWitt, Victoria, Calhoun and Refugio. The mandate of the GBRA is to conserve and protect the resources of the Guadalupe River Basin.

The services provided by GBRA include hydroelectric generation, water and wastewater treatment and raw water supply for municipal, industrial, and agricultural use.

In 2001 GBRA assumed operations as the contract operator for the Lockhart Water Treatment Plant. The well systems and water treatment plant are managed by the GBRA.

In 1978, GBRA constructed a water treatment plant in Luling with a capacity of 2.5 MG. Surface water from the San Marcos River is treated at the GBRA Luling Water Treatment Plant and delivered to the City of Luling and the City of

Lockhart. The plant is capable of diverting up to 4,422 acre-feet annually from the San Marcos River under a water rights permit issued by the State of Texas. Peak rated capacity is 2.779 MGD. Performance of the plant has earned state recognition through of the EPA with "The Environmental Excellence Award for Public Water Supply".


# 7.3 Wastewater Facilities Inventory

There are currently five wastewater facilities that are listed in the TCEQ database. Information regarding the facilities has been summarized in the following sections and an inventory of the data listed in *Table 7-3*. The location of these facilities can bee seen in *Exhibit 7-2*.

TABLE 7-3 Wastewater CCN							
Utility Name	Ownership Type	Primary County	Total Permitted Discharge (gpd)				
City of Lockhart	Municipality	Caldwell	2,600,000				
City of Luling (North/South)	Municipality	Caldwell	1,400,000				
Mustang Plaza	Private	Caldwell	99,000				
Sweetwater Utility LLC	Private	Hays	N/A				
Turner Crest	Private	Caldwell	300,000				

# 7.3.1 The City of Lockhart/ GBRA

The City of Lockhart (CCN# 20114) has two operational wastewater plants. The plants have a total combined discharge amount of 2.6 MGD. GBRA operates the Lockhart plants under state permit numbers WQ0010210-001 and WQ0010210-002.



In 1994 GBRA began operating the City of Lockhart's 1.1 MGD wastewater treatment plant on Larremore Street. The treated effluent is discharged through a pipeline to Town Branch and then into Plum Creek, Segment No. 1810 of the Guadalupe River Basin.

In 1999 an additional 1.5 MGD plant on F.M. 20 became operational in Lockhart. Septic tank waste is accepted and treated at the F.M. 20 Plant. A carousel activated sludge process is implemented at the plant along with ultraviolet (UV) light disinfection instead of chlorine. To ensure the effluent will not impair aquatic and other environments, daily sample tests are conducted to confirm the effluent meets all state and federal standards. The effluent is discharged into Plum Creek Segment No. 1810 of the Guadalupe River Basin.

### 7.3.2 The City of Luling

The City of Luling (CCN# 20113) has a North and South plant in operation. The plants have a combined discharge permit of 1.4 MGD. The wastewater treatment plants and collection systems are owned and operated by the City. The facilities are permitted under state permit numbers WQ0010582-001 and WQ0010582-002.

The North Plant has an operational permit that authorizes the discharge of treated wastewater at a volume not to exceed a daily average flow of 900,000 gallons per day. The discharge route is from the plant to Salt Branch then to Plum Creek.

The South Plant has an operational permit that authorizes the discharge of treated wastewater at a volume not to exceed a daily average flow of 500,000 gallons per day. The discharge from the site is routed to the Lower San Marcos River.

Wastewater is treated through the contact stabilization method and then discharged. The "sequence of operations in this process is aeration of raw

wastewater with return activated sludge, sedimentation to yield a clarified effluent, and re-aeration of the clarifier underflow with a portion wasted to an aerobic digester. Supernatant drawn from the digester is returned to the process influent. The raw wastewater aeration chamber, also referred to as the contact zone, is approximately one third of the total aeration volume." (Hammer, 1986)

Because system inefficiencies may develop with increases in population to process larger flows, the systems may not be as economical as conventional methods with larger demands.

## 7.3.3 Turner Crest Village Wastewater Company, LLC

Turner Crest Village WW CO (CCN# 21004) submitted an application for a facility that would be authorized to discharge treated wastewater at a volume no greater than 300,000 gallons per day. Under state permit no. WQ0014831-001 the discharge would be routed to an unnamed tributary of Morrison Creek, then to the Lower San Marcos River.

Turner Crest Village WW has not yet constructed the facility due to the conditions of the economy. The development of the subdivision has been postponed, perhaps indefinitely. No other information is available at this time.

### 7.3.4 Mustang Plaza

Mustang Plaza (CCN# 20953) affiliated with Aus-Tex Parts & Services, Ltd, is authorized to discharge treated wastewater at a volume not to exceed a daily average flow of 99,000 gallons per day. The discharge route is to an unnamed tributary of Cedar Creek and then to the Colorado River above La Grange. Limited information was available and obtained. Although the discharge point is located within Caldwell County the facility services Mustang Ridge.

### 7.3.5 Sweetwater Utility, LLC

Sweetwater Utility LLC (CCN# 20887) was listed to have a service area in Caldwell County for Neiderwald. The CCN boundaries extend into Caldwell County but the service area is primarily in Hays. Limited information was available and obtained. Unsuccessful attempts were made to contact and locate the CCN owners for more information on the utility.

### 7.3.6 Additional State Wastewater Permits

In addition to performing a CCN query on the TCEQ Database for Caldwell County, permitted wastewater facilities were also investigated. A list of the results has been presented in *Table 7-4*.

Additional active wastewater treatment facilities not located within a CCN include City of Martindale. The City of Martindale has been approved to treat domestic wastewater at a volume not to exceed a daily average flow of 57,000 gallons per day via surface irrigation of 32 acres of non-public access agricultural land. The permit submitted September 9, 2004 does not authorize discharge of pollutants into State waters. A few of the facilities are listed as inactive due to inactivity on the permit.

TABLE 7-4         TCEQ Permitted Wastewater Treatment Facilities							
State Permit No.	Applicant	Stream Segment	Status	Treatment			
WQ0010273-003	City of San Marcos and GBRA	1808	Inactive	Inactive			
WQ0011233-001	Texas Parks and Wildlife Department	1810	Inactive	Inactive			
WQ0013450-001	City of Martindale	1808	Active	Ground Application			
WQ0014033-001	Polonia WSC	1810	Active	Filter Backwash Effluent			
WQ0014033-002	Polonia WSC	1810	Active	Filter Backwash Effluent			
WQ0014104-001	AUS-TEX Parts & Services LLC	1434	Inactive	Inactive			
WQ0014439-001	Caldwell/Uhland 405 L P	1810	Inactive	Inactive			

#### **SECTION 8**

#### WATER DEMANDS

#### 8.1 Historical Water Use


Caldwell County currently has 14 water user groups (WUG) that supply water for various types of uses. There are twelve (12) entities that hold CCN and are listed as Municipal, Specialty Utility Districts, and Water Supply Corporations. The two (2) remaining user groups are state agencies. Several of the WUG supply water to other counties in addition to Caldwell.

Caldwell County water use has been primarily for municipal purposes. It appeared that prior to 1980 municipal water use accounted for about half of the water consumed, with livestock and irrigation representing the remainder. Historical water use data made available through the TWDB website is shown in *Table 8-1* and illustrated in *Graph 8-1*. The water consumption for the county, at an average of 4,800 ac-ft, has historically been used to meet municipal demands, and the remainder to meet demands for mining, manufacturing, livestock, and irrigation.

Water utilization for livestock has remained, for the most part, within the range of 800-950 ac-ft annually with an average of 850 ac-ft. Water consumption averaged about 220 ac-ft per year for manufacturing before 1986, after which there is none recorded for a few years. In 1993, manufacturing water use started up again with fluctuation of use typically less than 20 ac-ft. Irrigation use varies and ranges with minimum use of 182 ac-ft to a maximum of 1742 ac-ft annually. Mining water use has historically been limited to less than 70 ac-ft with a gradual decline in use. There is no record of water consumption for steam electric.

	TABLE 8-1           Caldwell County - TWDB Historical Water Use Summary           Unit: Acre Feet (ac-ft)									
Year	Municipal	Manufacturing	Steam Electric	Irrigation	Mining	Livestock	Total			
1974	3,069	206	0	1,660	70	1,149	6,154			
1980	4,033	219	0	1,600	0	1,036	6,888			
1984	5,092	240	0	694	27	834	6,887			
1985	4,430	224	0	499	27	747	5,927			
1986	4,483	223	0	500	0	817	6,023			
1987	4,617	0	0	500	28	803	5,948			
1988	4,904	0	0	500	25	841	6,270			
1989	4,855	0	0	1,198	27	827	6,907			
1990	4,931	0	0	1,375	27	816	7,149			
1991	4,320	0	0	954	13	836	6,123			
1992	4,456	0	0	1,513	13	835	6,817			
1993	4,825	2	0	1,127	12	769	6,735			
1994	4,718	11	0	1,361	12	890	6,992			
1995	4,755	10	0	1,696	12	907	7,380			
1996	5,186	12	0	1,742	12	801	7,753			
1997	4,584	10	0	1,560	12	869	7,035			
1998	4,813	8	0	1,705	12	816	7,354			
1999	4,818	8	0	1,621	12	910	7,369			
2000	4,929	11	0	989	12	917	6,858			
2001	4,534	200	0	1,590	6	888	7,218			
2002	4,311	6	0	1,590	6	958	6,871			
2003	4,978	0	0	1,065	6	965	7,014			
2004	4,770	1	0	183	6	1,051	6,011			

Data Source: Texas Water Development Board



### 8.2 TWDB Water Use Projections


The future water demands in *Table 8-2* and *Graph 8-2* were developed by the TWDB for Caldwell County. The demands have been estimated up to 2060. The years beyond 2040 have been shaded in the table since this study is not considering the same planning horizon.

The municipal water demand projections show a consistent linear increase from 6,306 ac-ft in 2010 to 10,555 ac-ft in 2040. According to the TWDB, the municipal water demand is based on population and expected water consumption for each person with a reduction to account for conservation. The GPCD varied in the county for each water user group.

Municipal water demand projections in the 2006 Region L Plan for Caldwell County were based on 122.5 gallons per capita per day (gpcpd) for year 2010 and 113.2 gpcpd for the year 2040. These demands are lower than the demands estimated for the whole of the South Central Region in the 2006 Region L Plan of 143 gpcpd in the year 2010 and 135 gpcpd in the year 2040.

The Caldwell County Study reported on herein used 150 gpcpd for the planning horizon of 2010 to 2040. These values were adopted based on surveys completed for water supply entities in Caldwell County. Water conservation practices could reduce the per capita demand by 10 to 20 percent. The larger per capita use rates in the Caldwell County study increase the volume of future water that must be developed to meet future needs when compared to the 2006 Region L Plan.

Water demands for mining are also expected to gradually increase about 1 ac-ft a decade from 14 ac-ft in 2010 to 17 ac-ft in 2040. Manufacturing increases about 3



ac-ft a decade from 15 ac-ft in 2010 to 24 ac-ft in 2040. The livestock water demands are projected to remain constant at 918 ac-ft. The constant demand implies no increase to the number or type of livestock in Caldwell County. A steady decrease is projected in irrigation from 1044 ac-ft in 2010 to 733 ac-ft in 2040. The decrease could signify a decrease in the acreage of crop land or crop type that requires less water application. The steam electric consumption is expected to remain zero as historical use has indicated.

TABLE 8-2         2006 Regional L - Caldwell County Water Demand Projections								
County Name	Category	2000	2010	2020	2030	2040	2050	2060
CALDWELL	Irrigation	989	1,044	928	824	733	651	578
CALDWELL	Livestock	918	918	918	918	918	918	918
CALDWELL	Manufacturing	11	15	18	21	24	27	29
CALDWELL	Mining	12	14	15	16	17	18	18
CALDWELL	Municipal	4,643	6,306	7,898	9,222	10,555	11,926	13,328
CALDWELL	Steam Electric	0	0	0	0	0	0	0
	Total	6,573	8,297	9,777	11,001	12,247	13,540	14,871

Source: Texas Water Development Board 2006 Regional Water Plan

<sup>1)</sup> Projections for years 2000 - 2060 in ac-ft<sup>1</sup>. An ac-ft is an amount of water to cover

one acre with one foot of water and equals 325,851 gallons.

In addition to projecting water demands by use, the TWDB also determined county municipal water demands for each WUG in Caldwell County. The demands are shown in *Table 8-3*. According to the TWDB, the municipal water demands increase steadily with an amount no greater than 1,500 ac-ft for every decade after 2020. The demands are based on projections of their population estimates that were discussed in Section 6 of this report.

The water user groups presented by the TWDB were developed using the population projections for the WUG in Caldwell County. The population projection estimates up to the year 2060 have been included in *Table 8-4*. The water demand and population projections according to the TWDB were last updated September 17, 2004. The tables indicate a split in region or county when

applicable. A "P" in the Region Split indicates that the WUG is located in more than one region. The values determined represent only the WUG population's projections within that particular region. A "P" in the County Split column indicates the WUG is located in more than one county. The projections listed will be representative of the WUG's population projections within Caldwell County only.

TABLE 8-3           2006 Pagian L. Caldwall County Municipal Water Demond Projections in Acro								
2006 Region L – Caldwell County Municipal Water Demand Projections in Acre- Feet								
Water User Group	2010	2020	2030	2040	Region Split <sup>1)</sup>	County Split <sup>2)</sup>		
Aqua WSC	267	339	396	458	Р	Р		
County Line WSC	204	308	405	501		Р		
County-Other	237	223	199	176				
Creedmoor Maha WSC	234	304	367	431	Р	Р		
Goforth WSC	184	269	342	417	Р	Р		
Gonzales County WSC	63	79	94	108		Р		
Lockhart	2,451	3,094	3,629	4,180				
Luling	1,067	1,210	1,299	1,384				
Martindale	125	134	139	143				
Martindale WSC	142	153	158	162		Р		
Maxwell WSC	503	678	844	996		Р		
Mustang Ridge	135	178	215	253	Р	Р		
Niederwald	26	43	61	78		Р		
Polonia WSC	668	886	1,074	1,268	Р	Р		
Caldwell Total	6,306	7,898	9,222	10,555				

Source: Texas Water Development Board 2006 Regional Water Plan

 If "P" is present in this column, the Water User Group (WUG) is located in more than one Region and the projections listed in the row represent only the WUG's population projections within that particular Region, not the WUG's total population projections. If the "P" is present for a county total entry, then the county has been split by Regional boundaries and the projections listed in the row represent only the county's populations within the particular Region, not the county's total population projections.
 If "P" is present in this column, the Water User Group (WUG) is located in more than one county and the projections listed in the row represent only the WUG's population projections within that particular county, not the WUG's total population projections.

TABLE 8-4								
2006 Region L – Caldwell County Water User Group Population Projections       Wester User Group     2010     2020     2040     Region     County								
Water User Group	2010	2020	2030	2040	Split <sup>1)</sup>	Split <sup>2)</sup>		
Aqua WSC	1,782	2,313	2,764	3,217	Р	Р		
County Line WSC	1,262	1,939	2,565	3,193		Р		
County-Other	1,229	1,172	1,066	968				
Creedmoor Maha WSC	2,217	3,015	3,717	4,423	Р	Р		
Goforth WSC	1,770	2,636	3,429	4,226	Р	Р		
Gonzales County WSC	215	277	329	381		Р		
Lockhart	16,328	21,083	25,111	29,154				
Luling	6,309	7,301	7,998	8,700				
Martindale	1,150	1,291	1,378	1,465				
Martindale WSC	1,307	1,468	1,566	1,666		Р		
Maxwell WSC	4,356	6,113	7,685	9,260		Р		
Mustang Ridge	555	746	911	1,077	Р	Р		
Niederwald	203	349	489	629		Р		
Polonia WSC	7,275	10,019	12,451	14,891	Р	Р		
Caldwell Total								

Source: Texas Water Development Board 2006 Regional Water Plan

1) If "P" is present in this column, the Water User Group (WUG) is located in more than one Region and the projections listed in the row represent only the WUG's population projections within that particular Region, not the WUG's total population projections. If the "P" is present for a county total entry, then the county has been split by Regional boundaries and the projections listed in the row represent only the county's populations within the particular Region, not the county's total population projections

2) If "P" is present in this column, the Water User Group (WUG) is located in more than one county and the projections listed in the row represent only the WUG's population projections within that particular county, not the WUG's total population projections.

### 8.3 Development of Water Demands

Municipal water demands for this study were based on information obtained from the TWDB, input from the Study Advisory Group and the State Demographer.

The TWDB population projections for each WUG in *Table 8-4* were further analyzed to determine percentages of the total population. The percentages calculated for each WUG, as shown in *Table 8-5*, indicated that Luling, Lockhart, and Polonia were the greatest water users in the county and accounted for over 50% of the population. The TWDB percentages of the WUG were multiplied by

the modified TSDC Scenario 1.0, shown in *Table 8-6*, to compare the growth estimates. The modification, as mentioned in Section 6, was to adjust the population projection in 2040 to 100,000. The product of *Table 8-5* and *Table 8-6* is given in *Table 8-7*.

TABLE 8-5								
<b>TWDB - Water User Groups Population Percentages</b>								
Water User Group         2010         2020         2030         2040								
Aqua WSC	0.039	0.039	0.039	0.039				
County Line WSC	0.027	0.032	0.036	0.038				
County - Other	0.027	0.020	0.015	0.012				
Creedmoor Maha WSC	0.048	0.050	0.052	0.053				
Goforth WSC	0.039	0.044	0.048	0.051				
Gonzales County WSC	0.005	0.005	0.005	0.005				
Lockhart	0.355	0.353	0.351	0.350				
Luling	0.137	0.122	0.112	0.105				
Martindale	0.025	0.022	0.019	0.018				
Martindale WSC	0.028	0.025	0.022	0.020				
Maxwell WSC	0.095	0.102	0.108	0.111				
Mustang Ridge	0.012	0.012	0.013	0.013				
Niederwald	0.004	0.006	0.007	0.008				
Polonia WSC	0.158	0.168	0.174	0.179				
Total	1.000	1.000	1.000	1.000				

TABLE 8-6TSDC Population Scenario 1.0 – Modified						
TSDC Scenario 1.0 Population	2010	2020	2030	*2040		
Projected Population	46,308	65,057	86,902	100,000		

*Table 8-7* presents the water user group population projections used in this study based on the modified TSDC Population Scenario 1.0.

In addition to calculating population projections for each WUG based on the TSDC Scenario 1.0, a per capita value was also determined to develop the water demands for this study. The per capita value has units of gallons per capita per day (gpcd). The value represents the average rate of water demand used per person per day for a given population within a distribution system.

TABLE 8-7								
Developed Water User Group Populations for Caldwell County								
Vater User Group         2010         2020         2030         2040								
Aqua WSC	1,796	2,520	3,361	3,864				
County Line WSC	1,272	2,112	3,119	3,835				
County - Other	1,238	1,277	1,296	1,163				
Creedmoor Maha WSC	2,234	3,284	4,520	5,313				
Goforth WSC	1,783	2,871	4,170	5,076				
Gonzales County WSC	217	302	400	458				
Lockhart	16,452	22,966	30,538	35,020				
Luling	6,357	7,953	9,726	10,450				
Martindale	1,159	1,406	1,676	1,760				
Martindale WSC	1,317	1,599	1,904	2,001				
Maxwell WSC	4,389	6,659	9,346	11,123				
Mustang Ridge	559	813	1,108	1,294				
Niederwald	205	380	595	756				
Polonia WSC	7,330	10,914	15,142	17,887				
Total	46,308	65,057	86,902	100,000				

The water use and population data obtained from the surveys were factors in determining the per capita values for each utility. The per capita values determined from the surveys varied from about 84 gpcd in any one year to 160 gpcd. As shown in *Graph 8-3* the average water consumption per person has gradually increased since 2005. In 2005, the average for the utilities surveyed was 113 gpcd and increased in 2006 to 116 gpcd. There was a slight decrease in 2007 with an increase again 2008 to an average of 135 gpcd.

The compiled data was presented to the Technical Advisory Committee for a consensus on the daily per capita value to be used for the study. The Technical Advisory Committee, after discussion, agreed to proceed with a value of 150 gpcd to determine water demand projections for the county. The 150 gpcd rate was applied to the projected population figures to estimate average daily water demands. The estimated demands are shown in MGD and ac-ft respectively in *Table 8-8* and *Table 8-9*.




TABLE 8-8Municipal Average - Yearly Water DemandsMillion Gallons Per Day									
Water User Group         2010         2020         2030         2040									
Aqua WSC	0.269	0.378	0.504	0.580					
County Line WSC	0.191	0.317	0.468	0.575					
County - Other	0.186	0.192	0.194	0.174					
Creedmoor Maha WSC	0.335	0.493	0.678	0.797					
Goforth WSC	0.268	0.431	0.626	0.761					
Gonzales County WSC	0.032	0.045	0.060	0.069					
Lockhart	2.468	3.445	4.581	5.253					
Luling	0.954	1.193	1.459	1.568					
Martindale	0.174	0.211	0.251	0.264					
Martindale WSC	0.198	0.240	0.286	0.300					
Maxwell WSC	0.658	0.999	1.402	1.668					
Mustang Ridge	0.084	0.122	0.166	0.194					
Niederwald	0.031	0.057	0.089	0.113					
Polonia WSC	1.100	1.637	2.271	2.683					
Total	6.946	9.759	13.035	15.000					


Klotz Associates Project No. 0972.000.000 January 2010

TABLE 8-9           Municipal Average - Yearly Water Demands           Acre-Feet Per Year								
Water User Group         2010         2020         2030         2040								
Aqua WSC	302	423	565	649				
County Line WSC	214	355	524	644				
County – Other	208	215	218	195				
Creedmoor Maha WSC	375	552	760	893				
Goforth WSC	300	483	701	853				
Gonzales County WSC	36	51	67	77				
Lockhart	2,765	3,859	5,131	5,884				
Luling	1,068	1,336	1,634	1,756				
Martindale	195	236	282	296				
Martindale WSC	221	269	320	336				
Maxwell WSC	738	1,119	1,570	1,869				
Mustang Ridge	94	137	186	217				
Niederwald	34	64	100	127				
Polonia WSC	1,232	1,834	2,544	3,006				
Total	7,781	10,932	14,602	16,803				

The municipal water demands based on population in Caldwell County are expected to increase from 7,781 ac-ft in 2010 to 16,803 ac-ft in 2040. These municipal water demands will need to be met through surface and groundwater resources. The demands can also be reduced through various conservation measures.

### 8.4 Conservation Measures

Conservation measures will be required from all WUG to reduce the expected water demands. A conservation measure of 10%, illustrated in *Graph 8-4*, will decrease expected water demands and is a recommended goal for all WUGs. Many water saving strategies to achieve this goal have been added in **Appendix H.** Several of the WUG have indicated that they are already implementing some conservation measures to reduce demands and will continue to develop new strategies. The strategies developed by the WUG are also discussed in the appendix.



#### **SECTION 9**

#### WASTEWATER FLOWS

#### 9.1 General

Wastewater flows are generated from domestic, industrial, and commercial uses. Inflow and infiltration are terms used to describe the groundwater and stormwater seepage. Inflow enters the system at direct connection points while infiltration is the groundwater that seeps in through cracks and leaks in the system.

The domestic water that is returned to the treatment facility comes from sinks, showers, tubs, lavatories and toilets. In an average system, 60% - 90% of the potable water is directed to a wastewater treatment facility or an on-site septic system. Water not returned to the wastewater treatment plant is typically used for irrigation and industrial applications.

The rate of return flow determined for the study was developed by comparing the average daily water use and average daily wastewater flow. Lockhart and Luling were the only systems that had data available to evaluate.

### 9.2 Wastewater Flows

Limited wastewater flow data exists for Caldwell County. Large portions of the county are served by OSSF systems that are regulated by the County or city.

Lockhart and Luling provided the only data in the survey to determine average daily wastewater flows and peak flow factors. The average daily wastewater flow ranged from 0.4 MGD to 1.2 MGD with an average of 0.8 MGD. The average flow was considered to be the base flow and the peak flows considered as infiltration and inflow.

Given the sewer base flow and population, a per capita value was determined. The sewer populations for Lockhart and Luling were estimated to be 13,464 and 4,978

respectively from the information provided in the survey. *Table 9-1* provides the survey data used to determine wastewater flows. The average daily wastewater flow for the county was 85 gpcd. The peak day wastewater flow factors for Luling and Lockhart, as shown in *Table 9-2*, were 3.75 and 1.25 respectively.

TABLE 9-1 Wastewater Connections							
Connections Connections Connections Population Population Wastewater Flow (MCD) Flow Per							0
Lockhart	4,095	4,085	0.998	13,600	13,464	1.2	89
Luling	2,152	2,122	0.986	5,080	4,978	0.4	80
				Average	0.8	85	

TABLE 9-2				
Wastewater Peak Day Flow Factors				
System	Peak Day Flow Factor			
Lockhart	1.25			
Luling	3.75			

As seen from *Table 9-2*, the water to wastewater return rates varied from 56% to 79%. The lower return rate can indicate greater outdoor water use or loss and the higher return rates can imply water inflow and infiltration. Normally, average return rates vary from about 60% - 80%. The return rate determined from the survey information provided was an average of 68%. The return rate was used to estimate return flows from the projected water demands.

TABLE 9-3 Wastewater Return Rate						
System Wastewater Water per capita Return Rat						
Lockhart	89	113	79%			
Luling	Luling 80 143					
	68%					

The projected wastewater flows for Caldwell County are presented in *Table 9-3*. The wastewater flows are based on 150 gpcd at a 68% return rate. The projected wastewater flows will increase along with population as shown in the table below. The wastewater flow is expected to increase approximately 5.5 MGD from 2010 to 2040.

TABLE 9-4           Caldwell County Projected Wastewater Flows						
Projected Population	2010 46,308	2020 65,057	2030 86,902	2040 100,000		
Total Projected Wastewater Flows (MGD)	4.723	6.636	8.864	10.200		

Caldwell County will be required to increase or develop new treatment facilities as limits are reached on facilities that treat 4.9 MGD.

### 9.3 Wastewater Loads

Loads produced from the expected wastewater flows are shown in *Table 9-5* and *Table 9-6* assumes the adoption of stringent discharge parameters. The BOD, TSS, Ammonia, and Phosphorus loading values are based on existing water quality conditions and the need for remediation in Plum Creek, where wastewater is discharged.

TABLE 9-5         Caldwell County Projected Wastewater Loads, (lbs/day)							
BOD 5		mg/ L	Ammonia	2	mg/L		
TSS	5	mg/ L	Phosphorous	1	mg/L		
Year of Proj		2010	2020	2030	2040		
Wastewater (MGD)		4.723	6.636	8.864	10.200		
	BOD	197	277	370	425		
	TSS	197	277	370	425		
A	mmonia	79	111	148	170		
Phos	phorous	39	55	74	85		

TABLE 9-6								
Caldwell County Projected Wastewater Loads, (lbs/year)								
Year	2010	2020	2030	2040				
BOD	71,893	101,000	134,915	155,249				
TSS	71,893	101,000	134,915	155,249				
Ammonia	28,757	40,400	53,966	62,100				
Phosphorous	14,379	20,200	26,983	31,050				

#### **SECTION 10**

#### WATER QUALITY

#### 10.1 General

Local ordinances in the Caldwell County political subdivisions regarding water quality and quantity issues are minimal. The county does not have authority to create, implement and enforce regulations related to water quality and quantity. Incorporated cities do have that authority and can exercise that right under local charter rules to adopt new ordinances. The US Environmental Protection Agency (USEPA) and the Texas Commission on Environmental Quality (TCEQ) are the national and state agencies that provide standards and regulate water quality.

#### **10.2** City Ordinances

A search conducted on www.municode.com provided some detail of existing regulations for the cities of Lockhart and Luling. These two cities were the only local governments listed for Caldwell County. The city of Martindale's website provided minimal city code information and a phone number to call for inquires. Searches for Mustang Ridge, Uhland, and Neiderwald were unsuccessful.

In reviewing the local code for Lockhart and Luling, only ordinances regulating water quantity and not water quality are discussed briefly. Water quantity is controlled by limiting or preventing an increase in run-off from a site. The quality of the run-off from a site however is not discussed.

Water quality issues arise from uncontrolled and unregulated point source and non-point source pollution. The uncontrolled quality of discharges into streams and rivers has resulted in substandard water quality in rivers and streams that is not acceptable at the State and National level.

### **10.3** United States Environmental Protection Agency (USEPA)

The USEPA is a federal agency that was established in 1970 to regulate and monitor various aspects of the environment. The USEPA creates and enforces regulations such as the Clean Water Act (CWA). The CWA was passed in 1972 and intended to restore and maintain the chemical, physical, and biological integrity of the nation's waters. This task was to be accomplished by preventing point and nonpoint pollution sources, providing assistance to publicly-owned facilities for the improvement of wastewater treatment, and maintaining the integrity of wetlands. The USEPA provides partnerships, educational programs, and grants to protect the environment.

### **10.3.1** The National Pollutant Discharge Elimination System (NPDES)

Section 402 of the CWA controls direct discharges or "point source" discharges into navigable waters. These are from sources such as pipes and sewers. NPDES permits are issued by either the EPA or an authorized state/tribe. Water quality criteria and standards vary from state to state and site to site, depending on the use classification of the receiving body of water. Most states follow USEPA guidelines that define aquatic life and human health criteria for many of the 126 priority pollutants.

### **10.4** Texas Commission on Environmental Quality (TCEQ)

The TCEQ is the environmental regulating agency for the state. The TCEQ was commissioned to "protect our state's human and natural resources consistent with sustainable economic development." The "goal is clean air, clean water, and the safe management of waste." All activities relating to water quality require permits, registrations, and conformance to standards. The regulated water quality activities include but are not limited to:

- Stormwater
- Wastewater

- General activities
- Agricultural operations
- City MS4s
- Industrial facilities

## 10.4.1 The Texas 303(d) List

As mandated by the CWA, *the Texas 303(d) List* is a management tool to identify streams that fail to have water quality that supports aquatic life and recreational use. In order to fulfill the requirements of the Section 303(d) of the federal CWA the state requires Total Maximum Daily Loads be established for the impaired watershed. The Plum Creek Watershed Partnership was developed in an effort to initiate remediation on a voluntary basis and in effort to mitigate sources of pollution within the watershed and restore full use of the water body.

Due to the unhealthy condition of the largest watershed in Caldwell County, Plum Creek was put on the *Texas 303(d) List* in 2002. The Texas Water Quality Inventory and 303(d) List reports on the status of the state's waters.

# 10.4.2 Texas Pollutant Discharge Elimination System (TPDES)

The state of Texas in 1998 assumed the authority to administer the National Pollutant Discharge Elimination System (NPDES) program for the USEPA. The Texas Commission on Environmental Quality (TCEQ) Texas Pollutant Discharge Elimination System (TPDES) program now has regulatory authority over discharges of pollutants to Texas surface water, with the exception of discharges associated with oil, gas, and geothermal exploration and development activities, which are regulated by the Railroad Commission of Texas.

### **10.4.3 Source Water Protection**

Source Water Protection is not a regulated activity but a voluntary program that helps public water systems protect their drinking water sources. The program requires only time from the water utility staff to participate.

## **10.5** Total Maximum Daily Loads Program (TMDL)

A TMDL program works to improve water quality in impaired or threatened water bodies. The program is intended to control and monitor pollution by targeting pollutants and their respective levels. The development of TMDL's is a scientifically rigorous process of intensive data collection and analysis. The loads are established after adoption by the TCEQ and review and approval by the USEPA.

With established TMDL, wastewater permit holders are required to adhere to higher levels of tertiary treatment to reduce the loadings on the stream. This will include implementation of new technologies and requirements to treat run-off from streets. Livestock and agricultural practices will need to implement better methods in order to reduce non-point source loadings.

At this time TMDL have not been established for any stream segments in Caldwell County. Enforcement by the USEPA has not been implemented and only voluntary monitoring has been established.

### 10.6 Plum Creek Watershed Protection Plan

The Plum Creek Watershed Protection Plan was developed in response to being posted on the 303d list. Efforts of the Plum Creek Watershed Protection Plan were voluntary and not mandated by the USEPA. Efforts to remediate Plum Creek are underway with recommended strategies to mitigate and eliminate pollution contributions.

Pollution sources listed in the Plum Creek Watershed Protection Plan included pets, sheep, goats, horses, cattle, deer, hogs, croplands, urban run-off, septic systems, WWTF, and oil production facilities. Pollution contributions include bacteria, nutrients, and other constituents such as E.coli. Voluntary monitoring of these constituents in Plum Creek will continue until recommended standards are met.

Estimated loading sources of pollution in the Plum Creek Watershed are listed in *Table 10-1*. The Plum Creek Watershed Protection Plan monitored the stream levels and collected data at monitoring stations to estimate pollutant loads and required reductions. A Load Duration Curve (LDC) to predict point and nonpoint source pollution was used with the SELECT approach to identify sources and contributions. SELECT is a Spatially Explicit Load Enrichment Calculation Tool developed by the Spatial Sciences Laboratory and the Biological and Agricultural Engineering Department at Texas A&M University.

TABLE 10-1							
Potential Pollution Sources							
Source	Bacteria	Nutrients	Other				
URBAN							
Run-off	х	х	х				
Pets	х	х					
WASTEWATER							
Septic Systems	х	х	х				
WWTF	х	х	х				
AGRICULTURE							
Sheep and Goats	х	х					
Horses	х	х					
Cattle	х	х					
Cropland	х	х	х				
WILDLIFE							
Deer	х	х					
Feral Hogs	х	х					
OTHER							
Oil and							
Productions			х				

#### **10.6.1 E.coli Potential**

It is estimated that the sub-watersheds with the most impervious cover have the greatest potential to load the stream with the most average daily E.coli. In Caldwell County the cities of Lockhart and Luling have the greatest impervious cover. The impervious cover creates a mode of transporting more constituents and bacteria found in pet waste to streams and rivers. Densities of pets are greater in urban areas yielding an increase in the concentrations and contribution from the cities.

Estimated wastewater and septic systems loads for Caldwell County were also greatest in Lockhart and Luling. Permitted discharges for wastewater treatment facilities have the potential to release concentrated amounts of bacterial larger than what is allowed by the Texas Water Quality Standard criterion of 126 cfu/100 mL.

The potential impacts of agricultural contributions varied depending on the source. For example, the E.coli from horse and cattle had the most significant loading impacts in the watershed, whereas sheep and goats only appeared to contaminate the south and northwest portions of the basin. Deer and feral hogs also have significant loading potential in Caldwell County.

Oil and gas contributions were not assessed for E.coli in the Plum Creek Watershed Protection Plan. The loads contributed by oil and gas include other compounds. Although, other pollutants such as trash and solid waste materials in the watershed are not believed to contribute E.coli loadings, they do contribute to the deterioration of the stream.

### 10.7 Seasonal Loading Impacts

Significant nonpoint source pollution loading contributions that degrade water quality are made during rainfall events. Stormwater runoff contains high TSS,

VSS, COD, Bacteria, Nutrients, and Lead concentrations that are transported to the streams. The continuous additions of constituents further concentrate the contaminant levels in the water. The concentration levels are also increased when runoff disturbs once settled sediment. The agitation of the water reloads the once settled constituents back into the system. The concentrations of sampled data at monitoring stations during dry and wet conditions help correlate loadings with high, mid-range, and low flow levels.

Monitoring stations in Lockhart, Luling and Uhland sampled constituents and plotted the results on a LDC. The LDC plots the condition of the stream flow with the percent of days the flow exceeds the water quality standards. The LDC and monitored data provide a means to calculate the load reduction required to meet water quality standards. *Tables 10-2, 10-3* and *10-4* list the load reductions calculated to meet water quality standards. E.coli, Nitrate, Phosphorus, and Orthophosphorus were the constituents monitored.

TABLE 10-2 Estimated Loadings from Lockhart Monitoring Station					
Load Required % Reduction in Flow					
	High- Moist	Mid Range	Dry - Low	Target	
E.coli			15	15	
Nitrate	18	66	80	80	
Orthophosphorus			49	49	
Total Phosphorus			5	5	

TABLE 10-3 Estimated Loadings from Luling Monitoring Station						
Load	Required % Reduction in Flow					
	High- Moist	Mid Range	Dry - Low	Target		
E.coli	41	11	8	41		
Nitrate			1	1		
Phosphorus				-		

TABLE 10-4 Estimated Loadings from Uhland Monitoring Station						
Load Required % Reduction in Flow						
Loau	High- Moist	Mid Range	Dry - Low	Target		
E.coli	65	51	26	65		
Nitrate		0.3	43	43		
Phosphorus			27	27		

E.coli was the consistent load that exceeded the standard in most flow conditions at all monitoring sites. Nitrate was consistent in Dry-Low flow conditions as was phosphorous. Phosphorus and Orthophosphorus also exceeded the standards in Dry-Low flow conditions. The results correlate with the land use. The monitored nutrients are found in fertilizers and pesticides commonly used in agriculture.

The initiatives in the Plum Creek Watershed Protection Plan to control the contaminant levels and restore Plum Creek to a healthy stream segment are discussed in Section 14. The BMP recommendations in the Plum Creek Watershed Protection Plan can be implemented in any watershed as a proactive approach to maintaining healthy streams and rivers.

# SECTION 11 WATER SUPPLY OPTIONS


### 11.1 Regional Water Plans

The "2006 South Central Texas Regional Water Plan" (SCTRWP) represents 66 water user groups that have identified water needs. The water plan details the strategies to develop water resources to meet the needs and reduce demands through conservation. The South Central Texas Region, also know as Region L, is shown in *Exhibit 11-1*. The exhibit illustrates the represented counties in Region L. In this section, a closer look is given at the plans and viability of the projects mentioned. For the purpose of this study, only the proposed plans that influence the supply for Caldwell County are discussed.

The plans and strategies in the 2006 SCTRWP that are reviewed include:

- Hays Caldwell Public Utility Agency (Plumbing Plan) supply project
- Lower Guadalupe Water Supply Project
- Lockhart Reservoir
- Recycled Water Programs
- Surface water rights
- Local Carrizo
- Local Storage (Aquifer Storage and Recovery)
- Simsboro Aquifer
- Weather Modification
- Rainwater Harvesting
- Water Conservation.

Additionally, the GBRA Mid-Basin Project, which is currently not in the 2006 SCTRWP, will be discussed. The work effort to review the Mid-Basin project for this study was sponsored by funds solely from the GBRA.



### 11.1.1 GBRA Mid-Basin Project

The Guadalupe-Blanco River Authority (GBRA) is proposing a project that will provide 25,000 ac-ft to customers of Caldwell, Comal, Gonzales, Guadalupe, and Hays Counties. The source of water will be primarily surface water from the Guadalupe River with a point of diversion below the confluence of the San Marcos River. The water in the river at the proposed diversion point is not considered firm yield unless it is backed up with off channel storage or a groundwater source. Off-channel storage in Guadalupe County is being considered for the Mid-Basin Project as well as a secondary source of supply from the Carrizo and/or Wilcox Aquifers in west-central or northeast Gonzales County.

A feasibility report has been prepared by HDR to assess the use of groundwater to supplement surface water during dry periods. During dry periods, water would be supplemented with groundwater from the Carrizo/ Wilcox Aquifer to provide a constant supply of 25,000 ac-ft/ yr.

Groundwater availability from the study was determined using the CCWQCS GAM model. The pumping simulation model was run over a period of 55 years from 2010 to 2065. Pumping and well distribution from the proposed field was analyzed in three scenarios. Two pumping scenarios were capable of producing up to 25,000 ac-ft/ yr alone from the Carrizo. The other alternative utilized the Carrizo-Wilcox wells with river water. The layout of the well field was assessed using current GCUWCD rules for well spacing and requirements of 1 ac-ft per acre.

The study used a baseline scenario for comparative purposes and to illustrate the groundwater level and projected draw down. Instream flow restrictions in the pumping simulations were based on the historical period from 1934 to 1989.

Klotz Associates Project No. 0972.000.000 January 2010 The proposed GBRA Mid-Basin Project is a viable solution to meet the water needs of Caldwell County. The permits for this project have not been issued by permitting agencies. Although it is a feasible solution, some concerns have developed regarding environmental flows. Preservation of fresh water in streams to maintain healthy ecosystems has caused some concern. Maintaining base flows of fresh water are necessary for rivers and streams to remain healthy and balanced. The TCEQ, Texas Parks & Wildlife and the TWDB are working to establish environmental flows and these flows will probably need to be established before permits will be issued.

Other issues that the project must resolve include:

- Carrizo-Wilcox groundwater availability (if needed for the project)
- Well spacing according to GCUWCD may require more land leases or acquisitions (if groundwater is needed)
- Obtaining groundwater leases from landowners if groundwater is a part of the project

# 11.1.2 Hays Caldwell Public Utility Agency Supply Project (HCPUA)

The HCPUA was initially formed with the Canyon Regional Water Authority, Buda, Kyle, and San Marcos for the purpose of sharing water supplies and cost of infrastructure development. The HCPUA was created under Chapter 422 of the Local Government Code General Law in January 2007. The role of the HCPUA is to provide wholesale water through the participants. The participants, who are part owners in percentage distribution, could take a role of wholesale water distributors.

The participants have been working together for approximately five years and initially had several interested entities. Many who were invited to participate chose not to pursue the project as a water supply strategy.

The water supply strategies developed by the HCPUA are described in <u>The</u> <u>Plumbing Plan Report</u> prepared by Lockwood, Andrews, and Newnam, Inc. The plan outlines the purpose, approach, timeline, and cost of the projects the HCPUA proposes. An evaluation is given of the water supply options in the report and then makes recommendations on infrastructure improvements and build-out phases.

The plan also developed scenarios based on a 50 year projection of water need. It was determined in the Plumbing Plan that water demand will surpass supply 2018. Some participants have been identified to need water before 2018. The plan projects a minimum water demand of 27,000 ac-ft/ yr in 2060 based on information they received from participants. The projected demand with high growth estimates from the State Data Center is approximately 142,000 ac-ft/ yr.

The project proposes to pump from wells in the southeast corner of Caldwell County adjacent to Bastrop, Fayette and Gonzales Counties. Available yield in this region of the Carrizo is expected to reach 15,000 ac-ft.

The HCPUA is a viable project but will not meet all the needs for Caldwell County. The project would need to consider additional WUG to meet the demands of the county. Other issues that the project must resolve include:

- Carrizo-Wilcox groundwater availability
- Well spacing according to GCUWCD may require more land lease/ acquisitions
- Obtaining leases from landowners (at the time of this study no leases have been obtained)

### 11.1.3 Lower Guadalupe Water Supply Project for GBRA Needs

The Lower Guadalupe Water Supply Project (LGWSP) for GBRA was introduced into the 2006 South Central Texas Regional Water Plan (SCTRWP) to meet water supply needs for customers in Caldwell, Comal, Guadalupe, Hays, and Kendall Counties. The strategy would deliver 36,710 ac-ft/ yr of available water through underutilized GBRA and Union Carbide Corporation water rights from the Guadalupe River.

The original LGWSP is no longer considered a viable strategy and has been removed from the SCTRWP. However, a smaller scale project using the concepts of the original LGWSP is considered a viable strategy for water supply development. The smaller project appears to have fewer potential participants than the original LGWSP.

# 11.1.4 Lockhart Reservoir

The Lockhart Dam and Reservoir project as described in the 2006 Region L Water Plan would be located upstream from Lockhart on Plum Creek as a means of meeting projected water needs. The Lockhart Reservoir was recommended to be included and considered as an important economic development. However, the original Lockhart Reservoir Project is no longer viable because the area where the dam was proposed is being used to mitigate loss of wetlands associated with the construction of SH 130. A reconfigured Lockhart Reservoir Project may be viable but this strategy is not currently being actively pursued.

## **11.1.5 Recycled Water Programs**

The Recycled Waters Program involves the expansion or development of programs that reclaim municipal water for non-potable uses. Recycled water can be used in to irrigate parks, cemeteries, golf courses, athletic fields, open spaces,

and landscape watering. The water can also be used to cool building and for industrial processes.

This strategy is a feasible solution with the development of new treatment facilities. It may not be cost-effective to retrofit and modify existing systems to provide this alternative.

## **11.1.6 Surface Water Rights**

The Surface Water Rights management strategy refers to the recognition of existing water rights available for purchase or lease under agreements from sellers and buyers. Additional diversion points consistent with TCEQ rules and applicable laws are consistent with the 2006 Regional Water Plan.

In Caldwell County run-of-the-river surface water rights are not viable. The water rights for the San Marcos River have all been appropriated. There are no water rights available.

## 11.1.7 Local Carrizo

The Local Carrizo management strategy involves the development and expansion of well fields in the Carrizo-Wilcox Aquifer. Local municipal and steam-electrical needs would be met in Atascosa, Caldwell, Gonzales, Guadalupe, and Wilson Counties. The planned implementation of this strategy as listed in the 2006 SCTRWP would provide new supplies totaling approximately 20,279 acft/ yr. The cost would range from about \$114 acft/yr to \$443 acft/yr.

This strategy is viable and utilized by the HCPUA (Plumbing Plan) and the GBRA Mid-Basin Project. However, groundwater withdrawal permits and if required, export permits, are currently being granted by groundwater districts on almost a "first come first serve basis" without a limitation on the total permitted volume. In the future, the process to establish desired future conditions (DFC) and

the maximum available groundwater from the aquifer may result in groundwater management rules that restrict or curtail groundwater production.


#### 11.1.8 Local Storage

According to the SCTRWP, local storage involves implementing large, regional scale Aquifer Storage and Recovery (ASR) Projects and/or surface storage facilities adequate in size to store surplus flows of surface water during periods of high stream flows, including flood flows, to be available during extended periods of drought. Present management strategies of the South Central Texas Regional Water Plan are sized and scheduled to meet seasonal and daily variations of demand, but some current supplies may not be fully reliable during extended or multi-year droughts. The lack of reliability creates the need for surface reservoirs, large scale ASR systems or multipurpose reservoirs. If the water management need is for a water source that could be made available for emergencies or used during drought, surplus water available during wet periods could be stored in the Carrizo or Gulf Coast Aquifers for future use or stored in surface water reservoirs.

Surface water would generally require treatment prior to storing it in an ASR project. Water treatment capacity necessary to meet peak day demands may be available at non-peak times (fall, winter, spring) to treat water for aquifer storage and subsequent recovery.

At this time, no ASR has been formally proposed for Caldwell County. The Plum Creek Conservation District has taken the initiative to investigate the availability of an ASR in the county. Some potential sites have been located and will be studied further to determine the characteristics and storage capacity of the formation. *Exhibit 11-2* illustrates the potential ASR location as described by Mr. Feather Wilson.

Klotz Associates Project No. 0972.000.000 January 2010



An ASR is a viable solution. Groundwater rights can be fully exhausted on a regional basis and stored in an ASR. Diverted flows from rivers that exceed base flood flows could also be stored with some treatment. The costs associated with an ASR would be dependent on the size of the void. The pipe network, transmission lines, and water treatment would also be cost to consider.

## 11.1.9 The Simsboro Aquifer

The Simsboro Aquifer water supply strategy involved the development of well fields over the Simsboro Aquifer. The project was reportedly headed by the San Antonio Water System (SAWS). SAWS and GBRA in 2008 were approached by a group of landowners, known as the Brazos Valley Water Alliance, to develop a project that would supply 200,000 ac-ft/ yr to participants.

The Brazos Valley Water Alliance was formed in 2002 to represent landowners over the Simsboro Aquifer. The Alliance has approximately 180,000 acres of land and more than 1,200 landowners. The Simsboro Aquifer is a member of the Carrizo/ Wilcox Aquifer which is capable of producing high quality water. After further investigation with SAWS no formal announcement or decision has been reached to continue evaluating this strategy. Additional studies are needed to fully evaluate this option.

## **11.1.10** Weather Modification

The weather modification strategy involves the practice of seeding clouds to increase precipitation. Licensed professionals within the planning region would seed clouds with iodide. The practice does not guarantee precipitation and water quantity estimates can not be measured. The strategy would be intended for cropland, livestock, and aquifer recharge. The strategy is still being studied and has been practiced since 2005 in some Texas counties.

Weather modification is a good strategy but is not considered an applicable or viable solution to meet the future water needs of Caldwell County. Without consistent results it can not be relied on to yield definite amounts of rainfall.

### 11.1.11 Rainwater Harvesting

The rainwater harvesting management strategy captures and stores runoff from rooftops for potable and non-potable use. In some instances this approach can adequately supply the needs of households and businesses.

Rainwater harvesting is a strategy that can assist in the demands projected by reducing per capita consumption. The effects of rainwater harvesting if consumers participated on a city wide basis could have great results. Reducing demand on a regional level would decrease the cost associated with developing new water sources or delay the timing. The Region L Water Plan estimated the cost of water developed by rainwater harvesting as \$2,000 per ac-ft. This cost is considered high. The cost associated with this strategy could be shared cities and homeowners for existing homes. New development could be given incentives for installing systems on homes and buildings. Changes in city development standards could also require such systems.

## 11.1.12 Water Conservation Strategy

The water conservation strategy is suggested to be part of every water management plan. It involves implementing programs and practices that will decrease water use per capita.

Municipally this approach is done by the use of low flow plumbing fixtures, selection of water efficient appliances, modifying landscaping or xeriscaping, addressing plumbing repairs, and modifying personal behavior.

Agricultural conservation methods include installing low energy precision application (LEPA) irrigation systems and furrow dikes.

The water conservation strategy is feasible and recommended to be employed with any other viable solution.

# **11.1.13 Desalination**

Desalination is a water management strategy that involves treating brackish groundwater or seawater. The desalination strategy lead to developing facilities adjacent to well fields in the Carrizo or intake and treatment facilities on the shore of the San Antonio Bay.

Although desalination could meet the water needs of Caldwell County, at this time this strategy is not a feasible solution. This strategy requires support from many local, state, and governmental participants to be considered a viable solution in meeting water needs for Caldwell County.

# **11.2 Conclusions**

The strategies reviewed for use in meeting the future water needs of Caldwell County indicate that there are potential solutions but the implementation of any of the projects will be costly and will require a dedicated effort to implement on a schedule that does not limit growth or development within the county. Multiple strategies may be implemented to ensure the "water future" of Caldwell County.

The most viable near term strategies appear to be the development of the GBRA Mid-Basin Project and/or the HCPUA Project. Each of these projects will rely on withdrawal of water from the Carrizo Aquifer. The GBRA Mid-Basin project has the added advantage of groundwater plus surface water supplies.

The use of a local ASR project to store surplus water in wetter years for future withdrawal is a strategy that merits further investigation. The ASR Project could be combined with the Mid-Basin Project or HCPUA to increase available water supplies during times of drought.

Developing water from the Simsboro Aquifer appears to be a strategy that could yield significant amounts of water for use in the central Texas region including Caldwell County. Development of this project will depend on a large number of potential users with significant needs coming together and jointly developing the project. The schedule for development of his project appears to be beyond the time when water will be needed in Caldwell County.

Desalination is a strategy that can meet the future water of the central Texas region. However, the cost and challenges associated with this project indicate that desalination will probably not be implemented within the planning horizon of this study.

#### **SECTION 12**

#### **REGIONAL WATER PLANNING**

#### 12.1 General

According to the 2006 SCTRWP, several of the water providers in Caldwell County are expected to have shortages in the coming years. *Table 12-1* lists the entities in Caldwell County and their respective shortage, as determined by the SCTRWP. The expansion and/or creation of new water management strategies will be necessary to meet the needs in Caldwell County. Proposed water management strategies in the SCTRWP will be expanded on and a regional network will be developed in this section.

Regional cooperation is necessary not only to mitigate cost but also to jointly find solutions that will benefit all participants. Communication and collaboration are efforts that are required to plan and implement a regional water plan.

TABLE 12-1           Caldwell County 2006 SCTRWP Projected Shortages (ac-ft)								
Water Supplier	Projected Shortage							
	2010	2020	2030	2040	2050	2060		
Aqua WSC	49	121	178	240	300	362		
City of Lockhart WSC	341	984	1,519	2,070	2,615	3,175		
City of Luling	168	311	400	485	587	695		
Creedmoor Maha		0	0	0	0	0		
Martindale WSC				2	19	41		
Maxwell WSC			73	249	479	692		
Polonia WSC			137	331	520	719		
Tri Community WSC								
County Line WSC	44	1,096	1,416	1,582	1,900	2,365		
Goforth WSC	79	532	969	1,415	1,963	2,408		
San Marcos	79	532	969	1,415	1,963	2,408		
Gonzales County	0	14	75	208	254	255		

#### 12.2 Water Supply Sources

Water supplies vary for the local water utilities. Surface water is supplied from GBRA and CRWA through river-run-of-rights. Groundwater is supplied through well permits in the Edwards (Barton Springs) Aquifer, Wilcox-Carrizo Aquifer, and Alluvial Wells. Future water supplies from these sources are expected to develop further to meet demands. Water supplies that are available to Caldwell County have been listed in *Table 12-2*. The information presented is from a query performed on the TWDB website on available water by source. The water sources listed in the survey by the WUG's were searched to provide information on the water available.

The accessible water supplies from the named sources in *Table 12-2* decrease for each decade. The available supplies in 2010 are 10,878 ac-ft, 2020 has 10,838 ac-ft, 2030 has 10,071 ac-ft, and 2040 has 10,063 ac-ft.

Given the listed supplies and calculated water demands discussed in Section 8, the expected shortages are slightly greater that the SCTRWPG. The difference is likely based on greater population estimates and different per capita values. A revised municipal demand for the "TWDB County Water Demand Projections" is presented in *Table 12-3*. The municipal demand revision reflects the water demands determined in this study. *Table 12-4* presents the expected shortages based on these revisions and study determinations.

TABLE 12-2           Caldwell County Water Supplies (ac-ft)							
Source Name	WUG Name	Supply 2010	Supply 2020	Supply 2030	Supply 2040		
CARRIZO-WILCOX AQUIFER	Mining	16	10	4	0		
CARRIZO-WILCOX AQUIFER	Manufacturing	84	84	84	84		
CARRIZO-WILCOX AQUIFER	Irrigation	1,037	916	809	714		
CARRIZO-WILCOX AQUIFER	Lockhart	2,310	2,310	2,310	2,310		
CARRIZO-WILCOX AQUIFER	Luling	2,730	2,730	2,730	2,730		
CARRIZO-WILCOX AQUIFER	County-Other	3,173	3,264	2,604	2,698		
	Sub-Total	9,350	9,314	8,541	8,536		
GUADALUPE RUN-OF-RIVER Luling		99	99	99	99		
GUADALUPE RUN-OF-RIVER	JADALUPE RUN-OF-RIVER Martindale		198	198	198		
GUADALUPE RUN-OF-RIVER County-Other		613	613	613	613		
	Sub-Total	910	910	910	910		
CANYON LAKE/RESERVOIR	Martindale	50	50	50	50		
CANYON LAKE/RESERVOIR	County-Other	258	258	258	258		
	Sub-Total	308	308	308	308		
EDWARDS-BFZ AQUIFER	County Other	161	161	161	161		
	Sub-Total	161	161	161	161		
QUEEN CITY AQUIFER	Mining	0	0	0	0		
QUEEN CITY AQUIFER	QUEEN CITY AQUIFER Manufacturing		3	3	3		
QUEEN CITY AQUIFER	Irrigation	36	32	28	25		
QUEEN CITY AQUIFER	County-Other	110	110	120	120		
	Sub-Total	149	145	151	148		
Total Supply		10,878	10,838	10,071	10,063		

Data obtained from TWDB WUG Supplies at http://www.twdb.state.tx.us/assistance/rwpg/DB02/index.asp

TABLE 12-3 TWDB County Water Demand Projections Based on Revised Municipal Demands 2010-2040 in ac-ft							
Category	Category 2010 2020 2030 2040						
Irrigation	1,044	928	824	733			
Livestock	918	918	918	918			
Manufacturing	15	18	21	24			
Mining	14	15	16	17			
Municipal	7,781	10,932	14,602	16,803			
Steam Electric	0	0	0	0			
Total Demand 9,772 12,811 16,381 18,495							

TABLE 12-4							
Caldwell County Additional Water Need (ac-ft)							
Year 2010 2020 2030 2040							
<b>Expected Need</b> (1,106) 1,973 6,310 8,432							


Regional facilities in this study will be developed to meet the approximate additional need of 8,500 ac-ft. Facilities and transmission lines will be sized to provide the determined need.


# 12.3 Conceptual Planning

In the evaluation of the population projections it was stated earlier that most of the development and growth is expected to occur to the north and west between the I-35 and SH 130 Highways. Planning for Caldwell County will develop with the understanding that growth will begin from the north and west and then south to Luling. Water systems will be planned to accommodate the growth and allow for further regional expansion. This approach will also consider both the HCPUA and the GBRA Mid-Basin Project strategies.

# 12.3.1 Source Development

Utilizing the viable strategies of the HCPUA and the Mid-Basin Project, water sources from the Carrizo-Wilcox and Guadalupe River Basin will be developed. As shown in *Exhibit 12-1*, the initial delivery of the raw surface water will be to Luling and the delivery of groundwater will be to Lockhart. Luling currently operates a water treatment plant that is capable of diverting up to 4,422 ac-ft/ yr of water with a peak rate treatment capacity of 2.779 MGD. The plant delivers the water to the city of Luling and Lockhart. The transmission line that would route water to Luling for treatment is shown in a dashed blue line and the existing line that delivers the water to Lockhart is solid red. The dashed red line indicates the groundwater route delivered to Lockhart. Another route to consider for groundwater is taken from a well field south of Caldwell County and delivered to Luling. Well fields that have been located for groundwater development are noted as "Well Area" in *Exhibit 12-2*. Surface water diversions at the confluence of the San Marcos and Guadalupe River are noted as "Surface Water Area" in the exhibit.






### 12.3.2 Distribution

The water will be delivered through a 24" transmission line flowing at 5 fps. Once water is delivered to designation delivery points it is recommended to develop a regional water distribution system as shown in *Exhibit 12-2*. The development of the Luling-Lockhart water transmission was a project that formed the beginning of a regional water distribution system. The following actions are recommended to further develop a regional water distribution system:

- Develop water sources to initial delivery point (Lockhart/ Luling)
- Develop a route to Uhland where population growth is expected to be the greatest
- Develop a transmission line route along SH 130 toward I-35 N
- Develop a transmission line route along SH-130 West
- Develop a transmission line route to loop the system

Development of the transmission lines would create a regional water distribution system that would not only aid Caldwell County, but also the neighboring counties in need of water. The benefit of including adjacent counties to participate is cost related. Sharing cost provides an incentive for many participants to pool together resources to develop the water sources needed for future water demands.

Current plans in the SCTRWP that detail the same routes are the Plumbing Plan developed by the Hays/Caldwell PUA and the GBRA Mid-Basin Project. *Exhibit 12-3* provides an illustration of approximate line locations. The Plumbing Report lists three options of delivery points that include the San Marcos WTP, the City of Kyle elevated storage tank (EST) and the City of Buda well site #3 where they have a ground storage tank (GST) that can be utilized. The Mid-Basin Project transmission main would in all scenarios deliver 4,000 acft of surface water to the San Marcos WTP.



### **12.4** Water System Cost Estimates

Various studies, reports, and recent bids were used to develop cost estimates. *Table 12-5* presents a summary of the estimated associated project cost for the proposed transmission lines. Current economic conditions may cause moderate fluctuations in construction costs and estimates. **Appendix M** provides a basis for the proposed cost estimate.

	TABLE 12-5         Project Summary Cost				
ITEM NO.	ITEM DESCRIPTION	AMOUNT			
1	Line 1A - Groundwater Source Route to Lockhart	\$33,800,000			
2	Line 1B - Groundwater Source Route to Luling	\$30,000,000			
3	Line 1C - Surface Water Source Route to Luling	\$51,500,000			
4	Line 2 - SH 130 North Route	\$12,000,000			
5	Line 3 - Northwest Route to Uhland	\$7,000,000			
6	Line 4 - SH 130 West	\$10,000,000			

It is recommended first to develop wells in the Carrizo/ Wilcox Aquifer initially with either Transmission Line 1A or 1B and begin to branch out before the expected growth. As growth occurs, a network of pipelines can begin to be established regionally to provide for a regional supply. The construction of SH 130 presents an opportunity to develop two of the branch network lines to supply water in the areas of expected growth. Transmission Line 2 and Line 4 are recommended to parallel SH 130.

### **SECTION 13**

#### **REGIONAL WASTEWATER PLANNING**

#### 13.1 Introduction

Regional wastewater planning is needed with the expected growth in Caldwell County. Evaluation of several options regarding collection treatment systems was necessary to provide recommendations for planning and implementation. Identifying the existing facilities in the county was a task necessary to understand the current systems and identify needed improvements or changes.

### 13.2 Existing Wastewater Collection Systems

Lockhart and Luling are the two municipalities that currently provide wastewater collection services. The remainder of the county is rural with septic systems in use. As previously mentioned, Lockhart has two facilities that treat a combined flow of 2.6 MGD and Luling also has two plants that treat a combined flow of 1.1 MGD. Three of the four treatment plants discharge into Plum Creek. One plant from Luling discharges into the San Marcos River.

Areas outside city limits and in unincorporated areas utilize on-site sewage facilities (OSSF) also known as septic systems. Septic system use in Caldwell County for urban regions and undeveloped portions of the county is typical and has steadily risen since 2005. The Director of Sanitation for Caldwell County provided the data shown in *Table 13-1* and *Graph 13-1*. The numbers of Septic System Certificates of Completion are listed for the last ten years.




TABLE 13-1Caldwell County On-Site Sewage Facilities (OSSF)Certificates of Completion				
Year	Permits			
1998	248			
1999	272			
2000	278			
2001	274			
2002	174			
2003	172			
2004	130			
2005	120			
2006	155			
2007	153			
2008	163			

Klotz Associates Project No. 0972.000.000 January 2010

#### 13.3 Wastewater System Planning


The development of wastewater facilities will be based on growth and land topography. A gravity flow systems is the expected design. Assumptions of land development are made based on typical patterns that occur along corridors. *Exhibit 13-1* illustrates the general areas that were considered in the evaluation of future growth. Steep elevation zones, floodplains, and drainage basins were the governing factors for determining the locations of the regional facilities and the decentralized systems.


It will be expected that as the population grows, the areas between San Marcos, Luling, Lockhart, and Mustang Ridge will become densely populated. Area 2 as shown in the exhibit is expected to show the initial growth with development following in areas 1 and 3. Areas 4 and 5 are not expected to grow as rapidly and become as densely populated. The construction of SH 130 will bring about a change in the land development for the area.

## **13.4** Wastewater Collection System Service Areas

The location of collection systems were based on the naturally occurring drainage basins. There are three major drainage basins in the county which can be utilized to develop systems transported by gravity. Gravity systems require very little energy and are typically less costly to develop and maintain than systems that require pumping. Evaluations of the service areas, as shown in *Exhibit 13-2*, were defined as follows:

 The Lockhart Regional Facility Area - This service area will include Lockhart and the northern area of the county that will develop as SH 130 develops from Mustang Ridge.





- The Martindale Regional Facility Area This service area will include Martindale and the area west of Lockhart. It is expected that this segment of SH 130 will bring development and growth.
- 3. The Luling Regional Facility Area This service area will include Luling and the area north of Luling. This service area will also include the portion of Caldwell County that is in the San Marcos Drainage Basin.
- 4. The Peach Creek Regional Facility Area This service will include the Peach Creek Drainage Basin areas in Caldwell County. This area is not expected to develop at significant rates. This area was established in this study for the purpose of providing a facility in every drainage basin represented.

# 13.5 Wastewater Collection System Options

Regional facilities and decentralized systems, which include package treatment facilities and OSSF's, were considered in the evaluation of wastewater treatment facilities. The recommended facilities were based on:

- 1. Population projections developed in this study
- 2. Wastewater return flows were based on 150 gpcd of water
- 3. 68% return flow rate
- 4. Wastewater treatment would be provided for 100% of population
- 5. Service plan does not include individual connections (lateral)

# 13.5.1 On-Site Sewage Facilities (OSSF) / Septic Systems

Upon evaluation of septic systems use in the county, septic systems were not considered to be an appropriate alternative to serve a growing community. Installation of these systems in an already impaired watershed could prove to be more costly financially and environmentally in long-term planning. Discharge of these systems cannot be monitored and evaluated on a regular basis to ensure the discharge meets standard requirements. Homeowners, in most cases, are not concerned or aware of problems until the issues become visible. Remediation efforts due to the contribution of failing OSSF's are unnecessary if appropriate planning measures are implemented to limit these systems. Larger lot sizes and buffer zones can decrease the loads imposed by OSSF.

Development of more stringent ordinances and preferences should be established to regulate private sewage facilities. The county has a position to take on these systems in areas expected to develop. Provisions need to be made for private owners in isolated rural areas that are not planning to develop the property and are not within 300 feet of a sewer line.

### **13.5.2 Regional Treatment Facilities**

Regional treatment facilities have traditionally been implemented in regional planning efforts. Economies of scale have been the motivating factor for the "bigger is better" selection rationale. Larger treatment facilities do provide cost effective solutions for wastewater treatment. Communities typically have an expectation of safer and better quality standards due to the municipal oversight. Federal regulations and funding have also been oriented toward centralized collection and delivery of point source discharges.

The regionalization of wastewater systems for the county does provides the benefit of minimizing the number of decentralized systems, including OSSF. Minimizing the number of point source discharges have the additional benefit of ensuring regulation and monitoring by municipalities or river authorities.

#### **13.5.3 Decentralized Treatment Facilities**

Multiple treatment facilities within a service area can be described as decentralized systems. The Turner Crest WW treatment facility is an example of a

decentralized system providing sewer services to the subdivision it would develop.

A shift in paradigm is occurring where decentralized systems are being considered more feasible, environmentally friendly, and aesthetically pleasing if designed, constructed, and operated properly.


As permanent components of infrastructure, it would be in the best interest of the public for the facilities to be managed by a public utility.

The smaller footprint of a decentralized system impacts the environment minimally. The system would require less land and minimize or eliminate effluent discharges. Recycling 100% of the discharge can also provide monetary benefits and reduce per capita water demands. The systems in the communities can be landscaped to be appealing and provide an aesthetic value to the area. The systems can also allow for development in rural areas where sewer service is not available. Energy use of a decentralized system can be substantially lower than a regional facility. Lastly, air quality issues are minimized.

The decentralized systems would be sized and located to serve smaller watersheds and communities. Placement of these facilities would require analysis of smaller regions. An example of these system locations at the regional level are shown in *Exhibit 13-3*.

## **13.5.4** Package Treatment Facilities

Package treatment plants are pre-assembled and factory installed treatment facilities that effectively utilize energy and mechanical, biological, chemical or physical treatments processes. They offer minimal on-site construction cost, fast plant start-up and cost efficient operation and maintenance (O&M). O&M is simple and requires minimal supervision.



Unfortunately, the simplicity of O&M has reportedly caused some plants to be out of compliance. The results of these facilities being managed incorrectly can cause detriment and degradation to the surrounding environment. For this reason, it will be recommended for these facilities to be operated by trained personnel.

Typical applications are in land development subdivisions, small cities, mobile home parks, and recreational areas. These package treatment facilities may be beneficial to apply as growth develops in urban areas and then to replace as the life of the system expires. These systems would act as decentralized systems and are recommended to be operated by public utilities to provide a service for the public health.

# 13.6 Proposed Wastewater Collection Facilities

The proposed regional and decentralized facilities are recommended to reuse 100% of the effluent. With stringent treatment levels for all collection facilities, the treated wastewater can be reused within the community it is serving. There is opportunity for reuse in both centralized and decentralized systems. The reuse water can serve to irrigate developments in nearby communities. Hospitals, schools, theaters, manufacturers, industries, and other facilities that require large amounts of water for irrigation and cooling of buildings are target customers of reclaimed water.

Although the recommendation is to reuse 100% of the wastewater, it may not entirely feasible for utilities to provide this service in existing facilities. The cost may exceed the benefits. Also, development and design of new facilities should employ this strategy with further investigation into the effects of instream flows and current laws.

The proposed regional collection facilities are to provide sewer services to the Lockhart, Martindale, Luling, and Peach Creek service areas as discussed earlier.

The projected flows developed in Section 9 and found in *Table 9-3* were further evaluated to determine wastewater flows for the service areas mentioned. A percentage of the expected population was assigned to each service area to estimate a wastewater flow for that service area. The percentages and expected wastewater flows are shown in *Table 13-2*. Lockhart was expected to produce 40%, Luling 35%, Martindale 20% and Peach Creek 5% of the projected wastewater flows.

Table 13-2           Service Areas Projected Wastewater Flows						
Total Projected Wastewater Flows (MGD) in given Year         2010         2020         2030         2040           4.723         6.636         8.864         10.200						
	4.725	0.030	0.004	10.200		
Service Area	Percentage	Waste	ewater Flows	for Service A	Areas	
Lockhart	40%	1.889	2.654	3.546	4.080	
Luling	35%	1.653	2.323	3.102	3.570	
Martindale	20%	0.945	1.327	1.773	2.040	
Peach Creek	5%	0.236	0.332	0.443	0.510	

## **13.6.1** Option 1 - Regional Facilities

The regional facilities option is to develop one regional facility in the four determined service areas. This option reduces the number of treatment systems with an anticipated lower unit cost of treatment. However, with a 100% reuse distribution system, this may prove to be more costly than other options. Reuse lines in a regional facility may be limited.

#### 13.6.2 Option 2 - Decentralized/ Package Treatment Systems

It is suggested by other industry professionals to consider implementing systems delineated by smaller drainage basins to serve local subdivisions and commercial/industrial sites. Having a smaller community collection and reuse distribution system can provide environmental benefits that outweigh other associated costs. Efficient and functional planning of these facilities with planned community development is necessary to be cost-effective.

This alternative also considers phasing out ineffective systems that are not functional. The collections systems can be removed and lines extended to connect to a network in place. Connection to a sewer main will route the wastewater to a regional facility. These systems should be strategically placed in locations that allow for the option to be phased out.

# **13.6.3 Option 3 - Combined Facilities**

Decentralized systems, in combination with regional facilities, can work together to provide load reductions in streams and rivers. Decentralized systems can collect, treat the wastewater and enable local reuse of the water. This approach promotes reuse of treated wastewater. The unusable sludge slurry can be piped to a regional treatment plant and treated at that plant prior to disposal.

# **13.7** Proposed Regional Wastewater Facilities


The recommended regional wastewater facilities for Caldwell County are presented in *Exhibit 13-4* and include:

- Lockhart Regional Wastewater Treatment Plant in 2040 is expected to treat 4.1 million gallons per day receiving 40% of the total wastewater produced in the county. Approximately 32 miles of main wastewater collection lines are proposed for this treatment plant.
- Luling Regional Wastewater Treatment Plant in 2040 is expected to treat 3.6 million gallons per day receiving 35% of the total wastewater produced in the county. Approximately 33 miles of main wastewater collection lines are proposed to service this treatment plant.

- Martindale Regional Wastewater Treatment Plant in 2040 is expected to treat 2.1 million gallons per day receiving 20% of the total wastewater produced in the county. Approximately 11 miles of main wastewater collection lines are proposed to service this treatment plant.
- Peach Creek Regional Wastewater Treatment Plant in 2040 is expected to treat 0.6 million gallons per day receiving 5% of the total wastewater produced. Approximately 9 miles of main wastewater collection lines are proposed to service this treatment plant.

**Table 13-3** presents estimated cost for each regional treatment plant based on a plant cost of \$3.75 per gallon of treatment capacity and in-place wastewater main cost of \$125 per linear foot of pipeline. Appendix M presents additional information on the wastewater cost estimates

TABLE 13-3         Regional Wastewater Collection and Treatment Plant Cost Estimates						
	Estimated Cost in Millions of Dollars					
	Lockhart Plant Luling Plant Martindale Peach Cre Plant Plant					
Item	4.1 mgd	3.6 mgd	2.1 mgd	0.6 mgd		
Plant Cost	\$15.3	\$13.4	\$7.7	\$1.9		
Main Collection Lines	\$21.1	\$20.1	\$7.0	\$5.7		
Total	\$36.4	\$33.5	\$14.7	\$7.6		



#### **SECTION 14**

#### **REGIONAL WATER QUALITY PROTECTION PLAN**

#### 14.1 Introduction

The Caldwell County Regional Water Quality Protection Plan (CCRWQPP) identifies actions that will assist in preventing continuing degradation of groundwater and surface water quality within Caldwell County. Regional water quality measures are necessary to assist in maintaining healthy streams, preventing contamination of groundwater from surface sources and in support of efforts to improve the quality of water flowing in streams within the county.

Segments of Plum Creek, the major drainage Basin within Caldwell County, have experienced declining water quality with increasing nutrient concentrations, sediment loads and bacterial contamination. Stream segment 1810 of Plum Creek was listed in 2002 as an impaired stream segment in accordance the requirements of the Federal Clean Water Act, Section 303(d).

Measures presented in the CCRWQPP include structural and non-structural best management practices (BMPs) that can assist in reducing pollutant loads to streams in the county, assist in improving water quality in streams and assist in guarding against groundwater degradation.

## 14.2 Caldwell County Watersheds

As discussed in Section 2 of this Report, the streams that are included in the planning region receive discharge from the Guadalupe and Colorado River Basins. The Colorado River Basin receives approximately 11 percent of the drainage and the Guadalupe River Basin receives the remaining 89 percent. The sub-watersheds of the Guadalupe River Basin in the county include Plum Creek (59%), the San Marcos River (16%), and Peach Creek (14%).

#### 14.3 Water Quality Concerns and Sources of Impairment

The constituents that threaten stream water quality in Caldwell County originate from several sources and have resulted in streams being classified as impaired because of the presence of excessive bacteria, concern with dissolved oxygen levels (DO), and high concentrations of total phosphorus, ortho-phosphate, and ammonia-nitrogen. Sources of these pollutants are as follows:

- Urbanization and Runoff Urbanization almost always results in removal of vegetation that in turn reduces the natural filter processes performed by vegetation and increases soil erosion from caused by larger peak runoff rates and volumes. Pollutants from human activity, pet waste and natural processes reach drains, storm sewers and streams without the benefit of vegetative filtering.
- Livestock and Wildlife Animal waste deposited in or near waterways can contribute significant pollutant loading to streams.
   Feral hogs, deer, sheep, goats, horses, cattle, chickens, turkeys and ducks are potential significant pollutant sources in Caldwell County.
- On-Site Sewage Facilities (OSSF) Improperly designed or installed, leaking and/or failing OSSF facilities can add significant pollutant loading to streams and groundwater. Bacteria from OSSF systems can reach drinking water sources and have severe and life-threatening impacts to human health.
- Wastewater Treatment Facilities Improperly designed, constructed and/or operated wastewater collection and treatment facilities can result in leaks, overflows and/or discharges to drains, storm sewers and streams that can add significant pollutant loads to natural water bodies.

- Agricultural Practices Improper and poor agricultural practices can significantly increase sediment, nutrient, organic, bacterial and/or chemical loading to streams. Over-fertilization is an example of a poor practice that can increase nutrient loads and increase production cost without a commensurate return on investment.
- Oil and Gas Production Brine leakage, nitrogen compounds, salts, and hydrocarbons (petroleum byproducts) can leak to waterways and result in diminished water quality and decrease the quality of the aquatic habitat.
- Solid Waste Sources Solid waste (such as used tires, home appliances and construction debris) that is improperly disposed of in drainageways and streams add to pollutant loads and can degrade aquatic habitat, stream functions and visual appearance.
- Natural Geological Characteristics Naturally occurring geological formations can contribute nutrients and other pollutants to water passing through the formation. The nutrient and pollutant loads can impair groundwater quality and surface water quality where groundwater discharges to streams.

The CCRWQPP addresses the potential pollutant sources and recommends BMPs that will reduce the impact of the various pollutant sources. Deployment of the BMPs may be an iterative process to meet pollutant goal removal. Monitoring will be necessary to determine the effectiveness of the management measures.

## 14.4 Water Quality Standards

Water quality standards established by TCEQ and Environmental Protection Agency (EPA) are used to define the acceptability and suitability of water for various uses including such uses as drinking water, water in streams and wastewater plant return flows. The standards are defined using chemical, biological and physical parameters.

The stream water quality standards for contact recreational waters in Texas include the following provisions for bacteria:

- the geometric mean of samples tested for E.coli should not exceed 126 colony-forming units per 100 milliliters (CFU/100mL)
- the geometric mean of samples tested for fecal coliform should not exceed 200 CFU/100ml fecal coliform
- For grab samples, not more than 25% of the samples tested for E.coli can exceed 394 CFU/100ml
- For grab samples, not more than 25% of the samples tested for fecal coliform can exceed 400 CFU/100ml

If a tested water body does not meet these standards, it can be classified as an impaired water body for bacteria.

For segments of stream where a high level of aquatic life is desired, the following water quality parameters are recommended:


- DO equal to or more than 5.0 mg/L
- pH in the range of 6.5 to 9.0
- Temperature not greater than 90° F

Water quality parameters used to evaluate drinking water for public water supplies include the following secondary criteria:

- Chloride not more than 300 mg/L
- Sulfate not more than 300 mg/L
- Total Dissolved Solids not more than 1000 mg/L

#### 14.5 Impairment Locations

Through SELECT modeling in the Plum Creek WPP, subwatersheds were identified that have the greatest potential to contribute specific pollutant parameters. For example, in *Exhibit 14-1* E.coli was identified to have the potential to contribute the specified amounts in Billions of CFUs in the delineated watersheds. The E.coli loads were based on average bacteria production rates and the concentration of a source within a subwatershed. The exhibit is taken from the Plum Creek WPP and illustrates one of many parameters analyzed for Daily Potential Loads.



14-5

Source: Plum Creek Watershed Protection Plan

#### 14.6 Recommended Load Reductions

Load Duration Curves in the Plum Creek WPP, prepared by the Texas AgriLife Extension Service, indicate both point and non-point pollution sources should be reduced. Water quantity and quality monitoring stations at Lockhart and Luling provided flows and water quality data used to compute existing pollutant loads. The recommended allowable pollutant loads were subtracted from the existing loads to determine the load reduction required. The recommended pollutant load reductions as a percentage of existing loads are shown in *Table 14-1*.

TABLE 14-1				
Pollution Reduction Needed				
Parameter Parameter				
Location	E.coli Bacteria	Phosphorus	Nitrate	
Lockhart	65%	27%	43%	
Luling	15%	49%	80%	

#### 14.7 Proposed Management Measures

The proposed management measures identified in the Plum Creek WPP are specific to Plum Creek but can be implemented in parts of the county that are not within the Plum Creek Watershed. The measures are intended to reduce bacterial loads but will also influence the reduction in nutrient loads. Nutrient loads associated from urban landscaping and cropland will also be addressed. Additionally, management measures will also focus on the reduction of phosphorus loads.

Naturally occurring nitrate in groundwater has been reported to discharge into Plum Creek and create impaired water quality conditions (nitrate concentrations exceed desired limits). Management efforts directed at nitrates should be focused on ensuring that additional nitrates from non-groundwater sources are not added to streams and measures are implemented to prevent further increases in nitrate concentrations in groundwater.

#### 14.7.1 Urban Stormwater Management Measures

A workgroup from the Plum Creek WPP specified implementation goals and placed emphasis on programs consistent with Municipal Separate Storm Sewer System (MS4) requirements. **Appendix I** lists the city specific measures to be implemented in Lockhart and Luling.

A study, "Predicting Effect of Urban Development on Water Quality in the Cities of New Braunfels, San Marcos, Seguin and Victoria" was completed in November 2000 by PBSJ. The study developed a series of equations to predict the impact of impervious cover on concentrations of four water quality parameters in stormwater runoff. These formulas may be useful in predicting water quality impacts from the construction of impervious cover in watersheds and assist in determining pollutant removal required as part of a construction permit.

The formulas are:

Total Suspended Solids in mg/L, TSS: TSS =  $10^{(2.41+(0.0149 \text{ IC}))}$ Total Nitrogen in mg/L, TN: TN = 1.08+(0.0564\* IC)Total Phosphorus in mg/L, TP: TP = 0.0231\*ICFecal Coliform, FC in CFU/100mL: FC =  $10^{(4.0+(0.0229* \text{ IC}))}$ 

Where IC is impervious cover expressed as a percentage, ^ is the symbol for exponential and \* is the symbol for multiplication.

It should be noted that the calculated concentration is an "Event Mean Concentration" (EMC) which is defined as a flow-weighted average. The EMC is used because the concentration of any parameter varies greatly in a storm event as the hydrograph rises (the first flush event), crests and falls in the trailing limb of the hydrograph.

14-7

## 14.7.2 Water Quality Development Ordinances and Policy

Several water quality guidelines can be implemented at the local level to effectively control non-point source pollution and point source pollution. Local governments have a responsibility to the community to develop sound and practical policies that will improve the quality of life. The uneducated, uninformed, and unwilling require nudges to comply. Growing and developing cities have an opportunity to guide, plan, and manage growth. Policies and procedures recommended to provide water quality protection and are not limited to:

- Buffer Ordinances
- Open/ Natural Space Conservation
- Tree Ordinance
- Zoning Ordinances
- BMP Ordinances
- Stringent OSSF Ordinances

These water quality ordinances and policy practices can be accomplished through the development and implementation of a Master Plan for the City that clearly defines buffer areas and open space conservation that protects natural areas. Widths of buffers can be based on contributing drainage areas and their location relative to a stream centerline. The plan should also define development practices through zoning requirements and provide guidance on tree protection and preservation.

Providing comprehensive site planning and pre-development reviews can ensure compliance and the review of water quality measures being incorporated into the design of the site. The preliminary reviews should demonstrate the technical elements that support the operation and maintenance of the water quality measures.

## 14.8 Structural BMPs for Discharges from Developed Land

Discharges from developed land can be managed through the implementation of structural BMPs. Structural BMPs that can offset the impact of development on water quality can include:

- Infiltration Systems
- Detention/ Sedimentation Basins
- Vegetative Filter Strips
- Vegetative Swales
- Riparian Buffers
- Rain Gardens

A long term operation and maintenance plan should be included in the design and construction of the BMPs. Funding and maintenance schedules should also be included prior to approval of construction.

# **14.8.1 Infiltration Systems**

Infiltration systems are designed to filter out particulates as water percolates through the soil, infiltrating the ground over some area and period of time. Infiltration systems include porous pavement, infiltration basins and trenches. Due to the removal efficiency and potential for migration, this system may not be appropriate over ground water sources.

## 14.8.2 Detention/ Sedimentation Basins

Detention/Sedimentation Basins are utilized to capture storm water and are effective at removing suspended constituents such as sediment. They can remove up to approximately 80% of suspended solids.

#### 14.8.3 Vegetative Filter Strips

Vegetative filter strips are land areas that are designed to treat stormwater for the purpose of removing sediment and other pollutants. The strips are effective in shallow sheet flow. For concentrated flow, design measures should be taken to distribute the flow and dissipate energy and reduce flow velocity. Vegetative filter strips generally remove suspended particulates and limited dissolved constituents. Vegetated filter strips should be used in series with other BMPs

#### 14.8.4 Vegetative Swales

Grassy swales are vegetated channels that convey stormwater and remove pollutants by filtering, settlement and infiltration through soil. They require shallow slopes and soils that drain well and are limited to light and moderate flows. The swales can be easily integrated into landscaping plans. The placement of these swales along roadside ditches has proven to be effective.

## 14.8.5 Riparian Buffers

Riparian forest buffers combine trees, shrubs, and native grasses to remove sediment and chemicals from runoff before they reach a waterway. The width of the buffer strips can vary from 35-100 feet depending on slope, soil type, adjacent land use, floodplain, and type of vegetation. The buffers, once established need to be maintained and monitored yearly to remain effective.

#### 14.8.6 Rain Gardens

Rain gardens are man-made depressions in the ground that forms a small bioretention area. The landscaping of the area improves the water quality by filtering the water that is slowly absorbed by the soil. These gardens are functional when placed strategically to intercept water runoff. Placement of these gardens in new proposed development can be accomplished cost-effectively. The rain garden will add value to the home as well as providing a water quality measure.

#### 14.9 Agricultural Best Management Practices

In 1998, the national water quality inventory indicated that 59% of the impaired river miles were a result of agriculture that included crop production, animal operations, and pastures and rangeland. Many agricultural producers are unaware of the practices that may cause impairment to water quality and may require assistance to implement the recommended practices. The following recommendations are presented to assist in reducing the impacts of livestock operations on water quality:

- Utilize rotational grazing assists in reducing soil erosion
- Develop off-stream water sources for livestock helps develop and maintain healthy riparian vegetation that filters nutrients and sediment
- Composting of solids use methods that prevent leaching of fluids or produce runoff to streams
- Accumulate and store manure appropriately store away from ditches and streams; kept covered to prevent leaching of bacteria and nutrients
- Protect water supply sources locate wells upgradient from confinement areas
- Plant and maintain buffer zone vegetation use buffer areas around manure storage and along drainageways and streams
- Armor heavy use areas use armoring materials to prevent soil erosion in heavily used areas
- Use livestock fences– prevent overgrazing and protect riparian buffers
- Use anaerobic digestion of waste to recover energy

- Use constructed wetlands to capture and treat runoff
- Use bio-filtration to control odor, gas, and dust emissions from facilities
- Use sequencing batch reactor for nitrogen management nitrogen removal
- Protect groundwater sources from contaminated water sources by installing liners to protect groundwater and allow water to evaporate

Recommendations for crop operations to improve water quality include:

- Use crop rotation to reduce soil loss and prevent nutrient depletion
- Control sediment using straw mulch to reduce erosion and prevent nutrient loss
- Plant streamside buffers to reduces nutrient pollution into streams
- Manage manure and nutrient applications so they are evenly applied as needed by crop type
- Apply fertilizers and chemicals in accordance with soil and plant needs to prevent excess nutrients and chemicals being washed into streams or percolating to groundwater
- Test manure to assist in establishing appropriate levels of manure application and guide fertilizer applications
- Test soils to prevent over application of nutrients
- Schedule irrigation based on crop needs, soil type, climate, topography, and infiltration rates to reduce run-off caused by overwatering

Assessments of the current practices in the county should be identified through survey mailings and questionnaires. Identification of the agricultural practices will determine the needs of the area and assist in developing guides to assist farmers and crop producers.

#### 14.10 Public Education/ Outreach

Public involvement facilitates interest and education while spreading the word. As citizens become informed and educated about the community initiatives they are more likely to participate and volunteer in programs. Public awareness and acceptance are crucial for the political and financial sustainability of water quality programs and efforts by local governments. Specific public education efforts include:

TV Commercials	Newspaper prints
Flyers	Poster Contest
Brochures	Photo Contest
Essay Contest	Billboard Announcements
Workshops	HOA Newsletters
Adopt-a-Stream	Stream Plantings

#### 14.11 Municipal Practices and Good Housekeeping

Activities and efforts by municipalities to participate in pollution prevention and good housekeeping are:

- Municipal Training and Education
- Parking Lot and Street Cleaning
- Municipal Landscaping
- Roadway Maintenance
- Spill Response and Prevention
- Hazardous Waste Pick-up and Drop-off days

The proactive efforts in establishing good housekeeping policies contribute to maintaining healthy streams and rivers by preventing pollution that would otherwise reach our waters.

14-13

## 14.12 Implementation Recommendations for the CCRWQPP

The following elements are recommended for implementation in Caldwell County to assist in improvement of existing water quality in degraded streams and prevent water quality degradation of streams in the future:

- Point Discharge Load Reductions
- Stormwater Filter Strips Along Streams
- Water Quality Remediation Associated with Impervious Cover Installation
- OSSF Inspection and Certification

# 14.12.1 Point Discharge Load Reductions

Wastewater treatment plant discharges represent a continuous point source of pollutants discharging into streams. Two practices can materially impact the pollutant discharge loading to streams. Producing "higher" quality of water for discharge will reduce loading and implementing reuse of reclaimed water can reduce loading.

Higher quality of discharge water refers to improving the treatment processes within a treatment plant to remove additional pollutants before the treated water is discharged to the stream. The effluent pollutant limits for wastewater treatment plants are established in permits issued by the TCEQ and based on the quality of the discharge and its impact on the receiving waters. The permits consider the ability of the stream to assimilate the pollutants discharged into it without lowering the water quality in the stream below the standards established for the reaches of stream below the outfall.

The larger wastewater treatment plants in the county are operated by the City of Lockhart and the City of Luling. The total existing plant capacity for Lockhart is 2.6 mgd and for Luling it is 1.4 mgd.

The existing wastewater treatment plant discharge parameters for these plants are shown in *Table 14-2*:

Table 14-2						
Wastewater Treatment Plant Permit Parameters						
ParameterLockhartLockhartLulingLulingPlant 1Plant 2Plant 1Plant 2						
Permitted Flow Capacity, mgd	1.1	1.5	0.5	0.9		
BOD <sub>5</sub> , mg/l	-	-	20	-		
CBOD <sub>5</sub> , mg/l	10	10	-	10		
NH <sup>3</sup> as N, mg/l	3	3	-	3		
Dissolved Oxygen, mg/l	4	5	2	5		
Total Suspended Solids, mg/l	15	15	20	15		

As the quality of discharge from wastewater treatment plants is raised to a higher standard, it becomes cost effective to implement water reclamation and a water reuse program. The following explanations provide information regarding implementation of a water use program.

*Water reuse* is the beneficial use of reclaimed water. Examples of water reuse include irrigation, cooling, or washing.

*Reclaimed water* is domestic or municipal wastewater which has been treated to a quality suitable for beneficial use.

Reclaimed water is not the same as *greywater* which is untreated, non-toilet, and household water including water from sinks, showers, and baths.

*Type I reclaimed water* is defined as use of reclaimed water where contact between humans and the reclaimed water is likely. Examples include landscape irrigation at individual homes or on public golf courses, fire protection, toilet or urinal flushing, and irrigation of pastures for milking animals.

*Type II reclaimed water* is defined as reclaimed water where contact between humans and the water is unlikely. Examples of Type II use include dust control, cooling tower applications, irrigation of food crops where the reclaimed water is not expected to come in direct contact with the edible part of the crop, and maintenance of impoundments or natural water bodies where direct human contact is not likely.

*Direct use* means the beneficial use of reclaimed water that has been transported from the point of production to the point of use without intervening discharge to waters of the state.

*Indirect use* means the beneficial use of reclaimed water that has been transported from the point of production to the point of use with an intervening discharge to waters of the state.

*Bed and Banks Permit* refers to authorization from the State of Texas to discharge water to waters of the state and subsequently recover that water at a downstream point. Water moved under a bed and banks permit cannot degrade the quality of water in the state waters, must not impact existing water rights, must not negatively impact instream uses, aquatic or riparian habitats or freshwater flows to bays and estuaries.

The use of reclaimed water in Texas is governed by TCEQ Chapter 210 (Use of Reclaimed Water) which provides for the quality criteria, design, and operational requirements for the beneficial use of reclaimed water.

Benefits of using reclaimed water include:

- The water is less expensive to use or to treat and users benefit from the savings
- It is a drought-proof source of water

- It is a source of water that automatically increases with increased economic activity and population growth
- It conserves traditional sources of water such as groundwater and surface water.

Disadvantages of using reclaimed water include:

- Water reuse may be seasonal in nature and can result in the overloading of treatment and disposal facilities during off seasons
- Reclaiming wastewater for reuse requires a treatment system which could result in higher initial costs
- Public acceptance of what some may consider as "dirty water" may be hard to overcome
- The end use for the reclaimed water can be located at a distance from the source and require a conveyance and distribution system that adds to the cost of the reclaimed water

If the wastewater plants produce Type I reclaimed water for reuse, the discharge parameters would be as follows in *Table 14-3*:

Table 14-3           Reclaimed Water Quality Parameters				
Parameter	Type I Reclaimed Water	Type II Reclaimed Water		
BOD <sub>5</sub>	5 mg/l	20 mg/l		
CBOD <sub>5</sub>	5 mg/l	15 mg/l		
Turbidity	3 NTU	No Requirement		
Fecal Coliform	20 CFU/100 ml*	200 CFU/100 ml*		
Fecal Coliform (not to exceed)	75 CFU/100 ml**	800 CFU/100 ml**		

14-17

\* geometric mean

\*\* single grab sample

Pollutant loading to streams from existing and future wastewater treatment plants can be meaningfully reduced and minimized by implementing two practices. These are:

- Renovate existing wastewater treatment plants and construct future wastewater treatment plants to produce and discharge effluent that has less pollutant load
- Produce reclaimed water that can be diverted for reuse away from streams

Renovating existing treatment plants to produce higher quality effluent can reduce pollutant loading for organic loading, nutrient loading and bacterial loading. If a goal is established for treatment plants to produce Type I reclaimed water, pollutants loads can be reduced as illustrated in Table *14-4*. If reuse of reclaimed water is implemented, there will be additional reductions in pollutant loading to streams. *Table 14-5* illustrates the load reductions if the existing treatment plants are upgraded and 50 percent of the reclaimed water is reused and the remaining 50 percent is discharged to streams.

Table 14-4           Annual Pollutant Load to Streams for Upgraded Existing Wastewater Treatment Plants								
Plant		ted Flow ity, mgd	CBOD <sub>5,</sub> pounds per year		Total Suspended Solids, pounds per year		NH <sup>3</sup> as N, pounds per year	
	Existing	Upgraded	Existing 10 mg/l	Upgraded 5 mg/l	Existing 15 mg/l	Upgraded 5 mg/l	Existing 3 mg/l	Upgraded 2 mg/l
Lockhart 1	1.1	1.1	33,503	16,751	50,254	16,751	10,051	6,701
Lockhart 2	1.5	1.5	45,685	22,843	68,528	22,843	13,706	9,137
Luling 1	0.5	0.5	30,457*	7,614	30,457**	7,614	4,569***	3,046
Luling 2	0.9	0.9	27,411	13,706	41,117	13,706	8,223	5,482
Total	4	4	137,056	60,914	190,356	60,914	36,549	24,366

\*\*Based on 20 mg/l for BOD<sub>5</sub> \*\* Based on 20 mg/l for Total Suspended Solids \*\*\* Based on 3 mg/l for NH<sup>3</sup> as N, permit has no limit The pollutant load reduction from the upgrade of existing treatment plants for the shown parameters would be:

- CBOD<sub>5</sub> or BOD5 (with 5 mg/l as limit): 76,412 pounds per year
- Total Suspended Solids (with 5 mg/l as limit): 129,442 pounds per year
- Table 14-5 Annual Pollutant Load to Streams for Upgraded Existing Wastewater Treatment Plants with 50 Percent Reuse of Reclaimed Water **Total Suspended** CBOD<sub>5</sub> NH<sup>3</sup> as N, pounds **Permitted Flow** Solids, pounds Capacity, mgd per year per year pounds per year Plant Upgraded Upgraded Upgraded Upgraded Existing Existing 5 mg/l Existing 2 mg/l5 mg/lExisting with 10 mg/l with 15 mg/l with 3 mg/lwith Reuse Reuse Reuse Reuse Lockhart 1 1.1 0.55 33,503 8,376 50.254 8,376 10,051 3.350 Lockhart 2 4,569 1.5 0.75 45,685 11,421 68,528 11,421 13,706 Luling 1 4,569\*\*\* 1,523 0.5 0.25 30,457\* 3.807 30,457\*\* 3.807 Luling 2 0.45 0.9 27,411 6,853 41,117 6,853 8,223 2,741 Total 4 2 137.056 30.457 190.356 30.457 36.549 12,183
- NH<sup>3</sup> as N (with 2 mg/l as limit): 12,183 pounds per year

\*\*Based on 20 mg/l for BOD<sub>5</sub>

\*\* Based on 20 mg/l for Total Suspended Solids

\*\*\* Based on 3 mg/l for NH<sup>3</sup> as N, permit has no limit

The pollutant load reduction from the upgrade of existing treatment plants and implementing reuse of 50 percent of the reclaimed water for the shown parameters would be:

- CBOD<sub>5</sub> or BOD5 (with 5 mg/l as limit): 106,599 pounds per year
- Total Suspended Solids (with 5 mg/l as limit): 159,899 pounds per year
- $NH^3$  as N (with 2 mg/l as limit): 24,366 pounds per year

Future growth in Caldwell County will increase wastewater production to an estimated 10.2 mgd. If 70 percent of the wastewater is treated by regional wastewater treatment plants, the volume of wastewater produced will be 7.1 mgd. If 50 percent of the reclaimed water is reused, the wastewater to be discharged to streams will be 3.6 mgd. If Type I reclaimed water is produced, the future pollutant loading will be less than the current loading. Table *14-6* illustrates this comparison.

Table 14-6           Comparison of Future Changes to Annual Pollutant Load to Streams				
Year	YearPortion of Permitted Flow Discharged to Streams, mgdCBOD5, pounds per yearTotal Suspended Solids, pounds per yearNH³ as I pounds pr year			
2010*	4	137,056	190,356	36,549
2040**	3.6	54,822	54,822	21,929
Difference	0.4	82,234	135,534	14,620

\* Based on existing discharge pollutant limits

\*\* Based on Type I Reclaimed Water and 50 % reuse of reclaimed water

# 14.12.2 Stormwater Filter Strips Along Streams

Stormwater runoff produces significant pollutant loading for streams in Caldwell County. Vegetated filter strips adjacent to streams can provide significant stormwater treatment as overland flow passes through the filter strips.

It is recommended that entities in Caldwell County that have regulatory authority implement requirements for filter strips adjacent to streams. The filter strips should be on each side of the stream with the width of the filter strip being measured from the top of bank for the stream. The recommended filter strips widths are presented in *Table 14-7*.

Table 14-7 Vegetated Filter Strip Width Requirements		
Drainage Area of Stream at Design Point, Acres		
0 to 10	10	
>10 to 100	25	
>100	50	

## 14.12.3 Water Quality Remediation Associated with Impervious Cover Installation

Increased stormwater runoff associated with installation of impervious cover results in increased pollutant loading associated with the stormwater. Capturing and filtering the "first-flush" runoff can significantly reduce pollutant loads. In addition, development rules that encourage limited impervious cover on tracts should be utilized.

It is recommended that entities in Caldwell County (those that have regulatory authority) implement requirements for limited impervious cover on tracts and requirements to capture and filter first flush runoff. The recommended impervious cover limits and filter requirements are presented in *Table 14-8*.

Table 14-8 Impervious Cover Filtration Requirements		
Impervious Cover Percentage	Volume of Water to Be Filtered, Inches	
0 to 20	0.00	
>20 to 50	0.50	
>50 to 80	0.75	
>80 to 100	1.00	

14-21

## 14.12.4 OSSF Annual Inspection and Certification

Failed OSSFs can be significant sources of bacteria and other pollutants for streams. In addition, improperly constructed, operated and/or maintained OSSFs can be contributors to bacteria and pollutants in streams.

Each entity responsible for permitting OSSFs should implement inspection and recertification programs. The frequency of inspection and recertification should be based the type of facility being served by each OSSF. *Table 14-9* presents the recommended program.

Table 14-9           Frequency of OSSF Inspection and Recertification Program				
Type of SystemFrequency of Self Inspection with Report to Regulatory Entity, yearsRecertification by Regulatory Entity, years				
Single Family Residential	2	5		
Multiple Family Units	1	3		
Commercial	1	3		
Other	Established at Permitting	Established at Permitting		

## **SECTION 15**

## **REGIONAL WATER QUALITY IMPLEMENTAION**

## 15.1 General

Regional implementation will require county, city, district, and local officials to be engaged and committed to the success of the planning strategies. Caldwell County has an opportunity to create new development standards that include stormwater, landscaping, and natural resource protection before development growth escalates. Unmanaged development and lack of natural resources protection will permit further deterioration of waterways.

Preservation of the natural resources will be accomplished by developing stormwater management policies, development ordinances, regional cooperation, and funding.

# **15.2** Stormwater Management Implementation

Training and education of personnel at the management and staff level of the EPA's water quality and TMDL standards is necessary for understanding stormwater pollution. Technical staff reviewing and approving development permits need to have some knowledge of nonpoint source pollution and the effects if uncontrolled.

 Development of a Stormwater Management Manual – policy manual that covers principles in design and construction of permanent structural controls for stormwater runoff. Instruction to staff on policies and procedures to improve plan review. Having staff understand the design of low-impact and smart-growth developments can benefit developers and investors in planning.

- Water Quality Monitoring Program test and monitor stormwater runoff and establish a database with results. The establishment of a database and mapping system can track and monitor development contributions to water quality.
- Water Quality Technical Committee the committee role could be to develop standards for local governments such as:
  - Sampling methods
  - Monitoring of data collected
  - Establishment of database
  - Data management
- Stormwater Operations and Maintenance management program to ensure proper drainage and pollutant removal efficiency. Inspection and maintenance of drainage structures and conveyance systems. Development of a plan for routine and remedial maintenance with an emergency containment plan in the event of a hazardous spill.
- Hazardous Household Waste Collection Program provide accessible recycling centers or drop off locations for the disposal of hazardous household items.
- Agricultural Management Programs provide tools for agricultural producers to remain profitable while protecting natural resources. Such tools could be:
  - On farm research and demonstration of BMP's
  - Pilot projects that evaluate or transfer technology
  - Conduct interviews and collect data
  - Educate and increase awareness of local practices
    - Workshops on new technology

0

Additional management measures recommended for implementation in the Plum Creek Watershed Protection Plan have been included in **Appendix J.** 

#### **15.3** Development of Ordinances

Many cities currently have ordinances that monitor and control stormwater quality and quantity. Ordinances include:

- Stormwater Development Ordinance management of runoff quality and quantity
- Illegal Stormwater Connection Ordinance prevents illegal connections to stormwater systems
- Floodplain Development Ordinance management of flood prevention and mitigation
- Buffer Ordinance control of runoff near streams by listing the type of developments allowed near floodplains/streams/creeks and give buffer width recommendations for each type of development or land use
- Greenspace Conservation Ordinance control of impervious cover development
- Tree Ordinance control of tree canopy reduction for developments

## **15.4 Regional Agreement**

An agreement established by local governments in Caldwell County will ensure that all entities are informed about the proposed regional practices and development of facilities. A Regional Compact has been included in **Appendix K**.

## 15.5 Funding

Funding to implement the recommended strategies requires community leaders to actively and rigorously apply for grants and search for monies available to execute strategies. Local, state, and federal sources are expected to fully fund programs. The EPA, TCEQ, TWDB, the Natural Resources Conservation Service (NRCS) and additional Foundations and Partnerships offer possible funding sources.

## Agriculture Best Management Practices (BMP) Loans

Develop low to no interest loans to producers for BMP implementation and new technology that enhances animal agriculture. This option will need to be developed for Texas. Currently, the Virginia Department of Environmental Quality and Minnesota Department of Agriculture provide these funding services. Further investigation to develop this program is required at the state or county.

# Agriculture Water Conservation Grants and Loans

State agencies and political subdivisions of the state are eligible for the grants and loans made available to political subdivisions of the state, institutions of higher education, interstate compact commissions, and nonprofit water supply corporations (Chapter 69 of Water Code). Banks and farm credit system may apply for link deposit funds to make loans available to individuals.

# Clean Water State Revolving Fund (CWSRF)

The CWSRF provides funding for water quality projects that are associated with wastewater treatment, nonpoint source pollution control, and watershed and estuary management. Funds are available through full grants and low-interest loans with flexible terms for planning, acquisition and construction, wastewater treatment, stormwater and nonpoint source pollution control, and reclamation/reuse projects.

## Economically Distressed Area Program

The TWDB provides grants, loans or a combination for water and wastewater services in areas of economic distress where current facilities are inadequate to meet residents' minimum standards.

## **Environmental Quality Incentives Program (EQIP)**

The Environmental Quality Incentives Program (EQIP), implemented by the NRCS, offers financial and technical assistance for application of structural and management BMP's on agricultural land.

# Drinking Water State Revolving Fund

The Drinking Water State Revolving Fund (DWSRF) program awards capitalization grants to states to provide low-cost loans to public water supply systems for infrastructure needed to achieve or maintain SDWA compliance. These loans and additional subsidies are available for disadvantaged communities only. Community water system owners, political subdivisions of the state and private individuals are eligible to apply for the funding.

# Environmental Educational Grants

The Environmental Educational Grants provide funding for educational projects that enhance the public's awareness, knowledge, and skills to help people make informed decisions that affect environmental quality.

# **EPA Smart Growth Grants**

Limited grants are occasionally offered by the EPA to support activities that improve the quality of developments and protect human health and the environment. Funding for the program ranges between \$2 and \$3 million with average grants in the \$15,000 to \$25,000 range.

## Foundations and Partnerships

Over 200 Foundations and Partnerships are listed in the National Council for Science and the Environment that can provide an additional source of funding. Numerous funding opportunities were also listed at the National Science Foundation.

## • Federal Clean Water Act Grant Program (Section 319(h))

Under the Federal Act Grant Program, the USEPA appropriates funds to TCEQ to fund nonpoint source pollution management. Administered funds are used to assess nonpoint sources of pollution, provide education and outreach, develop and implementing watershed protection plans, implement nonpoint source portions of TMDL Implementation Plans, and implement both the technology-based and water-quality-based management measures contained in the coastal nonpoint pollution control programs.

## General Revenues

A fee based on the amount of runoff to tie into the local MS4 can be allocated through a development permit. Bond sales, development impact fees and stormwater user fee are other alternatives and options. Property taxes and sales taxes can also be a source of contribution.

Several bond types are currently available to provide financing. Depending on goals, tax situation and risk tolerance, the options available are: municipal, government, corporate, asset-backed, securities and international bonds. Development impact fees can be applied at the application stage of development. Fees can be based on site acreage, location, and type of development.

Stormwater user fees can be assessed on a one time basis or annually depending on discharge rate and quality of runoff. Fees can be appropriated to fund O&M programs.

The general tax revenue fund may have available monies for to develop and/or maintain programs.

## Privatization

Privatization involves partnering with the private sector to plan, finance and develop, operate and maintain facilities for the public sector. Contracts outline the obligations and agreements of the responsible party.

## Supplemental Environmental Project Program

The Supplemental Environmental Project Program (SEP) provides funds collected through penalties and fines. Instead of applying monies to the State's General Revenue Fund, TCEQ will apply them toward remediation and improvements in the environmental quality of the region where the fines were collected.

# Targeted Watersheds Grants Program

The Targeted Watershed Grants Program funds are designed to encourage successful community-based approaches and management techniques to protect and restore watersheds. The awarded funds have been given on a competitive basis for water quality trading, agricultural best management practices, wetland and riparian restoration, nutrient management, fish habitat restoration and public outreach and education. The stakeholders of the watershed organizations should include various types of community leaders from educational to political and non-profit affiliations.

#### Water Quality Management Plan Program

The Water Quality Management (WQMP) Plan program is implemented by the Texas State Soil and Water Conservation Board (TSSWCB) for the development of a site specific plan. The TSSWCB determines the level of pollution prevention or abatement that is consistent with the state's water quality standards. The methods for meeting these standards include appropriate land treatment practices, production practices, management measures, technologies or combinations thereof.

#### Water Pollution Control Program Grants (Section 106)

15-8

The Water Pollution Control Program funds ongoing water pollution control programs that include permitting, pollution control activities, surveillance, monitoring, and enforcement; advice and assistance to local agencies, and the provision of training and public information.

#### **SECTION 16**

## SUMMARY OF RECOMMENDATIONS FOR WATER AND WASTEWATER FACILITIES

#### 16.1 Introduction

The following paragraphs summarize the general facilities plans for water and wastewater treatment that resulted from the Caldwell County Regional Water and Wastewater Planning Study.

#### 16.2 Recommended Regional Water Supply Facilities

The recommended regional water supply facilities are those that will be developed to utilize water made available under a proposed conjunctive-use groundwater-surface water project to be developed by the GBRA. This project, known as the Mid-Basin Project, was not included in the 2006 Region L Plan and a request has been made by GBRA to add the project to the 2011 Region L Plan.

The proposed Mid-Basin Project will provide 25,000 ac-ft to customers of Caldwell, Comal, Gonzales, Guadalupe, and Hays Counties. The source of water will be primarily surface water from the Guadalupe River with a point of diversion below the confluence of the San Marcos River. The water in the river at the proposed diversion point is not considered firm yield unless it is backed up with off channel storage or a groundwater source. Off-channel storage in Guadalupe County is being considered for the Mid-Basin Project as well as a secondary source of supply from the Carrizo and/or Wilcox Aquifers in west-central or northeast Gonzales County.


The advantage of the Mid-Basin Project compared to the proposed Hays-Caldwell PUA Project is the ability of the Mid-Basin Project to draw on either surface

water or groundwater to meet future water supply needs. Redundancy in water sources is an important part of a long-term water supply plan to buffer impacts from droughts, aquifer management rules and potential pollutant contamination of water sources.

*Exhibit 16-1* presents the features of the recommended regional water supply plan. The primary features include:

- River pumping plant with dam to create pumping pool in Guadalupe River for scalping flood flows
- Off-channel storage reservoir near river pumping plant to provide water delivery system water balance
- Carrizo Aquifer Well Field in southern Caldwell/northeastern Gonzales Counties
- Pipeline (approximately 18 miles) to convey raw surface water from offchannel storage reservoir to Luling
- New surface water treatment plant at Luling
- Pipeline (approximately 21 miles) to convey unchlorinated groundwater from Carrizo well field to Lockhart
- New groundwater treatment plant at Lockhart
- Pipeline (approximately 12 miles) to convey treated water north from Lockhart along SH 130
- Pipeline (approximately 10 miles) to convey treated water west from Lockhart along SH 130
- Pipeline (approximately 7 miles) to convey treated water north from Lockhart along FM 2720
- Use existing pipeline from Lockhart to Luling to move water in either direction as demands and supplies are balanced

The majority of the stakeholders attending the regional planning meetings supported either the proposed Mid-Basin Project or the HCPUA Project. The



16-3

Mid-Basin Project and associated facilities were recommended for implementation. There was no voiced or written opposition to the Mid-Basin Project but the owners of the HCPUA project have expressed that they will continue to move the HCPUA project forward.


## **16.3 Recommended Regional Wastewater Treatment Facilities**

The recommended regional wastewater treatment facilities are based on a regionalization concept that will ultimately provide four regional wastewater facilities in the county. These facilities will be sized and phased to accommodate growth and enable reuse of reclaimed water.

*Exhibit 16-2* presents the features of the recommended regional wastewater treatment plan. The primary features include:

- Wastewater treatment plant at Lockhart
- Wastewater treatment plant at Martindale
- Wastewater treatment plant at Luling
- Wastewater treatment plant in Peach Creek Basin
- Regional wastewater collection pipelines with downstream connectivity

The majority of the stakeholders attending the regional planning meetings supported either the proposed regional plan or a decentralized plan of multiple smaller treatment plants throughout the County. The large plant regionalization plan was recommended for implementation. There was no voiced opposition to the large plant regionalization plan but there is growing interest in the decentralized treatment plant concepts.





# Appendix A

Caldwell County Stakeholder Sign-In Sheets

		S	Sign in Sheet		
Group	Here	Contact	Address	ĊĬŴ	Email
Texas State Soil & Water Conservation		Pam Casebolt	P. O. Box 658	Temple, Texas 76503- 0658	awendt@tsswcb.state.tx.us
Board	7	HULON MENON			purse with the source.
Tri-Community Water Supply Corporation		Tommy Forester	92 Ward Street	Fentress, Texas 78622	tri-commwater@hwtx.com
Turner Crest	•	Bob Richards	100 E. San Antonio St., Suite 103A	San Marcos, Texas 78666	brichards@ccias.com
Creedmoor- Maha WSC		Charles Laws	12100 Laws	Buda, TX 78610-9607	
Luling Independent School District		Mark Weisner	212 E. Bowie	Luling, TX 78648	
San Marcos Consolidated Independent School District		Dr. Patty Shafer	P.O. Box 1087	San Marcos, TX 78667	

	Email	muclson of udb. State. to. w					
	City	Austin, Texas 78711- 3231	San Marcos, Texas 78666	Seguin, Texas 78155	Gonzales, Texas 78629	Bastrop, TX 78602	Lockhart, TX 78644
Sign in Sheet	Address	P.O. Box 13231	111 E. San Antonio, Suite 300	307 W. Court Street	414 St. Joseph St., Suite 200	650 Hwy 21E	191 <b>6</b> W. San Antonio St.
	Contact	Matt Nelson	Liz Sumter, County Judge	Mike Wiggins, County Judge	David Bird, County Judge	Tommy Frizzell	Joyce Buckner
	Here	7				$\mathbf{X}$	
	Group	Texas Water Development Board	Hays County	Guadalupe County	Gonzales County	Bluebonnet Electric	Bluebonnet Electric

		Š	Sign in Sheet		
Group	Here	Contact	Address	City	Email
County Line Water		Daniel Heideman	ŧ	Kyle, Texas 78640	heideman@clws.com
Supply Corporation	7		Road 1315	whend	512-398-4748
Crystal Clear Water		Mark Speed	2370 FM 1979	San Marcos, Texas	mark@crystalclearwsc.com
Supply Corporation	7			78666	
Envision Central Texas		Jim Walker	P.O. Box 17848	Austin, Texas 78760- 7848	info@envisioncentraltexas.org
Envision Central Texas	>	Sally Campbell, Executive Director	P.O. Box 17848	Austin, Texas 78760- 7848	info@envisioncentraltexas.org
Gary Job Corp		Bob Elsey	P.O.Box 967	San Marcos, Texas 78666	elsey.bob@jobcorp.com
GoForth Water Supply Corporation		Mario Tobias	8900 Niederwald Strasse	Kyle, Texas 78640	mario@goforthwater.org
Gonzales County Water Supply Corporation		Barry Miller	1903 E. Sarah DeWitt Drive	Gonzales, Texas 78629	
Lockhart Independent School District		Dr. Jose Parra	P.O.Box 120	Lockhart, Texas 78644	

		ş							
	Email/Phone no.	Jour Legaque WSC. Com	<u>htwright@lockharttx.net</u> or <u>marie.cavanagh@co.caldwell.tx.</u> <u>us</u>	<u>crwa@crwa.com</u>	jbertram@lockhart-tx.org	vrodgers@lockhart-tx.org		mhendricks5@austin.rr.com	bethh@martindaletexas.org
	City	Bastrop, Texas 78602	Lockhart, Texas 78644	New Braunfels, Texas 78130	Lockhart, Texas 78644	Lockhart, Texas 78644	Luling, Texas 78648	Luling, Texas 78648	Martindale, Texas 78655
Sign in Sheet	Address	P.O. Box P	110 S. Main St.	850 Lakeside Pass	P.O. Box 239	P. O. Box 239	509 E. Crockett	509 E. Crockett	P. O. Box 365
	Contact	John Burke	H. T. Wright	David Davenport	James Bertram	Vance Rogers	Bobby Berger	Mike Hendricks	Patricia Petersen
	Here		7	7	Í	7			
	Group	Aqua Water Supply Corporation	Caldwell County	Canyon Regional Water Authority	City of Lockhart	City of Lockhart	City of Luling	City of Luling	City of Martindale

# Kick-off Meeting - September 25, 2008 Sign in Sheet

Group	Here	Contact	Address	City	Email
Prairie Lea Independent School District		Lopez	6910 San Marcos Hwy	Prairie Lea, TX 78661	
Edwards Aquifer Authority	>	Mr. Mark Taylor, Board Member – District 11	<del>1615 N. St.</del> Mary's Street 130 E Siem	<del>8an Antonio, TX 78215</del> San Incres TX 18666	markbtaylor@grandecom.net
Hays Caldwell Public Utility Agency	> '	Graham Moore	400 West Hopkins, Suite 203	San Marcos, TX 78666	gmmoore@lan-inc.com
Gonzales County Groundwater Conservation District	7	Greg Sengelmann	P.O.Box 1919	Gonzales, Texas 78629	geuwedæguec.net
Caldwell County Environmental Enforcement		Robert Hall	405 E. Market Street	Lockhart, Texas 78644	
Oscar Fogle	2	GBRA Director	3146 Westwood Road	Lockhart, Texas 78644	oscar@fogle.org

	<del>utin n com</del> peed org	<del>uctin n. com</del> pcco. org ted . org mu.edu	<del>uctin n. com</del> pc. o. org tr cd . org nu.edu et	uctin m. com pc. D.	pccdjohnie@austin.r.compc.0.019 info@ptcd.o19 n-dictson@tamu.edu paulp@ctxu.net wassenich@sanmarcos.net
	pccdjohnie@austin.n.com/ info@ptcd.org	pccdjohnie@austin.n. info@ptcd. n-dictson@tamu.edu	pccd <u>iohnie@austin.rr.</u> info@ptcd. n-dictson@tamu.edu paulp@ctxu.net	pccdjohnie@a <del>ustin.n.som</del> info@p¢cd.org n-dictson@tamu.edu paulp@ctxu.net wassenich@sanmarcos.net	
	Lockhart, Texas 78644	Lockhart, Texas 78644 College Station, Texas 77843-2474	Lockhart, Texas 78644 College Station, Texas 77843-2474 Lockhart, Texas 78644	Lockhart, Texas 78644 College Station, Texas 77843-2474 Lockhart, Texas 78644 San Marcos, Texas 78666	Lockhart, Texas 78644 College Station, Texas 77843-2474 Lockhart, Texas 78644 San Marcos, Texas 78666 Uvalde, Texas 78802
00001	1403 Blackjack Lo Street, Suite 3 78		ackjack buite 3 eep 5474 5x 778	ackjack ackjack eep 2474 5x 778 5x 778 5x 778 5x 778	ackjack ackjack 2474 2474 5478 5478 5478 5478 5478 5478 5478 5
	le c	rton Veyer	Meyer 1	nurton Meyer (Y enich	nton Meyer (y enich
_	V Johnie Halliburton	V Johnie Hallibu V <b>Pan'el A</b> Nikki Dictson	V Johnie Halliburto Dan'el Me Nikki Dictson V Joe Kelly		
	cek ation District	eek ation District eek Watershed hip	eek ation District eek Watershed hip Water Supply tion	eek ation District reek Watershed hip Water Supply tion troos River tion	Plum Creek Conservation District Plum Creek Watershed Partnership Polonia Water Supply Corporation San Marcos River Foundation South Central Texas Water Planning Group

Kick-off Meeting - September 25, 2008

398 - 2857


5

Griselda Gonzales 755D IH ID West Suito 300 S.A. TX (210) 736-0425 griselda.gonzales@klotz.com

Alan Thompson Klotz Associates alan. thompson@klotz.com

Pamela Hohman Eastern Caldwell Co. Landowners Banelahohman@ Gmail.com 836 540 3727

### Caldwell County Water and Wastewater Planning Study Advisory Group Meeting 2




## **SIGN IN SHEET**

Please verify information and check next to name. Please add a contact phone number where you can be reached. Add contact information if not listed. Thank you.

T NOT IISTED. I NANK YOU.	Address/Phone #	Attendees		Final	
Organization	PO Box 658	Pam Casebolt		pcasebolt@tsswcb.state.tx.us	
Fexas State Soil & Water	Temple, Texas 76503-0658	Aaron Wendt		awendt@tsswcb.state.tx.us	
Conservation Board	Temple, Texas 70505-0056				
	PO BOX 13231	Matt Nelson		mnelson@twdb.state.tx.us	
Texas Water Development Board	Austin, Tx 78711-3231				
Development board					
	650 Hwy 21E	Tommy Frizzell		-	
Bluebonnet Electric	Bastrop, Tx 78602				
					~
	1916 W San Antonio St.	Joyce Buckner		joyce buckner arbhebo	nnet etectri
Bluebonnet Electric	Lockhart Tx, 78644			~ ~	
	South				
County Line Water	131 Camino Real	Daniel Heideman		heidman@clws.com	
Supply Coorporation	Uhland, Texas 78640	512-738-2073	- <i>V</i>		
	2370 FM 1979	Mark Speed			
Crystal Clear Water	San Marcos, Texas 78666		$+ \mathcal{V}$	····	
Supply corporation				· · · · · · · · · · · · · · · · · · ·	
	PO Box 17848	Sally Campbell		info@envisioncentraltexas.org	
Envision Central Texas	Austin, Texas 78760-7848			Scampbell Denvision	
		· · · · ·		centraltexasiona	
	PO Box P	John Burke			
Aqua Water Supply Corporation	Bastrop, ⊺x 78602				
Corporation					
	110 S Main St	HT Wright	/	htwright@lockharttx.net	
Caldwell County	Lockhart Tx, 78644	Tom BONN	<u> </u>	thonn 71 Ogmail.c	OM
Canyon Regional Water	850 Lakeside Pass	David Davenport		crwa@crwa.com	
Authority	New Brausfels, Texas 78130	Craig Hines		chines@gvec.net	
	PO Box 239	Vance Rogers		vrodgers@lockhart-tx.org	
City of Lockhart	Lockhart Tx, 78644				
-					
Edwarda Aguifar	130 E Sierra Circle	Mark Taylor	V	markbtaylor@grandecom.net	
Edwards Aquifer Authority	San Marcos, Texas 78666				
,		· · · · · · · · · · · · · · · · · · ·			
Hays Caldwell Public	400 West Hopskins, Ste 203	Graham Moore		gmmoore@lan-inc.com	
Utility Agency	San Marcos, Texas 78666		_		
			_	acuwcd@avec.net	
Gonzales County Graoundwater	PO Box 1919 Conzolos, Toxos 78620	Greg Sengelmann		<u>Acamca(6)Anectuer</u>	
Conservation District	Gonzales, Texas 78629				
	3146 Westwood Road	Oscar Fogle, GBRA Director		oscar@fogle.org	
GBRA	Lockhart Tx, 78644		-	A CONTRACTOR OF THE OWNER OWNE	
		Bill West		gm@gbra.org	
	3146 Westwood Road			dmagin@gbra.org	
GBRA	Lockhart Tx, 78644	Debbie Magin		unaginagunaguna	
GBRA		Debbie Magin		unagin (aguna.org	
	Lockhart Tx, 78644 523 Mulberry	Debbie Magin Mike Kuck	-	Iffmanager@sbcglobal.net	
GBRA Luling Foundation	Lockhart Tx, 78644				
	Lockhart Tx, 78644 523 Mulberry Luling, Texas 78648	Mike Kuck		lffmanager@sbcglobal.net	
	Lockhart Tx, 78644 523 Mulberry Luling, Texas 78648				

### Caldwell County Water and Wastewater Planning Study Advisory Group Meeting 2

1



Deleste Mister	PO Box 778	Paul Pitman	μ	paulp@ctxu.net	
Polonia Water SupplyCorporation	Lockhart Tx, 78644	Joe Kelly Austin Pittman, Board President			
		Ausur Fillman, Board Flesident			
Eastern Caldwell County Landowner		Pamela Hobman		pamelahohman@gmail.com	
	7550 IH-10 West, Ste 300	Alan Thompson, PE	+	alan.thompson@klotz.com	
Klotz Associates Inc.	San Antonio, Texas 78229 210-736-0425	Griselda Gonzales	<u> </u>	griselda.gonzales@klotz.xom	
IL ITY RE	DO 815315	PATRILIA PETERSEN		ep Hemera abaustin. 1700	m
MARTINOALE	MARTINOME TX 78655	MAYOR			
Prairie Lea Ist	6910 San Marios Hus	Jesse Lopez	V	jesus loper o prairie le	a.txed.c
	Prairie Lea TK 78661	Superntendent	┨──		
lockhart ISD	P.O. Bor 120	Jose Parva, Sapt,		jose.perra@lockhar	
	Lockhart, TY78644	Ed Shenpard, Principal	<u> </u>	el. sheppede lorkhat	tre no
city of	509 E. Crockett	Bobby Berger Cheis Powell		public works @ citgof/w	ing.ne
holing	Kuling, Tx. 78648				
and with	12100 Laws Rd.	Gen, Managen		Charles PLaws, MOL	,COM
Plum Creek	Mustzy Kilm 18410	Ainki Dictson	IV	ndictson@ag.tamu.	edu
Watershed Partnership	2474 TAMU Collegestation, Tx 77843-2474				
CITY OF SAN	630 E. HOPHINS	TOM TAGGART		taggart-tom Q ci.san-marcos, tr.	
MARCOS/		· · · · · · · · · · · · · · · · · · ·		ci.san-marcos, tz.	25
HCPVA GONZAles Co.	SAN MARCOS, TX 78666 PO Box 749	Barry Miller	-	bmiller e.gueca	VOT
W.5C.	GONZULOS, TY				
		· · · · · · · · · · · · · · · · · · ·		· · · · · · · · · · · · · · · · · · ·	
		·			
				· · · · · ·	
	1	1	1		



# Appendix **B**

# Caldwell County Regional Water and Wastewater Planning Study Utility Survey

### APPENDIX-B

### **Utility Survey**

### Caldwell County Water and Wastewater Planning Study Survey

Utility Name		
Interview Complet	ed By	
Date		_
Do you supply	Potable Water Service	Wastewater Collection and Treatment
Under what law or created?	statue was utility	

### General Information – Please consider only services to Caldwell County

What are your sources of water (please check all that apply):

Groundwater – self produced – permitted annual volume: Groundwater – purchased from others – permitted annual volume: Surface Water – own water rights/self treat – maximum annual volume: Surface Water – buy raw from others/self treat – maximum annual volume: Surface Water – buy treated water from others - maximum annual volume: Other (describe):

Please List Certificates of Convenience and Necessity (CCN) that your utility holds for water.

Number Date Granted

Page 1 of 10 T:\0972.000.000\06.00 Work Products\Report\TOC-Appendix\APPENDIX A - CC UTILITY SURVEY\Survey.doc

For Calendar Year 2008, what was your average daily water delivery? \_\_\_\_\_mgd What is your historic peak day volume for water delivery? \_\_\_\_\_mgd that occurred on \_\_\_\_\_(month, day, year)

Please provide the following water use data:

<u>Calendar Year</u>	Volume of Water Pumped into System	Volume of Water Billed
2008	Million Gallons	Million Gallons
2007	Million Gallons	Million Gallons
2006	Million Gallons	Million Gallons
2005	Million Gallons	Million Gallons
2004	Million Gallons	Million Gallons

Please provide the following customer data:

<u>Calendar Year</u>	<b>Residential Meters</b>	Commercial/ <u>Industrial Meters</u>	Other Meters
January 1, 2009			
January 1, 2008			
January 1, 2007			
January 1, 2006			
January 1, 2005			

<u>Calendar Year</u>	<u>Residential Meters</u>	Commercial/ <u>Industrial Meters</u>	<u>Other Meters</u>
January 1, 2010			
January 1, 2011			
January 1, 2014			
January 1, 2019			
January 1, 2039			

Your Future Projections (based on your planning):

**Please Describe Your Water Production Facilities:** 

<u>Name</u>	<u>Type (well, treatment plant)</u>	Rated Capacity, mgd

## Population Information – Please consider only population in Caldwell County

Based on the inform	ation you have available	e, can you estima	te:
<u>Calendar Year</u>	Estimated Population i	n your service ar	<u>ea in Caldwell County</u>
January 1, 2009			
January 1, 2008			
January 1, 2007			
January 1, 2006			
January 1, 2005			
Future Projections (	based on your planning)	:	
<u>Calendar Year</u>	Estimated Population i	<u>n your service ar</u>	<u>ea in Caldwell County</u>
January 1, 2010			
January 1, 2011			
January 1, 2014			
January 1, 2019			
January 1, 2039			
Please list your top f	ive water users (in anni	ual volume of wa	ter consumed):
1			million gallons/year
2		<u> </u>	million gallons/year
3.			million gallons/year
4			million gallons/year
5			million gallons/year
Please list any NDEP	'S permits you hold for y	our water produ	ction facilities:
<u>Number</u>	Date Granted	Per	mitted Volume
			million gallons/year
	Pag	ge 4 of 10	

million gallons/year	 
million gallons/year	 
million gallons/year	 

### Water Quality

Please describe any quality issues or concerns you have experienced with your source water:

Do you have any recurring potable water quality issues that are related to your source water?

Describe any concerns you may have regarding point source discharges and non-point source pollution that occurs in Caldwell County that may impact water quality.

### Water Conservation

What measures have you implemented to encourage water conservation?

What future measures are being considered to encourage water conservation?

My utility has a state approved drought contingency plan. Yes. Date of Plan \_\_\_\_\_ No

Plans for the Future

Please describe any plans (available options) that will be considered or implemented to support future growth.

Please describe any planned additions, changes, and/or upgrades for water production facilities.

### Wastewater Services

If you are wastewater service provider, how do you operate? (Please check all that apply) Own and operate wastewater collection system Own and operate wastewater treatment plant Own wastewater treatment plant operated by others Other (describe): \_\_\_\_\_\_

Please List Certificates of Convenience and Necessity (CCN) that your utility holds for wastewater.

Number Date Granted

For Calendar Year 2008, what was your average daily wastewater flow treated (if multiple plants, please break out by plant)? \_\_\_\_\_mgd

What is your historic peak day volume for wastewater water treatment?mgd that occurred on(month, day, year)									
Please provide the following water use data:									
<u>Calendar Year</u>	Volume of Wastewater Treated	Volume of Water Billed							
2008	Million Gallons	Million Gallons							
2007	Million Gallons	Million Gallons							
2006	Million Gallons	Million Gallons							
2005	Million Gallons	Million Gallons							
2004	Million Gallons	Million Gallons							

Please provide the following data regarding sewer connections:

<u>Calendar Year</u>	Residential Sewer	Commercial/ Industrial Sewer	Other Sewer
January 1, 2009			
January 1, 2008			
January 1, 2007			
January 1, 2006			
January 1, 2005			

What are your future projections for sewer connections? (Based on your planning)

<u>Calendar Year</u>	<b>Residential Sewer</b>	Commercial/ <u>Industrial Sewer</u>	Other Sewer
January 1, 2010			
January 1, 2011			
January 1, 2014			
January 1, 2019			
January 1, 2039			

**Please Describe Your Wastewater Treatment Facilities:** 

<u>Name</u>	Type of Treatment Plant	Rated Capacity, mgd

Please list your top five wastewater producers (in annual volume of wastewater):

1	million gallons/year
2	million gallons/year
3	million gallons/year
4	million gallons/year
5	million gallons/year

Please list any NDEPS Permits you hold for your wastewater treatment facilities:

Number	Date Granted	Permitted Volume					
		million gallons/year					
		million gallons/year					
		million gallons/year					
		million gallons/year					

Do you re-use treated wastewater and/or do you have plans to do so?

Please describe any wastewater treatment plans (available options) that will be considered or implemented to support future growth?

Please describe any planned additions, changes, and/or upgrades for wastewater treatment facilities.

### Other

Please provide any other comments pertinent to the study:



# Appendix C

Water Quality Standards

APPENDIX-C

### APPENDIX C

The following tables are found in <u>30 TAC 290 Subchapter F: Drinking Water Standards</u>. Refer to this section of the Texas Administrative Code (TAC) for further details on drinking water standards.

Summary of Secondary Standards								
CONTAMINANT	LEVEL (mg/l except where otherwise stated)							
Chloride	300							
Flouride	2.0							
Iron	0.3							
Manganese	0.05							
Sulfate	300							
Total Dissolved Solids	1,000							

### **Secondary Constituents**

### **Inorganic Contaminants**

Inorganic Contaminants							
CONTAMINANT	MCL (mg/l)						
Nitrate	10 (as Nitrogen)						
Nitrate	1 (as Nitrogen)						
Nitrate & Nitrate (Total)	10 (as Nitrogen)						



# Appendix D

TWDB Groundwater Quality Report



### Texas Water Development Board Groundwater Database Reports



### Water Quality Publication Report

County: Caldwell

State Well Number	Aquifer	Depth	Date	B/U	pH	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
5860703																						
	124WLCX	49	2 / 27/ 19	946 U							0	65.9	28	41		62						
5860704																						
50 40 <b>5</b> 0 5	124WLCX	18	2 / 27/ 19	946 B	7.2	35	46	6.7	36	4.6	0	152.54	20	51	0.2	9.8	284	470	142	35	1.29	0
5860705	124WLCX	44	6 / 11/ 19	946 U							0	84	13	102		41						
5860706	12400 ECA		0, 11, 12	740 0							0	04	15	102		41						
	124WLCX	26	6 / 11/ 19	946 U							0	328	16	84		2.2						
5860707																						
	124WLCX	150	1 / 9 / 19	964 B	7.6	16	24	7.8	c 150		0	334.09	37	74	0.6	0	473	795	92	78	6.77	3.64
5860709											_											
6702503	124WLCX	180	7 / 19/ 19	977 B	7.6	29	50.6	9.97	103		0	219.66	44	115	0.3	2.4	462	846	167	57	3.45	0.25
6702503	110AVML	29	6 / 13/ 19	946 U							0	270	16	16		30						
6702507	1101111111		0 / 10/ 1	, 10 0							0	210	10	10		50						
	110AVML	21	6 / 12/ 19	946 U							7.9	230	20	16		41						
6702601																						
	110AVML	19	6 / 12/ 19	946 U							12	202	32	26		34						
6702602	110.130.0		< 1 101 10	0.4 <i>6</i> . 11							0.0		12	20		60						
6702603	110AVML	21	6 / 12/ 19	946 U							9.8	144	13	28		60						
0702000	110AVML	35	6 / 13/ 19	946 U							11	231	25	27		55						
6702702																						
	100ALVM	27	2 / 26/ 19	968 B	7.3	19	98	7	30		0	339.26	20	22	0.3	7	370	680	273	19	0.79	0.09
6702703											_											_
6702704	100ALVM	31	2 / 26/ 19	968 B	7.2	20	130.2	8.5	57.3		0	345.36	58	55	0.4	72	571	1038	359	25	1.3	0
0702704	110AVML	31	3 / 28/ 19	946 U							0	294	65	71		59						
6702705																						
	110AVML	22	3 / 28/ 19	946 U							0	286	34	64		47						
6702706																						
	110AVML	25	3 / 28/ 19	946 U							0	356	65	141		176						
6702707	100 41 3734	26	2 / 26/ 10	DCO D	7.2	19	106.4	7.66	27.9		0	256.24	27	10	0.5	12	202	716	207	16	0.71	0
6702708	100ALVM	20	2 / 26/ 19	908 B	7.3	18	106.4	7.66	27.8		0	356.34	27	18	0.5	13	393	716	297	16	0.71	0
0702700	100ALVM	29	2 / 28/ 19	968 B	7.1	18	201	21	180		0	339.26	211	334	0.5	16.5	1148	2272	587	39	3.23	0
6702801																						

State Well Number	Aquifer	Depth	Date	B/U	pH	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
	100ALVM	22	2 / 14/ 1	1946 B			122	5.1	c 38		0	268.07	40	81		40	457	891	325	20	0.92	0
6702902																						
	112LEON	25	3 / 28/ 1	1946 U							0	264	110	358		58						
6702905																						
	112LEON	24	3 / 29/ 1	1946 U							0	248	65	239		38						
6702908											_											
	112LEON	20	7 / 18/ 1	1976 B	7.2	17	133.6	5.5	44.4		0	405.15	35	57	0.4	5.8	497	924	356	21	1.02	0
6703301	10.0011 (00	20	< 1 11 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1								0	240	1150	1240								
	124WLCX 124WLCX		6 / 11/ 1		7.0	24	514	215	((0)		0	340	1150	1240	1.5	1.2	4412	0244	21/7	20	6.17	0
6703303	124WLCX	20	7 / 19/ 1	19// В	7.8	24	514	215	660		0	817.63	1788	808	1.5	1.3	4413	8344	2167	39	6.17	0
0705505	124WLCX	67	6 / 11/ 1	1946 U							0	298	24	54		0						
6703304	12400 ECA	07	0, 11, 1	1940 0							0	270	24	54		0						
0705504	124WLCX	72	2 / 27/ 1	1946 U							0	336	85	560		1.5						
6703401	121012011	,2	2 / 2//	010 0							0	550	00	200		1.0						
0705101	110AVML	14	6 / 12/ 1	1946 U							0	308	65	32		25						
6703402																						
	110AVML	30	6 / 12/ 1	1946 U							0	284	54	70		33						
6703601																						
	124WLCX	49	4 / 12/ 1	1946 U							0	412	80	94		0.5						
6703602																						
	124WLCX	35	6 / 11/ 1	1946 U							0	340	765	148								
6703603																						
	124WLCX	26	6 / 11/ 1	1946 U							0	338	430	800								
6703703																						
	112LEON	29	1 / 24/ 1	1946 U							0	326	46	22		26						
6703704																						
	218EDRDA	3367	2 / 20/ 1	1964 B	6.9	17	894	433	c 2480		0	547.15	2130	4770			10993	15800	4012	57	17.03	0
6703705																						
	112LEON	23	1 / 25/ 1	1946 U							0	278	45	27								
6703706														105								
	112LEON		7 / 14/ 1											195								
	112LEON		8 / 23 / 1								0	274	(0)	209		16						
(202202	112LEON	23	1 / 25/ 1	1946 U							0	274	60	42		16						
6703707	112LEON	22	1 / 24/ 1	046 U							0	272	26	20		20						
6703708	TIZLEON	23	1 / 24/ 1	1940 0							0	212	20	20		20						
0105100	112LEON	16	1 / 24/ 1	1946 U							0	253	35	26								
6703709	IIZEEOI	10	1 / 24/ 5	1940 0							0	200	55	20								
2102107	112LEON	17	1 / 24/ 1	1946 U							0	282	26	38		39						
6703711		17	., 247								0	202	20	50		21						
	112LEON	31	1 / 24/ 1	1946 U							0	316	45	37		26						
6703712																						
	112LEON	22	1 / 24/ 1	1946 U							0	298	45	30								

State Well Number	Aquifer	Depth	Date	B/U	рН	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
6703713																						
	112LEON	17	1 / 24/ 19	946 U							0	303	90	100								
6703715																						
	112LEON	12	3 / 28/ 19	946 U							0	310	34	32		30						
6703717																						
	112LEON	25	7 / 14/ 19	943 U										370								
	112LEON	25	8 / 23 / 19	943 U										390								
	112LEON	25	1 / 25/ 19	946 U							0	251	70	191								
6703718																						
	112LEON	21	1 / 25/ 19	946 U							0	276	32	45								
6703719																						
	112LEON	21	1 / 25/ 19	946 U							0	260	22	30								
6703720																						
	112LEON	25	8 / 23/ 19	943 U										30								
	112LEON	25	1 / 25/ 19	946 U							0	274	28	32		48						
6703721																						
	112LEON		7 / 2 / 19				158	12	c 121		0	299.08	127	215		32	812	1380	443	37	2.5	0
	112LEON		7 / 14/ 19											210								
	112LEON	28	8 / 23/ 19	943 U										197								
	112LEON	28	1 / 25/ 19	946 U							0	320	70	155								
	112LEON	28	6 / 20/ 19	964 B	6.8	21	119	9	c 80		0	314.09	54	112	0.4	45	594	986	334	34	1.9	0
6703722																						
	112LEON	15	1 / 25/ 19	946 U							0	277	40	29								
6703723																						
	112LEON	21	7 / 14/ 19	943 B			252	9	c 112		0	226.07	108	402		55	1049		665	26	1.89	0
	112LEON	21	1 / 25/ 19	946 U							26	306	60	102								
6703801																						
	112LEON		3 / 16/ 19		7.2	17	142	7.05	c 75		0	273.08	49	160	0.4	53	637		383	29	1.67	0
	112LEON	15	3 / 31/ 19	944 B	7.2	20	142	7	c 70		0	292.88	69	128	< 0.4	55	635		383	28	1.56	0
	112LEON	15	4 / 3 / 19	945 B	7.5	21	125	8	c 86		0	298.98	70	91	0.4	106	654		344	35	2.01	0
	112LEON		2 / 8 / 19		7.3	14	126	6.1	54	12	0	322.09	47	82	< 0.4	54	553	941	339	25	1.28	0
	112LEON		8 / 12/ 19		7.2	19	122	14	c 25		0	336.1	47	43	0.2	40	475		362	13	0.57	0
	112LEON	15	5 / 4 / 19	951 B	7.4	21	107	7	c 50		0	336.1	49	43	0.2	23	465		295	26	1.26	0
6703802																						
	112LEON		3 / 16/ 19		7.1	25	420	29	c 304		0	223.07	187	1030	< 0.4	20	2125		1167	36	3.87	0
	112LEON		4 / 2 / 19		7.2	32	343	21	c 276		0	241.07	292	724	< 0.4	27	1833		942	38	3.91	0
	112LEON		4 / 3 / 19		7.2	32	346	25	c 359		0	250.07	370	781	0.5	71	2107		966	44	5.02	0
	112LEON		2 / 8 / 19		7.4	12	246	15	269	15	0	293.08	321	465	0.6	60	1547	2560	675	46	4.5	0
	112LEON		8 / 12/ 19		7.5	25	158	11	c 212		0	342.1	263	224	0.2	38	1099		439	51	4.4	0
	112LEON	25	7 / 16/ 19	951 B	7.5	20	109	7	c 116		0	329.09	141	85	0.3	22	662		300	45	2.91	0
6703803																						
	112LEON	15	11 / 29/ 19	938 B	7.7	27	168	15	c 99		0	290.08	86	211	0.4	89	838		480	30	1.96	0
	112LEON		3 / 16/ 19		7.1	24	286	19	c 167		0	183.05	121	604	0.4	35	1346		791	31	2.58	0
	112LEON	15	3 / 31/ 19	944 B	7.2	30	285	18	c 204		0	250.07	220	540	< 0.4	44	1464		785	36	3.17	0

	State Well Number	Aquifer	Depth	Date	В/Ц	JI	pH	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
1 1		112LEON	15	4 / 3 /	1945 B		7.2	23	207	14	c 199		0	281.08	200	355	0.4	84	1220		574	42	3.61	0
19700 16 17 17 18 17 18 17 18 17 18 17 18 17 18 </td <td></td> <td>112LEON</td> <td>15</td> <td>2 / 8 /</td> <td>1946 B</td> <td></td> <td>7.4</td> <td>15</td> <td>166</td> <td>10</td> <td>147</td> <td>11</td> <td>0</td> <td>308.09</td> <td>174</td> <td>218</td> <td>0</td> <td>60</td> <td>952</td> <td>1600</td> <td>455</td> <td>41</td> <td>3</td> <td>0</td>		112LEON	15	2 / 8 /	1946 B		7.4	15	166	10	147	11	0	308.09	174	218	0	60	952	1600	455	41	3	0
1         1 <th1< th="">         1         1         <th1< th=""></th1<></th1<>		112LEON	15	8 / 12/	1947 B		7.4	21	133	13	c 121		0	329.09	141	142	0.2	40	773		385	40	2.68	0
1 1200         1 <td></td> <td>112LEON</td> <td>15</td> <td>5 / 4 /</td> <td>1951 B</td> <td></td> <td>7.6</td> <td>24</td> <td>104</td> <td>8</td> <td>c 116</td> <td></td> <td>0</td> <td>323.09</td> <td>109</td> <td>103</td> <td>0.5</td> <td>27</td> <td>650</td> <td></td> <td>292</td> <td>46</td> <td>2.95</td> <td>0</td>		112LEON	15	5 / 4 /	1951 B		7.6	24	104	8	c 116		0	323.09	109	103	0.5	27	650		292	46	2.95	0
1         1		112LEON	15	1 / 7 /	1963 B		7.5		114	9	85		0	311.09	72	101	0.3	54	588	1140	321	36	2.06	0
111100         15         1 </td <td></td> <td>112LEON</td> <td>15</td> <td>1 / 12/</td> <td>1965 B</td> <td></td> <td>7.5</td> <td></td> <td>120</td> <td>9</td> <td>89</td> <td></td> <td>0</td> <td>330.71</td> <td>80</td> <td>104</td> <td>0.6</td> <td>48</td> <td>613</td> <td>1145</td> <td>336</td> <td>36</td> <td>2.11</td> <td>0</td>		112LEON	15	1 / 12/	1965 B		7.5		120	9	89		0	330.71	80	104	0.6	48	613	1145	336	36	2.11	0
1         1		112LEON	15	2 / 22/	1966 B		7.6		112	7	77		0	295.32	69	84	0.6	39	533	1020	308	35	1.91	0
1         1		112LEON	15	5 / 12/	1967 B		7.4		115	6	78		0	294.1	66	97	0.6	33	540	1050	311	35	1.92	0
1         1		112LEON	15	2 / 15/	1968 B		7.5		116	9	83		0	322.17	89	98	0.5	32	585	1113	326	35	2	0
112100         15         2         15         15         15         15         15         15         17         10         10 <th1< td=""><td></td><td>112LEON</td><td>15</td><td>2 / 17/</td><td>1969 B</td><td></td><td>7.4</td><td></td><td>114</td><td>10</td><td>66</td><td></td><td>0</td><td>297.76</td><td>66</td><td>84</td><td>0.6</td><td>39.5</td><td>526</td><td>996</td><td>325</td><td>30</td><td>1.59</td><td>0</td></th1<>		112LEON	15	2 / 17/	1969 B		7.4		114	10	66		0	297.76	66	84	0.6	39.5	526	996	325	30	1.59	0
112100       15       1 </td <td></td> <td>112LEON</td> <td>15</td> <td>4 / 13/</td> <td>1970 B</td> <td></td> <td>7.2</td> <td></td> <td>122</td> <td>8</td> <td>71</td> <td></td> <td>0</td> <td>298.98</td> <td>73</td> <td>100</td> <td>0.5</td> <td>31</td> <td>552</td> <td>1057</td> <td>337</td> <td>31</td> <td>1.68</td> <td>0</td>		112LEON	15	4 / 13/	1970 B		7.2		122	8	71		0	298.98	73	100	0.5	31	552	1057	337	31	1.68	0
1       1 <th1< th=""> <th1< th=""> <th1< th=""></th1<></th1<></th1<>		112LEON	15	2 / 15/	1971 B		7.3		131	11	71		0	286.78	65	131	0.4	39	589	1141	372	29	1.6	0
9000000000000000000000000000000000000		112LEON	15	2 / 17/	1972 B		7.4		122	9	78		0	292.08	73	111	0.5	40	577	1120	341	33	1.84	0
111 LON125571087108910 <t< td=""><td></td><td>112LEON</td><td>15</td><td>7 / 19/</td><td>1977 B</td><td></td><td>7.5</td><td>21</td><td>130</td><td>7.9</td><td>54</td><td></td><td>0</td><td>352.68</td><td>48</td><td>79</td><td>0.4</td><td>20.9</td><td>534</td><td>987</td><td>357</td><td>24</td><td>1.24</td><td>0</td></t<>		112LEON	15	7 / 19/	1977 B		7.5	21	130	7.9	54		0	352.68	48	79	0.4	20.9	534	987	357	24	1.24	0
112.60       2 <td>6703804</td> <td></td>	6703804																							
90000       9000		112LEON	25	5 / 4 /	1951 B		7.6	21	88	9	c 106		0	311.19	96	78	0.4	26	577		256	47	2.88	0
112.000121717171810		112LEON	25	2 / 22/	1966 B		7.4		102	11	63		0	285.56	65	66	0.5	42	489	930	299	31	1.58	0
All Ale Normal Series and Seri	6703805																							
A BEAN 2 1 1 2 9 1 9 0 10 1 3 1 2 9 1 9 0 10 1 3 1 4 1 9 1 9 0 10 1 4 1 4 1 9 1 9 0 10 1 9 1 9 1 9 1 9 1 9 1 9 1		112LEON	21	7 / 14/	1943 U											262								
93090       1 <td></td> <td>112LEON</td> <td>21</td> <td>8 / 23/</td> <td>1943 U</td> <td></td> <td>315</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>		112LEON	21	8 / 23/	1943 U											315								
1 1 LEON 1 2 LEON 2 8 / 1 / 1 / 1 / 1 / 3 0 2 8 / 2 / 1 / 3 / 3 0 3 8 / 2 / 1 / 3 / 3 0 3 8 / 2 / 1 / 3 / 3 0 4 8 / 2 / 1 / 3 / 3 0 4 8 / 2 / 1 / 3 / 3 0 5 8 / 2 / 1 / 3 / 3 0 5 8 / 2 / 1 / 3 / 3 0 5 8 / 2 / 1 / 3 / 3 0 5 8 / 2 / 1 / 3 / 3 / 3 0 5 8 / 2 / 1 / 3 / 3 / 3 0 6 8 / 3 / 3 / 3 / 3 / 3 / 3 / 3 / 3 / 3 /		112LEON	21	1 / 29/	1946 U	ſ							0	361	60	162								
11 LEON202	6703806																							
112E0291/29/19400002834343461000006038936100		112LEON	29	7 / 14/	1943 U	r										88								
112607       24       34       24       24       24       24       24       24       24       24       24       24       24       24       24       24       24		112LEON	29	8 / 23/	1943 U	ſ										84								
1 Part 1 and 1		112LEON	29	1 / 29/	1946 U	ſ							0	278	34	43		61						
673939       1       1       2       1       2       1       2       1       2       1       2       1       2       1       2       1       2       1       2       1       2       1       2       1       2       1       2       1       2       1       2       1       2       1       2       1       2       1 <td>6703807</td> <td></td>	6703807																							
112LEON       18       17       29/194       19       10       10       28       93       93       93       105       10		112LEON	24	1 / 24/	1946 U								0	381	90	72								
670380       112LEON       28       1       29       194       0       0       332       105       292       105       105       105         670380       1       12LEON       29       194       0       0       0       332       105       292       105 </td <td>6703808</td> <td></td>	6703808																							
112LEON       28       1       29       14       29       14       29       14       29       14       29       14       29       14       29       14       29       14       29       14       29       24       20       232       20       232       20		112LEON	18	1 / 29/	1946 U								0	268	95	93		165						
6703810         112LEON       30       1/2       2/1       1/2	6703809																							
112LEON       30       1/2       2/4       1/4       0       340       200       327         670381       112LEON       35       1/2       2/5       1/4       0       330       330       40       46		112LEON	28	1 / 29/	1946 U	ſ							0	332	105	292								
670381         112LEON       35       1       25       1946       0       330       40       460	6703810																							
112LEON       35       1       2       1       2       1       1       2       1<		112LEON	30	1 / 24/	1946 U	ſ							0	340	230	327								
670420       124 WLCX       27       8       7       194 0       0       377       46       38       0       56	6703811																							
124WLCX       27       8 / 7 / 194       0       0       317       46       38       0 <td></td> <td>112LEON</td> <td>35</td> <td>1 / 25/</td> <td>1946 U</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>0</td> <td>330</td> <td>40</td> <td>46</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>		112LEON	35	1 / 25/	1946 U								0	330	40	46								
670401       128       1 / 1 / 1 / 1 / 1 / 1 / 1 / 1 / 1 / 1 /	6704202																							
124 WLCX       128       1/2		124WLCX	27	8 / 7 /	1946 U								0	317	46	38		0						
6704501 124WLCX 120 7 / 27 / 1953 U 47 0 159 137 119 0.1 0.2 653 1090 124WLCX 120 2 / 12 / 1962 B 7 49 194 20 c81 0 264.07 332 128 0.2 0 934 1330 566 23 1.48 0 6704502	6704401																							
124WLCX       120       7       27       1953       U       47       0       159       137       119       0.1       0.2       653       1090         124WLCX       120       2       12       196       8       7       49       194       20       c 81       0       264.07       332       128       0.2       0       934       1330       566       23       1.48       0         6704502		124WLCX	128	4 / 12/	1946 U								24	460.07	90	408		2.5						
124WLCX 120 2 / 12/ 1962 B 7 49 194 20 c 81 0 264.07 332 128 0.2 0 934 1330 566 23 1.48 0 6704502	6704501																							
6704502		124WLCX	120	7 / 27/	1953 U	ſ		47					0	159	137	119	0.1	0.2	653	1090				
		124WLCX	120	2 / 12/	1962 B		7	49	194	20	c 81		0	264.07	332	128	0.2	0	934	1330	566	23	1.48	0
124WLCX 110 3 / 14/ 1946 B 7.4 36 132 18 36 17 0 376 72 85 0 0.8 581 961 403 16 0.78 0	6704502																							
		124WLCX	110	3 / 14/	1946 B		7.4	36	132	18	36	17	0	376	72	85	0	0.8	581	961	403	16	0.78	0

State Well Number	Aquifer	Depth	Date	B/U	рН	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
6704503																						
	124WLCX	70	4 / 12/ 1	946 U							0	100	75	374		5.5						
	124WLCX		1 / 13/ 1		7	43	73	13.5	65	5	0	112.27	28	189	0.1	4.5	476	903	237	37	1.83	0
	124WLCX	70	7 / 19/ 1	977 B	7.1	49	83	15.7	73		0	137.9	27	196	0.1	10.9	522	1008	271	36	1.92	0
6704504																						
6704506	124WLCX	150	8 / 7 / 1	946 U							0	339	60	44		0						
6704506	124WLCX	07	8 / 7 / 1	046 11							0	332	45	101								
6704511	124 W LCA	97	0////	940 U							0	332	43	101								
0704511	124WLCX	323	4 / 29/ 1	978 B	7.8		120.1	27.2	108		0	285.56	151.5	181	0.4	0	728	1150	411	36	2.32	0
	124WLCX		10 / 21 / 1		7.19	31	87	22	92	7.3	0	285.56	125	107	0.58	< 0.04	612	963	308	39	2.28	0
6704512																						
	124WLCX	336	6 / 5 / 1	998 B	6.95	42.6	107	20.8	73.8	3.79	0	258.71	113	121	0.11	< 0.22	610	1114	353	31	1.71	0
	124WLCX	336	3 / 25/ 2	2002 B	7.08	38.2	96.6	19	72.8	3.41	0	262.37	102	115	0.25	0.18	577	970	319	33	1.77	0
	124WLCX	336	6 / 14/ 2	2006 B	7.2	33.5	103	20.5	72.4	3.3	0	268.47	108	113	0.3	< 0.44	587	843	342	32	1.7	0
6704601																						
	124WLCX	185	8 / 5 / 1	946 U							0	416	220	372		0						
6704602																						
	124WLCX	174	8 / 5 / 1	946 U							0	622	200	141		0						
6704605		100												100				0.50	224			
6704701	124WLCX	100	6 / 12/1	9/8 B	7.7	46	68	15	90		0	250.17	50	128	0.3	< 0.4	520	959	231	45	2.57	0
6704701	124WLCX	00	A I A I 1	047 D			118	23	c 43		0	236.06	120	116		2	538	909	389	19	0.95	0
6704709	124 W LCA	82	4 / 4 / 1	947 D			118	25	C 45		0	230.00	120	110		2	338	909	369	19	0.93	0
	124WLCX	136	9 / 26/ 1	963 B	7.1		172	45	545	16	0	305.09	725	650			2303	4044	614	65	9.57	0
6704710																						
	124WLCX	445	2 / 4 / 1	952 B	7.38	22	67.2	13.5	c 65.5		0	158.6	108.6	86			440		223	38	1.91	0
6704801																						
	124WLCX	206	8 / 2 / 1	946 U							0	370	26	35								
6704803																						
	124WLCX	494	10 / 11/ 1	995 B	7.9		30	13	109		0	279.46	43	61	0.6	< 0.04	394	748	128	64	4.19	2.01
6704901																						
	124WLCX	327	8/3/1	946 U							0	266	25	152								
6704902											10		100	100								
6704904	124WLCX	216	4 / 17/ 1	946 U							12	568	480	180								
6704904	124WLCX	270	11 / 6 / 1	060 B	7.6	31	92	36	54	4	0	261.15	23	186	0.5	< 0.4	555	1106	377	23	1.21	0
6704905	124 W LCA	270	11 / 0 / 1	)0) <b>D</b>	7.0	51	)2	50	54	4	0	201.15	25	100	0.5	< 0.4	555	1100	511	25	1.21	0
0704905	124WLCX	200	8/3/1	946 U							0	352	20	76								
6704906																						
	124WLCX	295	6 / 24/ 1	964 B	7.3	19	108	88	c 451		0	604.17	244	610	0.1	2	1819	3000	631	60	7.81	0
6705402																						
	124WLCX	200	8 / 5 / 1	946 U							0	517	70	308								
6705701																						

State Well Number	Aquifer	Depth	Date	B/U	рН	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
	124WLCX	165	8 / 3 / 19	946 U							0	662	95	332								
6705702																						
	124WLCX	350	8 / 5 / 19	946 U							0	364	130	205								
6705703																						
(705901	124WLCX	160	6 / 24/ 19	964 B	7	15	178	88	c 474		0	636.18	216	770	0.3	3	2057	3410	806	56	7.26	0
6705801	124CRRZ	27	6 / 24/ 19	964 B	6	95	26	13	c 60		0	32.01	17	96	1.1	83	406	565	118	52	2.4	0
6705802	12401012	27	0 / 24/ 1		0	25	20	15	<b>C</b> 00		0	52.01	17	20	1.1	05	400	505	110	52	2.4	0
	124WLCX	419	6 / 24/ 19	964 B	7.4	38	80	16	c 99		0	236.06	4.8	200	0.2	0.2	554	1010	265	44	2.64	0
6710101																						
	112LEON	26	2 / 0 / 19	943 B	7.6	14	90	23	c 18	3.4	0	325.09	19	21	0.2	57	405	737	319	10	0.44	0
6710103																						
	112LEON	29	6 / 13/ 19	946 U							9.8	245	60	102		60						
6710104	100ALVM	22	2 1 4 1 1	Dec D	0.1	15	06	5.2	12	2	0	251 20	42	0	0.3	44.57	250	(25	260	9	0.22	0
6710201	100AL V M	23	3 / 4 / 19	980 B	8.1	15	96	5.2	12	2	0	251.39	43	9	0.5	44.57	350	625	260	9	0.32	0
0710201	112LEON	25	2 / 14/ 19	946 B	7.2	14	244	28	155	22	0	265.07	183	426	0.6	99	1301	2250	724	31	2.51	0
6710202																						
	112LEON	34	4 / 9 / 19	946 U							0	244	170	450		52						
6710203																						
	100ALVM		6 / 20/ 19		6.8	22	178	19	c 189		0	268.07	273	268	0.7	62	1143	1780	522	44	3.6	0
	100ALVM	30	8 / 18/ 19	977 B	8	25	315	31	250		0	264.82	291	637	0.6	78.8	1758	3562	913	37	3.6	0
6710301	112LEON		3 / 28/ 19	946 U							0	306	240	248		81						
6710501	112LEON		5 / 20/ 1	940 0							0	500	240	248		61						
0710001	100ALVM	35	8 / 9 / 19	946 U							0	268	65	126		108						
6710502																						
	112LEON	21	5 / 9 / 19	946 U							0	420	210	443		168						
6710504																						
	112LEON	24	4 / 8 / 19	946 U							0	296	55	30		38						
6710801	100 41 3/34	24	2 / 12/ 14	) (2 D	67	12	79	16	11	0.7	0	275.09	26	22	0.2	2.0	205	529	260	8	0.2	0
6710802	100ALVM	54	2 / 13/ 19	902 B	6.7	12	78	16	11	0.7	0	275.08	26	22	0.3	3.8	305	538	260	8	0.3	0
0710802	100ALVM	30	4 / 8 / 19	946 U							0	391	24	28		0.5						
6710901											-											
	124WLCX	27	2 / 0 / 19	943 B	8	15	67	19	c 12	3.4	0	257.08	26	20	0.6	10	299		245	9	0.33	0
6710907																						
	124WLCX	18	4 / 3 / 19	946 U							17	275	1460	467								
6710908																						
	124WLCX	30	4 / 3 / 19	946 U							0	638	340	308		231						
6711101	112LEON	20	4 / 19/ 19	046 II							0	308	75	98		86						
6711104	112LEUN	20	4 / 19/ 19	740 U							U	308	15	98		80						
0/11104	112LEON		3 / 29/ 19	946 U							0	300	36	27		19						
											~			••								

State Well Number	Aquifer	Depth	Date	B/U	рН	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
6711105																						
	112LEON		1 / 30/ 19	946 U							0	261	36	36		49						
6711202																						
6711203	112LEON	28	4 / 19/ 19	946 U							0	304	40	72		62						
6/11203	112LEON	74	3 / 20/ 19	946 U							0	346	100	770		260						
6711204	112222011		57 207 1								0	510	100			200						
	112LEON	29	3 / 20/ 19	946 U							0	357	20	157		150						
6711301																						
	124WLCX	324	2 / 14/ 19	952 B	7.35	16	85.8	9.6	c 81.2		0	373.3	27.7	67			470		253	41	2.2	1.05
6711306																						_
6711307	124WLCX	138	3 / 3 / 19	964 B	7.4	33	155	22	c 177		0	486.14	66	265	0.2	24	981	1680	477	44	3.52	0
6/1150/	124WLCX	76	4 / 16/ 19	946 U							0	292	12	80		118						
6711308	1240 ECA	70	4 / 10/ 1	740 0							0	272	12	00		110						
	124WLCX	52	4 / 16/ 19	946 U							0	292	15	20		20						
6711309																						
	124WLCX	100	4 / 2 / 19	964 B	7	20	92	2.6	c 17		0	272.08	15	20	0.3	13	313	532	240	13	0.48	0
	124WLCX	100	7 / 20/ 19	977 B	7.6	9	63	17	151		0	124.48	121	229	0.2	< 0.4	651	1305	226	59	4.36	0
6711310	124WLCX	50	1 / 30/ 19	146 II							0	309	16	36		32						
6711311	124 W LCA	30	1 / 50/ 1	940 U							0	309	10	50		32						
	124WLCX	110	4 / 2 / 19	964 B	7.1	28	168	29	c 165		0	308.09	181	322	0.5	1.2	1046	1780	538	39	3.09	0
6711312																						
	124WLCX	2500	1 / 30/ 19	946 B			66	19	c 279		0	356.1	50	358		1.2	948		242	71	7.79	0.98
6711501																						
6711502	124WLCX	168	3 / 20/ 19	946 U							0	344	140	156		0.5						
0/11302	124WLCX	94	3 / 20/ 19	946 U							0	300	650	430		30						
6711601	121002011		57 207 1								0	500	020	150		50						
	124WLCX	125	5 / 9 / 19	958 B	7.8	32	82	5.8	c 49		0	358.1	15	17	0.4	0	377	611	228	31	1.41	1.3
6711606																						
	124WLCX	97	5 / 3 / 19	946 U							15	222	14	30		85						
6711607		<b>c</b> 0									22	214	22	25		124						
6711608	112LEON	68	5 / 3 / 19	946 U							22	214	22	35		126						
0/11000	112LEON	86	5/3/19	946 U							29	207	16	33		130						
6711618																						
	124WLCX	35	2 / 2 / 19	946 B			364	67	c 172		0	432.12	613	400		1.5	1829		1183	24	2.17	0
6711619																						
(711)(20)	124WLCX	168	5 / 19/ 19	971 B	7.4	32	121	14	29		0	367.32	41	54	0.2	< 0.4	472	852	359	14	0.67	0
6711620	124WLCX		5 / 20/ 19	071 D	7.2	34	284	22	118		0	311.19	49	530	0.4	4.5	1194	2496	799	24	1.82	0
6711623	124 W LCA		5 / 207 1;	,,, 1 D	1.2		204	22	110		0	511.17	7/	550	0.4	4.5	11/4	2470	())	27	1.02	U

State Well Number	Aquifer	Depth	Date	B/U	рН	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
	124WLCX	400	10 / 21/	1992 B	6.72	37	158	17	63	4	0	322.17	66	178	0.19	< 0.04	682	1122	465	22	1.27	0
	124WLCX	400	6/5/	1998 B	6.57	41.8	163	18.5	69	3.44	0	314.85	79	223	0.06	< 0.22	754	1450	484	23	1.37	0
	124WLCX	400	3 / 25/	2002 В	6.68	37.8	164	18.2	71.9	3.41	0	317.29	78.9	223	0.15	0.14	754	1323	485	24	1.42	0
	124WLCX	400	6 / 14/ 2	2006 B	6.78	33.6	186	19.7	74.8	3.3	0	317.28	87	235	0.2	< 0.44	797	1149	547	23	1.39	0
6711701																						
	124WLCX	30	4 / 3 /	1946 U							0	478	300	480		540						
6711702																						
	124WLCX	42	4/3/	1946 U							0	542	55	104		0						
6711703																						
	124WLCX	56	4/3/	1946 U							0	408	44	42		1						
6711704																						
	124WLCX	65	4/3/	1946 U							0	38	850	190								
6711705																						
	124WLCX	130	11 / 14/	1963 B	7.6	28	280	61	c 290		0	360.1	240	730		6.7	1812	3130	949	39	4.09	0
6711801																						
	124WLCX	14	3 / 20/	1946 U							0	106	100	49		110						
6711902																						
	124WLCX	44	5 / 7 /	1946 U							20	262	360	184		8.7						
6711905																						
	124WLCX	203	1 / 8 /	1964 B	7.6	23	54	16	138	3.6	0	370	68	97	0.3	0	581	972	200	59	4.24	2.05
6711912																						
	124WLCX	220	5/4/	1978 B	7.4	51	141	33	136		0	319.73	330	110	0.6	< 0.4	959	1690	487	37	2.68	0
6712101																						
	124WLCX	368 *	2 / 18/	1952 B	7.3	11	98.4	10	c 85.9		0	395.3	31.5	82			513		286	39	2.19	0.75
	124WLCX	240	8 / 11/	1952 B	7.7	38	98	12	61	1.2	0	367.1	28	71	0.2	0	489	878	293	31	1.55	0.14
6712102																						
	124WLCX	140 *	4 / 24/	1952 B	7.8	15	34.4	6.8	c 197		0	339.1	44.3	154			618		113	79	8.19	3.28
	124WLCX	276 *	5 / 22/	1952 B	8.12	21	15.7	5	c 206.4		0	375.11	33.4	116			581		59	88	11.62	4.95
	124WLCX	283	8/6/	1952 B	7.8	22	19	6.6	201	0.4	0	354.1	39	124	1	2	589	1030	74	85	10.02	4.31
6712103																						
	124WLCX	342	2/9/	1952 B	7.25	26.8	88.6	18.4	c 69.7		0	363.6	27.3	86			495		296	33	1.77	0.02
6712104																						
	124WLCX	484	2 / 22/	1952 B	7.9	8	24.6	7.8	c 159.1		0	293.08	81.5	80			505		93	78	7.09	2.93
6712105																						
	124WLCX	364	5 / 17/	1952 B	8	14	13	3.2	c 226.1		0	423	0	136			600		45	91	14.69	6.02
6712106																						
	124WLCX	91	6 / 17/	1946 U							0	57	140	179		34						
6712107															_							
	218EDRD	2539	8 / 23/		7.8	37	87	20	c 104		0	369.11	26	139	0	0.2	594	986	299	43	2.61	0.06
	218EDRD	2539	1 / 30/	1946 U							0	374	26	126								
6712110											-	ac :	0-									
	124WLCX	39	6 / 27/	1946 U							0	294	90	209		1						
6712111																						
	124WLCX	175	1 / 13/	1970 B	8	33	70	17	66	7	0	90.31	133	136	0.2	3	509	952	244	36	1.84	0

State Well Number	Aquifer	Depth	Da	ite	B/U	рН	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
6712112												_											
6712113	124WLCX	300	6/7	7 / 190	64 B	7.6	22	35	12	c 154		0	214.06	168	85	0.3	0	581	921	136	71	5.73	0.77
0/12115	124WLCX	213	6/2	3/ 19	52 B	7.22	51	43.2	6.2	c 40.1		0	124.4	35.2	58			294		133	39	1.51	0
6712114																							
(710115	124WLCX	201	6/2	4/ 19	52 B	7.25	28	74.8	5.5	c 44.3		0	209.8	35.8	68			359		209	31	1.33	0
6712115	124WLCX	552	10 / 2	9/ 19	52 B	8.4	15	9.6	3.5	c 221.3		0	398	26.2	116			587		38	92	15.54	5.76
6712116																							
	124WLCX	240	11 / 1	0/ 190	69 B	6.9	17	50	16	61	5	0	93.97	80	115	0.3	< 0.4	390	750	190	41	1.92	0
6712117	124WLCX	200	5/2	0/ 19	71 B	7.2	34	99	7	42		0	250	36	91	0.7	1	433	798	276	24	1.1	0
6712119	12400 ECX	200	572	07 17	,	7.2	54		,	42		0	250	50	,,,	0.7		455	170	270	24		0
	124WLCX	302	9/1	7/ 19	70 B	7.83	13	9	3	c 228		0	394.17	13	138			597	1040	34	93	16.81	5.76
6712202		150		7/ 10	46 11							0	222	100	150		1.0						
6712203	124WLCX	153	6 / 1	// 194	46 U							0	322	120	158		1.8						
	124WLCX	87	6 / 1	9/194	46 U							0	164	50	206		0						
6712301																							
6712302	124WLCX	300	3 / 1	4/ 194	46 B	7.5	22	96	59	134	16	0	430.12	96	229	0.6	22	886	1580	482	37	2.65	0
0712502	124WLCX	126	7 / 1	6/194	46 U							0	358	60	230		0						
6712303																							
(712205	124WLCX	66	6/2	0/ 194	46 U							22	316	250	550	6.5							
6712305	124WLCX	335	6/2	0/ 194	46 U							24	248	150	375								
6712306																							
	124WLCX	100	8/2	2 / 194	46 U							0	302	40	80		0.5						
6712307	124WLCX	140	8/2	0 / 10	46 U							0	446	45	181		22	467					
6712312	124WLCA	140	0/2	27 19	+0 0							0	440	45	181		22	407					
	124WLCX	520	3 / 2	2/ 19	71 B	8		40	15	105		0	298.98	45	60	0.4	5	417		161	58	3.59	1.67
	124WLCX	520	6/5			7.52	26.4	24.7	9.99	128	3.19	0	319.73	41.1	50.4	0.35	< 0.22	442	896	103	73	5.49	3.19
6712406	124WLCX	520	3/2	57 200	02 B	7.53	25.6	25.6	10.2	112	2.9	0	318.51	35.7	46.7	0.46	0.26	416	698	106	69	4.74	3.1
0/12/00	124WLCX	47	4 / 1	6/ 194	46 U							5.9	318	16	22		45						
6712407																							
6712408	124WLCX	88	5/3	8 / 194	46 U							0	549	65	755		125						
0712408	124WLCX	113	5/3	8 / 194	46 U							0	307	17	25		0.8						
6712412		-			-							-			-								
	124WLCX	300	5 / 1	9/ 19	71 B	7.5	29	66	27	62		0	314.85	58	69	0.3	< 0.4	466	852	275	32	1.62	0
6712413	112LWCX	80	5/1	9/10	71 R	7	42	156	21	47		0	335.6	54	173	0.4	< 0.4	658	1260	475	17	0.94	0
	112L W CA	30	571	<i>)</i> 17	, 1 D	,	72	150	21	77		Ū	555.0	54	175	0.4	< 0. <del>1</del>	050	1200	775	17	0.74	U

State Well Number	Aquifer	Depth	Date	B/U	pH	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
6712414																						
(712415	124WLCX	120	5 / 20/ 19	71 B	7	32	550	28	258		0	453.97	93	920	0.3	315	2419	4805	1487	27	2.91	0
6712415	112LWCX	110	5 / 19/ 19	71 B	7.3	21	93	3.2	15		0	273.36	12	14	< 0.1	17	309	544	245	11	0.42	0
6712416	112E W CA	110	5 / 1)/ 1)	/1 D	1.5	21	)5	5.2	15		0	275.50	12	14	< 0.1	17	507	544	245	11	0.42	0
0/12/10	124WLCX	120	5 / 19/ 19	71 B	7.7	25	49	19	86		0	335.6	24	63	0.1	< 0.4	431	786	200	48	2.64	1.49
6712417																						
	112LWCX	90	5 / 19/ 19	71 B	7.5	23	93	2.67	8.3		0	253.83	14	13	0.2	12	290	508	242	6	0.23	0
6712418																						
	112LWCX	90	5 / 20/ 19	71 B	7.3	31	118	2.4	25.1		0	378.31	9	24	0.2	< 0.4	396	720	304	15	0.63	0.11
6712419	112LWCX	80	5 / 20/ 10	71 D	7.2	22	151	12	64		0	205.00	56	170	0.5	25	627	1242	425	24	1.35	0
6712421	112L WCA	80	5 / 20/ 19	//I D	7.2	22	151	12	64		0	305.09	56	179	0.3	2.5	637	1242	425	24	1.55	0
0712421	124WLCX	99	4 / 12/ 19	81 B	8.2	29	103	4	9		0	303.87	6	14	0.2	22	336	580	273	6	0.24	0
6712423																						
	124WLCX	273	5 / 20/ 19	71 B	7.2	32	106	9.7	37		0	366.1	24	41	0.3	< 0.4	430	750	304	20	0.92	0
6712501																						
	124WLCX		3 / 25/ 19		7.5	45	55	14	c 51		0	241.07	21	60	0.1	0	364	619	194	36	1.59	0.06
	124WLCX		4 / 14/ 19		6.8	43	62	17	57	3.1	0	232	44	85	0.3	0	425	708	224	35	1.65	0
(710500	124WLCX	340	3 / 3 / 19	986 B	8	39	79	20.3	105	4	0	270.92	71	158	0.3	0.04	609	1168	280	44	2.73	0
6712502	124WLCX	320	4 / 28/ 19	53 B	7.97	20	56	9.6	c 60.2		0	212.06	30	74			354		179	42	1.96	0
	124WLCX		5 / 23/ 19		7.4	65	60	14	c 63		0	208.06	44	89	0.4	0.2	437	701	207	39	1.9	0
	124WLCX		5 / 26/ 19		7.2	05	53	15	61		0	203.05	53	70	0.2	< 0.4	352	650	193	40	1.91	0
	124WLCX	320	1 / 7 / 19	63 B	7.2		58	11	55		0	210.06	43	74	0.1	< 0.4	344	702	189	38	1.74	0
	124WLCX	320	4 / 15/ 19	64 B	6.8	48	55	14	56	4.2	0	212	43	75	0.2	0	399	654	194	37	1.75	0
	124WLCX	320	2 / 22/ 19	66 B	7.4		59	12	56		0	207.06	40	78	0.3	< 0.4	347	700	196	38	1.74	0
	124WLCX		5 / 12/ 19		7.2		60	13	59		0	212.06	40	82	0.4	< 0.4	359	720	202	38	1.8	0
	124WLCX		2 / 15/ 19		7.2		58	14	58		0	212.34	40	82	0.4	< 0.4	357	730	202	38	1.77	0
	124WLCX 124WLCX		2 / 17/ 19		7.1		61 59	13 17	56		0 0	211.12	42 53	82	0.3	< 0.4	358	704	205	37 35	1.7	0
	124WLCX 124WLCX		4 / 13/ 19 2 / 12/ 19		7.1 7.1		63	17	56 54		0	209.9 211.12	43	80 85	0.4 0.3	< 0.4 < 0.4	369 362	720 725	216 210	35	1.65 1.62	0
	124WLCX		2 / 16/ 19		7.3		62	14	59		0	209.9	44	86	0.4	< 0.4	369	735	210	37	1.76	0
	124WLCX		2 / 26/ 19		7.1		63	14	58		0	211.12	47	89	0.3	< 0.4	375	750	214	37	1.72	0
	124WLCX	320	7 / 29/ 19	77 B	7.9	50	68	13	62		0	212.34	50	91	0.3	< 0.4	439	770	222	37	1.81	0
	124WLCX	320	3 / 3 / 19	86 B	8	44	92	18	81	4	0	242.85	64	164	< 0.1	0.04	586	1120	303	36	2.02	0
6712503																						
	124WLCX	290	2 / 15/ 19	46 U							0	82	70	104								
6712516		402 *	11 / 10/ 10	50 D	0		50.0	12.0	50.6		0	251.2	20.5	~ 1			225		202	25	1.55	0.0.
	124WLCX 124WLCX		11 / 10/ 19		8	14 36	58.8	13.8	c 50.8		0	251.3	20.6	54 86			335 408		203 223	35	1.55	0.04 0
	124WLCX 124WLCX		11 / 13/ 19 11 / 14/ 19		7.3 7.85	36 12	66 28	14.4 6.3	c 59 c 155		0	246.4 327.09	26 37	86 88			408 487		223 95	36 77	1.72 6.89	0 3.45
6712517	.24 11 LCA	-#02	, 14, 15	D	1.05	12	20	0.5	0 155		Ū	521.07	51	00					ور	, ,	0.07	5.45
	124WLCX	456	4 / 22/ 19	53 B	8.3	8	51	12.8	c 154.6		0	336	31.8	146			569		179	65	5.02	1.91

Image: problem         Image:	State Well Number	Aquifer	Depth	Date	B/U	рН	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
	6712518																						
i         i		124WLCX	50	5 / 17/ 1	946 U							0	312	56	286		0.5						
Normal bit         Normal	6712519																						
i and C.         i and		124WLCX	160	11 / 17/ 1	969 B	7.6	44	80	19	65	4	0	211.12	60	130	0.3	< 0.4	506	930	277	33	1.7	0
Nervice         1 </td <td>6712520</td> <td></td>	6712520																						
oright bit is a serie of the serie of t		124WLCX	368	5 / 11/ 1	967 B	6.98	39	52	9	c 61		0	234.31	34	51			361	578	166	44	2.05	0.5
i widd		124WLCX	368	11 / 12/ 1	969 B	7.3	40	66	13	54	4	0	230.65	40	77	0.4	< 0.4	408	740	217	34	1.59	0
Inverse         a         b </td <td>6712522</td> <td></td>	6712522																						
1 10 10 10 10 10 10 10 10 10 10 10 10 10																							
NuckNuckNNN <td></td> <td>124WLCX</td> <td>403</td> <td>10 / 21 / 1</td> <td>992 B</td> <td>6.98</td> <td>45</td> <td>103</td> <td>24</td> <td>80</td> <td>4.7</td> <td>0</td> <td>247.73</td> <td>69</td> <td>179</td> <td>0.26</td> <td>&lt; 0.04</td> <td>627</td> <td>1038</td> <td>356</td> <td>32</td> <td>1.85</td> <td>0</td>		124WLCX	403	10 / 21 / 1	992 B	6.98	45	103	24	80	4.7	0	247.73	69	179	0.26	< 0.04	627	1038	356	32	1.85	0
12000         1 <th1< th="">         1         1         1</th1<>	6712601											0			10.6								
11211		124WLCX	352	6 / 20/ 1	946 U							0	390	30	106								
othom       othom <th< td=""><td>6712603</td><td>12 AWL OV</td><td>171</td><td>2 / 15/ 1</td><td>046 11</td><td></td><td></td><td></td><td></td><td></td><td></td><td>0</td><td>101</td><td>7</td><td>101</td><td></td><td>0.9</td><td></td><td></td><td></td><td></td><td></td><td></td></th<>	6712603	12 AWL OV	171	2 / 15/ 1	046 11							0	101	7	101		0.9						
Image: Problem in the state of the state	(712(07	124WLCA	1/1	2/ 15/ 1	946 U							0	101	/	101		0.8						
12.112 </td <td>0/1200/</td> <td>124WLCY</td> <td>71</td> <td>6 / 10 / 1</td> <td>046 U</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>0</td> <td>50</td> <td>764</td> <td>229</td> <td></td> <td>15</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>	0/1200/	124WLCY	71	6 / 10 / 1	046 U							0	50	764	229		15						
Inverse <t< td=""><td>6712701</td><td>124WLCA</td><td>/1</td><td>0 / 19/ 1</td><td>940 0</td><td></td><td></td><td></td><td></td><td></td><td></td><td>0</td><td>50</td><td>704</td><td>556</td><td></td><td>1.5</td><td></td><td></td><td></td><td></td><td></td><td></td></t<>	6712701	124WLCA	/1	0 / 19/ 1	940 0							0	50	704	556		1.5						
941203 941203 94120	0/12/01	124WI CX	49	6 / 14 / 1	946 U							0	394	80	224		0						
<pre> 112EPD 1 12 14 14 14 14 14 14 14 14 14 14 14 14 14</pre>	6712703	121012011		0 / 11/ 1	,							0	571	00	221		0						
141200 <p< td=""><td></td><td>112LEON</td><td>19</td><td>6 / 14 / 1</td><td>946 U</td><td></td><td></td><td></td><td></td><td></td><td></td><td>17</td><td>196</td><td>16</td><td>6</td><td></td><td>3.2</td><td></td><td></td><td></td><td></td><td></td><td></td></p<>		112LEON	19	6 / 14 / 1	946 U							17	196	16	6		3.2						
12 WLX       34       5       7       14       14       100       40       57       9.2 <td>6712801</td> <td></td>	6712801																						
124VLCX       3       5       7       7       9       0       9       9       9       9       9         671300       7       5       196       8       7       9       6       12       15       00       12       15       00       12       15       00       12       15       00       12       15       00       15       16       16 <td></td> <td>124WLCX</td> <td>34</td> <td>5 / 17/ 1</td> <td>946 U</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>11</td> <td>100</td> <td>40</td> <td>57</td> <td></td> <td>9.6</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>		124WLCX	34	5 / 17/ 1	946 U							11	100	40	57		9.6						
c71301         124W1CX       60       3 /       5 / 19/4       B       79       4.6       12       1.5       1.02       4.5       0       12.03       78       60       0.2       1.2       3.4       566       3.6       8.6       7.1       1.2         124W1CX       6.0       1.7       2.10       3.4       1.6       1.2       3.4       0       0.2       1.2       0.4       8.9       1.73       8.4       8.7       1.2       1.2       1.4       1.4       1.2       1.4       1.4       1.2       1.4       1.4       1.2       1.4	6712803																						
124WLCX       60       3 / 5 / 194       8       79       4.6       12       1.5       1.02       4.5       0       12.03       78       60       0.2       1.2       3.4       566       36       86       7.18       1.28         124WLCX       620       1.7       1.01       197       8       7.8       1.4       2.7       6       2.2       0       2.01       2.3       1.7       0.2       2.04       872       161       2.2       86       1.2       2.6         124WLCX       60       3 / 5 / 1964       8       7.9       6       2.2       0       2.03       1.7       0.2       2.04       872       161       2.2       86       1.2       2.6         124WLCX       60       3 / 5 / 1964       8       7.9       6       2.2       0       7.0       8.0       8.4       7.9       0       2.00       0.0       7.0       8.0       8.0       1.0       9.0       2.0       1.0       7.0       8.0       8.0       1.0       9.0       2.0       1.0       1.0       1.0       1.0       1.0       1.0       1.0       1.0       1.0       1.0       1.0		124WLCX	31	5 / 17/ 1	946 U							0	170	848	658								
124WLCX       620       1/	6713101																						
124WLCX       620       7       201       197       8       7.8       14       27       6       282       0       203       177       0.2       <0.4		124WLCX	620	3 / 5 / 1	964 B	7.9	4.6	12	1.5	102	4.5	0	122.03	78	60	0.2	1.2	324	566	36	86	7.18	1.28
124VLCX       12		124WLCX	620	11 / 17/ 1	969 B	7.6	12	23	6.6	272	3	0	261.15	220	174	0.4	< 0.4	839	1573	84	87	12.74	2.59
6713102       124WLCX       450       3 / 5 / 1964       B       7.9       17       81       7.9       0       20.90.6       103       106       0.2       0       503       846       236       42       2.29       0         124WLCX       450       11 / 17       197       90       143       5       0       305.9       102       75       0.6       <0		124WLCX	620	7 / 20/ 1	977 B	7.8	14	27	6	282		0	270.92	233	177	0.2	< 0.4	872	1617	92	86	12.79	2.6
124WLCX       450       3 / 5 / 194       8       7.9       17       81       7.9       0       209.06       103       106       0.2       0       503       846       236       42       2.29       0         124WLCX       450       11 / 17/199       8       7.6       15       39       10       133       5       0       305.09       102       75       0.6       <0.4		124WLCX	620	3/3/1	986 B	8.1	13	20.6	5.6	291	3	0	261.15	232	182	0.2	0.13	875	1650	74	89	14.42	2.79
124WLCX       450       11       17       1969       8       7.6       15       39       10       143       5       0       305.09       120       75       0.6       < 0.4	6713102																						
671303         124WLCX       302       2 / 0       0       93       353       120       c 190       0       374.11       802       780       0       1       2641       3850       1828       18       1.93       0         6713201       124CRRZ       18       1       124			450	3 / 5 / 1	964 B		19			81	7.9		209.06	103	106	0.2	0	503	846	236		2.29	
124WLCX       302       2       7       9       730       9       7370       9       1       261       3850       128       18       1.93       0         6713201       124CRRZ       198       1       1       12       197       9       4       0       14.64       7       17       <0.1		124WLCX	450	11 / 17/ 1	969 B	7.6	15	39	10	143	5	0	305.09	102	75	0.6	< 0.4	540	1001	138	69	5.29	2.23
6713001       124CRRZ       198       1       12/tdv 1970       B       6.5       19       4.2       1.7       9       4       0       14.64       7       17       < 0.1	6713103																						
124CRRZ       198       1       12/1 1970       B       6.5       19       4.2       1.7       9       4       0       14.64       7       17       < 0.1		124WLCX	302	2/0/1	964 B	7.4	30	535	120	c 190		0	374.11	802	780	0	1	2641	3850	1828	18	1.93	0
6713303       124RLW       14       14       18/1946       U       0       16       200       154       40         6713502       124CRRZ       240       1       10/1964       U       4       53       5.5       4.4       30       8.4       0       0       80       53       0.2       0.2       234       424       31       67       2.31       0         6713601       124QNCT       65       4       14       30       8.4       0       0       80       53       0.2       0.2       2.34       424       31       67       2.31       0         6713601       124QNCT       65       4       18       64       0       72       90       96       76       1       1       1       67       2.31       0       1 <t< td=""><td>6713201</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></t<>	6713201																						
124RKLW       14       14       18/1946       0       16       200       154       40         6713502       1       10/1964       0       4       53       5.5       4.4       30       8.4       0       0       80       53       0.2       0.2       234       424       31       67       2.31       0         6713601       124QNCT       65       4/18/1946       0       0       72       90       96       76       1		124CRRZ	198	1 / 12/ 1	970 B	6.5	19	4.2	1.7	9	4	0	14.64	7	17	< 0.1	< 0.4	69	96	17	52	0.92	0
6713502 124CRRZ 240 1 / 10/ 1964 U 4 53 5.5 4.4 30 8.4 0 0 80 53 0.2 0.2 234 424 31 67 2.31 0 6713601 124QNCT 65 4 / 18/ 1946 U 0 72 90 96 76 6713602	6713303											0					10						
124CRRZ       240       1       10/1964       U       4       53       5.5       4.4       30       8.4       0       0       80       53       0.2       0.2       234       424       31       67       2.31       0         6713601       124QNCT       65       4       18/1946       U       0       72       90       96       76       57       56       57       56	(712502	124RKLW	14	4 / 18/ 1	946 U							0	16	200	154		40						
6713601 124QNCT 65 4 / 18/ 1946 U 0 72 90 96 76 6713602	6/13502	1240007	240	1 / 10/ 1	064 11		52			20	0.4	0	0		52			224	12.1	21		2.21	0
124QNCT 65 4 / 18 / 1946 U 0 72 90 96 76 6713602	6712601	124CRRZ	240	1 / 10/ 1	964 U	4	53	5.5	4.4	30	8.4	0	0	80	53	0.2	0.2	234	424	31	67	2.31	0
6713602	0/13001	1240NCT	65	1 / 10/ 1	046 U							0	72	00	06		76						
	6712602	124QINCI	05	+ / 10/ 1	740 U							U	12	90	90		/0						
	0/15002	124RKI W	77	3/1/1	946 U	63						0	0	738	300		1						
		124002.0	, ,	2 / 1 / 1		0.5						v	0	750	500								

State Well Number	Aquifer	Depth	Date	B/U	рН	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
6713603																						
	124CRRZ	171	4 / 26/ 1	946 U							0	0	700	1100								
6713605																						
	124CRRZ		2 / 20/ 1		6.8	37	14	1.2	c 55		0	95.03	33	32	0.4	0	219	326	39	74	3.83	0.76
	124CRRZ	470	1 / 12/ 1	970 B	7.8	19	305	58	72	16	0	173.29	620	269	0.5	< 0.4	1445	2704	999	13	0.99	0
6713613		100																1500				0
(210200	124RKLW	100	6 / 20/ 1	964 B	6.1	25	118	57	c 131		0	94.03	99	448	0.2	1.8	926	1730	529	35	2.48	0
6713702	124CRRZ	270	6 / 20/ 1	064 P	6.1	25	6	9.5	c 20		0	65.02	15	20	0	0	127	206	54	44	1.16	0
6713801	124CKKZ	270	0 / 20/ 1	904 D	0.1	25	0	9.5	C 20		0	05.02	15	20	0	0	127	200	54	44	1.10	0
0715001	124CRRZ	250	5 / 17/ 1	946 U							0	0	240	114		0						
6713802											-	-				-						
	124CRRZ	270	2 / 19/ 1	964 B	6.9	37	195	41	c 104		0	225.07	356	230	0.2	0.2	1074	1660	655	25	1.77	0
6713901																						
	124QNCT	16	4 / 26/ 1	946 U							16	206	35	102		110						
6714401																						
	124RKLW	120	1 / 14/ 1	964 B	6.1	76	39	19	c 114		0	48.01	186	135	0.1	0.2	592	912	175	58	3.74	0
6714403																						
	124CRRZ	500	10 / 3 / 1	963 B	4.3		48	9	90		0	0	270	50			467		157	55	3.13	0
	124CRRZ	500	2 / 19/ 1	964 B	7.1	27	0.2	0.1	c 174		0	90.02	240	39	0.2	0	524	808	0	99	79.33	1.46
	124CRRZ	500	5 / 5 / 1	992 U												1.02						
6714406																						
	124CRRZ	550	6 / 20/ 1	964 B	7.3	10	105	26	c 41		0	268.07	199	22	0	0	534	868	368	19	0.93	0
6714701	10101107																					
6714704	124QNCT	97	5 / 2 / 1	946 U							0	65	45	256		3.5						
0/14/04	124QNCT	110	2/6/1	064 B	6.9	49	6	2	c 66		0	70.02	88	12	0.2	0.2	257	338	23	86	5.96	0.68
6714801	124QIVC1	110	27 07 1	704 D	0.9	47	0	2	C 00		0	70.02	00	12	0.2	0.2	237	550	25	80	5.90	0.08
0714001	124QNCT	59	2 / 19/ 1	964 B	6.7	45	74	20	78		0	66.02	6	261	0.3	9.6	526	997	266	38	2.08	0
	124QNCT	59	8 / 12/ 1		6.9	46	52	10	54	4	0	106.17	13	128	0.3	5	364	660	170	40	1.8	0
	124QNCT	59	8 / 17/ 1		7.4	52	47	7	48		0	125.7	23	89	0.4	7.1	335	592	146	41	1.73	0
	124QNCT	59	3 / 3 / 1	986 B	7.7	45	34	7	51	2	0	92.75	26	88	0.4	6.56	305	544	113	49	2.08	0
	124QNCT	59	9 / 22 / 1	993 B	6.4	48	47	8.5	64	2.7	0	115.93	35	107	0.38	10.54	380	583	152	47	4.07	0
6714803																						
	124QNCT	475	10 / 26/ 1	998 B	7.08	26.31	264	62	87.1	22.3	0	179.39	866	104	0.08	< 0.22	1521		915	17	1.25	0
	124QNCT	475	3 / 25/ 2	002 B	6.95	24.3	263	62.8	86.4	22	0	180.61	800	101	< 0.1	0.28	1449	1948	915	17	1.24	0
6719108																						
	124WLCX	99	4 / 3 / 1	946 U							0	308	260	845		1.5						
6719201																						
	124WLCX	182	3 / 20/ 1	946 U							0	226	500	231		0.5						
6719202	10.000 000		0 1 0 1 -	0.4.6							<u>_</u>	2.12	1110			<u>_</u>						
< 71 0 0 0 1	124WLCX	123	8 / 9 / 1	946 U							0	242	1110	468		0						
6719301	124WL CV	270	21011	046 11	6.05		00		170		0	109	120	200			769					
	124WLCX	370	3 / 0 / 1	946 U	6.95		80		170		0	198	120	200			768					

State Well Number	Aquifer	Depth	Date	B/U	pH	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
	124WLCX	370	5 / 17/ 19	946 U							0	198	120	196		2						
6719302																						
	124WLCX	190	8 / 9 / 19	946 U							0	118	13	70		0						
6719304																						
-	124WLCX	406	1 / 8 / 19	964 B	8.1	11	13	8.1	c 846		0	720.2	16	920		1.8	2170	3840	65	96	45.52	10.49
6719306	124001 CV	220	1 / 0 / 1/	064 D	67	12	142	21	02	5.2	0	240	100	212	0.9	0	834	1270	493	29	1.92	0
	124WLCX		1 / 8 / 19		6.7	43	142	31	92	5.3 4	0	240	190	212	0.8	0		1370	482		1.82	0
	124WLCX 124WLCX		1 / 14/ 19		7.6 7.9	35 32	126 87	30 24	106	4	0 0	290.44 318.51	180 194	177	0.6 0.2	< 0.4	801 753	1503	437	34 48	2.2 3.3	0
6719308	124 WLCA	330	8 / 17/ 19	9// D	1.9	32	87	24	135	/	0	516.51	194	117	0.2	< 0.4	133	1395	315	40	5.5	0
0/19508	124WLCX	72	1 / 8 / 19	964 B	6.6	45	75	21	117	4.3	0	190	172	146	0.6	0	674	1080	274	47	3.08	0
6719401	1240 DOM	12	1 / 0 / 1	/04 <b>D</b>	0.0	-10	15	21	117	4.5	0	190	172	140	0.0	0	074	1000	214	47	5.00	0
	100ALVM	27	6 / 25/ 19	946 U							0	538	140	164		24						
6719402	100112.0.00	27	0 / 20/ 1	,							0	220	110	101		2.						
	124WLCX	120	8 / 6 / 19	946 U							0	407	50	83		0						
6719506																						
	124WLCX	36	6 / 25 / 19	946 U							0	360	8	18		9.6						
6719507																						
	124WLCX	315	2 / 12/ 19	946 U							0	366	3	84		0						
6719601																						
	124WLCX	259	10 / 22/ 19	942 B	8.5	16	12	5	409		0	653	163	167	< 0.4	< 0.4	1093		50	94	25.03	9.69
	124WLCX	259	2 / 0 / 19	943 B	8.4	6	2.7	1.7	c 419	5	46	534	178	163	0.2	0	1084		13	98	45.98	10.01
	124WLCX	259	8 / 19/ 19	943 B	8.3	21	29	7	c 385		0	628	180	168	0.5	< 0.4	1099		101	89	16.65	8.27
	124WLCX	259	5 / 8 / 19	945 B	8.4	14	5	1	430		0	609	196	176	0.9	0.9	1123		16	98	45.92	9.65
	124WLCX	259	7 / 23/ 19	947 B	8.5	16	10	4	444		0	732	161	170	0.2	1.3	1166		41	95	30.01	11.17
	124WLCX	259	1 / 25/ 19	951 B	8.6	12	11	6	430		0	652	183	185	0.1	< 0.4	1148		52	94	25.91	9.64
	124WLCX	259	6 / 21/ 19	954 B	8.7	10	2	4	451		0	634	211	185	0.3	0.9	1175		21	97	42.36	9.96
	124WLCX	259	12 / 12/ 19	955 B	8.8	12	2	1	440		0	591	221	178	0.2	< 0.4	1145		9	99	63.43	9.5
	124WLCX	259	6 / 6 / 19	960 B	8.5		3	1	405		0	597	215	183	0.2	< 0.4	1101	1916	11	98	51.73	9.55
	124WLCX	259	6 / 24/ 19	964 B	8.3	14	2	1	433	1.6	14	542	227	175	0.5	0.2	1134	1840	9	99	62.42	9.17
	124WLCX	259	12 / 2 / 19	969 B	8.5	11	1.8	2.06	433	1	10.8	527.19	240	170	0.5	< 0.4	1129	2025	12	98	52.31	8.74
	124WLCX	259	2 / 27/ 19	986 B	8.4	10	79	17	21	2	2.4	252.61	35	46	0.8	5.36	342	675	267	14	0.56	0
6719602																						
	124WLCX	304	10 / 22/ 19	942 B	8.7	17	15	6	405		0	560	223	174	0.6	0.7	1116		62	93	22.35	7.94
	124WLCX		2 / 0 / 19		8.4	8	2	1.4	c 416	5.2	43	457	227	170	0	0	1097		10	98	55.19	8.71
	124WLCX	304	8 / 19/ 19		8.5	23	27	6	c 393		0	569	226	173	0.5	< 0.4	1128		92	90	17.82	7.48
	124WLCX		5 / 8 / 19		8.4	15	7	1	c 404		0	546	218	174	0.8	< 0.4	1088		21	97	37.83	8.52
	124WLCX	304	6 / 23 / 19	947 B	9	19	7	4	c 441		0	629	222	174	0.2	1.3	1177		33	96	32.94	9.63
6719603					<i>.</i> .		-										aor -		2-	0-		
	124WLCX	312	6 / 22 / 19	954 B	8.6	13	7	5	c 813		24	647	91	809	0.3	< 0.4	2080		38	97	57.34	10.64
6719605	10.000	207		0.51 5	6.5		c	,			10		100				1007		20	07	00.05	10.00
	124WLCX		1 / 25/ 19		8.6	11	9	4	c 419		18	677.29	133	160	0.1	< 0.4	1087		38	95	29.22	10.92
	124WLCX	307	6 / 22/ 19		8.7	12	3	4	c 437		24	671.19	158	156	0.3	1.3	1125		23	97	38.85	11.32
	124WLCX	307	12 / 12/ 19	955 B	9	12	12	3	c 450		30	646.78	157	174	0.2	< 0.4	1156		42	95	30.1	10.75

State Well Number	Aquifer	Depth	Date		B/U	рН	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
	124WLCX	307	6/6/	1960	В	8.4		6	2	500		4.8	656.55	170	343	0.2	< 0.4	1349	2575	23	97	45.16	10.46
	124WLCX	307	6 / 20/	1964	В	8.2	14	5.8	3.8	575	2.2	0	686.2	171	385	0.4	0.8	1495	2500	30	97	45.59	10.64
	124WLCX	307	12 / 2 /	1969	В	8.5	12	9	5	610	3	8.4	629.7	195	462	0.5	< 0.4	1614	3042	43	96	40.45	9.74
	124WLCX	307	9 / 12/	1972	В	7.8		11	7	770		0	646.78	225	710	0.5	< 0.4	2041	3875	56	96	44.66	9.48
6719606																							
	124WLCX	447	4 / 16/	1957	В	8.5		2	1	470		14.4	721.22	135	170	0.5	< 0.4	1147		9	99	67.76	12.12
	124WLCX	447	10 / 15/	1962	В	8.2		2	3	518		0	673.63	248	239	0.2	< 0.4	1341	2475	17	98	54.12	10.69
	124WLCX	447	6 / 24/	1964	В	8.3	14	1.5	1.8	505	2.3	37	642	202	220	0.6	2.5	1302	2100	10	98	65.79	11.53
	124WLCX	447	9 / 12/	1972	В	8.6		1	2	482		18	744.41	140	198	0.7	< 0.4	1208	2240	10	98	64.03	12.59
6719607																							
	124WLCX	331	12 / 12/	1955	В	9	15	2	1	c 441		0	731	123	170	0.4	< 0.4	1112		9	99	63.58	11.8
	124WLCX	331	6/7/	1960	В	8.5		2	< 0.5	c 425		0	732	138	200	0.3	< 0.4	1126	1956	7	99	61.27	11.86
	124WLCX	331	6 / 20/	1964	В	8.2	14	1.2	1.7	488	3.4	0	716.21	155	229	0.4	1	1245	2040	9	99	67.17	11.54
	124WLCX	331	12 / 2 /	1969	В	8.6	8	5.4	3.65	630	2	15.6	688.28	145	479	0.6	< 0.4	1628	3068	28	97	51.34	11.23
6719608																							
	124WLCX	519	2/7/	1946	В	8.3	15	2.2	1.3	525	22	51	682	212	222	0.4	1.2	1387	2310	10	99	69.37	12.66
6719609																							
	124WLCX	284	8/6/	1946	U							0	803	3	1410								
6719612																							
	124WLCX	300	2/7/	1946	В	7.4	26	122	6.1	78	9.9	0	427.12	63	68	0	0.5	583	981	329	33	1.87	0.41
6719613																							
	124WLCX	150	2/7/	1946	В	7.7	21	90	23	65	6.5	0	419.12	23	72	0	0.2	506	923	319	30	1.58	0.49
	124WLCX	150	12 / 4 /	1969	В	7.7	18	49	18	115	3	0	394.17	19	77	0.3	< 0.4	493	912	196	56	3.57	2.53
6719614																							
	124WLCX	260	2 / 11/	1949	В	8.05	8	77	26	c 101		0	215.06	76	188			581		298	42	2.54	0
6719615																							
	124WLCX		12 / 9 /			7.3	17	123	39	97		0	231.87	129	252	0.2	< 0.4	771	1551	467	31	1.95	0
	124WLCX	230	12 / 9 /	1969	В	7.4	17	117	41	98	3	0	246.51	122	251	0.2	< 0.4	770	1540	460	31	1.99	0
6719628																							
	124WLCX		* 5 / 8 /			8.58	12	7	3	c 326		13.2	435.66	135	181			891	1560	29	95	25.97	6.98
	124WLCX		* 5 / 9 /			8.77	11	3	1	c 308		21.6	569.9	< 4	127			755	1280	11	98	39.34	9.83
	124WLCX	435	5 / 22/	1968	в	8.37	13	6	3	c 379		0	512	95	235			982	1680	27	96	31.55	7.85
6719629				10.00								<b>a</b> 0.4		105				1000					10.00
	124WLCX		12 / 8 /			8.7	11	3	2	520		20.4	727.33	197	217	0.4	< 0.4	1328	2400	15	98	57.06	12.29
-	124WLCX	525	12 / 8 /	1969	В	8.7	12	3	2	520	1	25.2	727.33	197	214	0.6	< 0.4	1332	2400	15	98	57.06	12.45
6719643	124001 (22	240		1070	D	7.0	12		11	1205		0	710.24	7	1.000	0.4	. 0.4	2270	6904	70	07	66.12	10.10
(710///	124WLCX	340	5/4/	19/8	в	7.9	12	11	11	1296		0	710.24	7	1692	0.4	< 0.4	3379	6804	72	97	66.12	10.19
6719644	12484 08	100	2 / 12/	1072	р	7.4	22	50	27	70	4.1	0	200.09	42	00	0.2	1.0	470	007	255	27	1.07	0
(710//-	124WLCX	180	2 / 12/	1962	в	7.4	33	58	27	72	4.1	0	290.08	42	98	0.3	1.8	478	826	255	37	1.96	0
6719645	124001 (22	140	4 / 22/	1045								20	21.9	55	159		0.0						
6719647	124WLCX	149	4 / 22/	1946	U							20	218	55	158		0.8						
0/19647	124001 022	150	7 / 25	10.45								0	1114	2	100		0						
(700101	124WLCX	150	7 / 26/	1946	U							0	1114	2	498		0						
6720101																							

\* Depth value here reflects the bottom of the SAMPLED INTERVAL which was different from the completed well depth

State Well Number	Aquifer	Depth	Da	ite	B/U	pН	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
	124WLCX	300	5/7	7 / 194	6 U							20	252	120	153		3.5						
	124WLCX	300	3 / 2	7/ 197	9 B	8.1	23	39	13	182		0	268.48	100	164	0.4	< 0.1	653	1240	150	72	6.45	1.38
6720102																							
	124WLCX		2 / 2	2 / 194	6 B			4.6	1.9	c 786		30	1082	2	558		2	1916		19	98	77.84	18.35
6720104																							
	124WLCX	580	3/4	196	4 B	8.6	12	3	1.3	c 756		83	924	0	540		0.2	1849	3140	12	99	96.56	17.65
6720108																							
	124WLCX	263	3 / 2	7/ 197	9 B	8.5	16	16	6	530		12	915.26	2	320	1.3	< 0.1	1353	2560	64	94	28.68	14.11
6720109																							
	124WLCX	185	3 / 2	7/ 197	9 B	8.7	13	4	2	648		30	839.6	95	433	1.6	0.3	1639	3045	18	98	66.06	14.4
6720202																							
	124WLCX	14	7 / 1	6/ 194	6 U							0	62	190	83		76						
6720203																							
	124WLCX	46	7 / 10	6/ 194	6 U							0	410	17	146		9.4						
6720204																							
6720205	124WLCX	360	6 / 1	1/ 195	6 B			24	32	690		0	1020.29	17	599			1863		191	88	21.69	12.89
6720205		100		4 4 10 6	4 D			220	00	107		0	206.00	167	500	0.5	2	1.004	2540	11.00	10	1.62	0
(720.102	124WLCX	190	6 / 24	4/ 196	4 B	6.6	44	320	88	c 127		0	296.08	467	500	0.5	2	1694	2540	1160	19	1.62	0
6720402												10		-	20								
(720.102	124WLCX	24	7 / 10	6/ 194	6 U							12	257	60	39		7.6						
6720403	124WLCX	221	11 / 20	0/ 106	2 D	8	15	1	2.3	c 713		0	1010.29	0	520		1.8	1749	3020	11	99	89.69	16.32
6720408	124WLCA	521	11 / 29	97 190	зь	0	15	1	2.5	C /15		0	1010.29	0	520		1.0	1749	5020	11	99	89.09	10.52
6720408	124WLCX	172	3 / 2	7/ 107	0 B	8.8	13	2.8	1.7	656		37.2	835.94	100	431	1.6	< 0.1	1654	3129	13	99	76.32	14.66
6720501	12+W LCA	172	572	// 1//	<i>у</i> р	0.0	15	2.0	1.7	050		57.2	055.74	100	451	1.0	< 0.1	1054	512)	15	,,,	70.52	14.00
0720501	124WLCX	19	7/3	8 / 194	6 U							0	76	32	78		100						
6720601	124WECK	1)	,, ,	,, 1)+	0 0							0	70	52	70		100						
	124CRRZ	91	4/4	L/ 194	7 B			23	10	c 70		0	20	55	116		16	299	547	98	60	3.07	0
6720602	12 foldu	<i>,</i> ,		., .,.	. 5			20	10	0,0		0	20	55	110		10	200	517	20	00	5107	0
	124CRRZ	80	5/7	7 / 194	6 U							0	0	85	69		0						
6720604																							
	124CRRZ	97	4/4	4 / 194	7 B			32	22	c 118		0	8.01	185	154		15	529	934	170	60	3.93	0
6720703																							
	124WLCX	285	5/7	/ 194	6 U							0	837	1	1210		0						
	124WLCX	285	12 / 6	5 / 196	3 B	7.7	13	14	14	c 1510		0	2080.59	0	1180		0	3754	6130	92	97	68.28	32.25
6720704																							
	124WLCX	19	5/7	7 / 194	6 U							0	145	280	246		3						
6720706																							
	124WLCX	200	1 / 23	3/ 196	4 B	8.1	14	1.8	0.4	c 517		0	876.25	125	198	0.7	0.2	1287	2130	6	99	90.78	14.24
6720707																							
	124WLCX	240	1 / 23	3/ 196	4 B	7.8	13	6	3.2	c 1100		0	1940.55	0.2	590		0.5	2667	4270	28	98	90.21	31.24
6720708																							
	124WLCX	81	5/7	7 / 194	6 U							0	944	55	215		0						
6720801																							

\* Depth value here reflects the bottom of the SAMPLED INTERVAL which was different from the completed well depth

State Well Number	Aquifer	Depth	Date	B/U	pH	Silica	Calcium	Magnesium	Sodium	Potassium	Carbonate	Bicarb.	Sulfate	Chloride	Fluoride	Nitrate	Dissolved Solids	Spec. Cond umhos	Hardness as CaCO3	% Sodium	SAR	RSC
	124CRRZ	120	5 / 3 / 19	946 U							0	29	14	57		0						
6720802																						
	124WLCX	200	1 / 23/ 19	964 B	6.2	30	16	14	c 41		0	80.02	23	68	0.1	0.2	231	399	97	47	1.81	0
	124WLCX	200	7 / 29/ 19	977 B	7.1	66	132	29	52		0	141.56	315	88	0.7	< 0.4	752	1290	448	20	1.07	0
6721104																						
	124CRRZ	300	6 / 20/ 19	964 B	4.3	50	13	5.2	23	9.5	0	0	59	44	0	0	203	303	53	48	1.37	0
	124CRRZ	300	7 / 29/ 19	977 B	6.7	48	35	7	26	10	0	23.19	105	39	0.2	< 0.4	282	438	116	32	1.05	0
6721202																						
	124CRRZ	157	5 / 17/ 19	946 U							0	109	360	165		0						
6721203																						
	124CRRZ	381	5 / 2 / 19	978 B	7.2	41	138	22	74		0	128.14	308	112	0.2	< 0.4	758	1352	435	27	1.54	0
6721302																						
	124CRRZ	334	1 / 10/ 19	964 B	7.6	17	48	30	c 78		0	334.09	18	85	0.3	0	440	771	243	41	2.18	0.61
6721303																						
	124QNCT	148	1 / 10/ 19	964 B	6.4	33	430	148	137	23	0	100.03	1440	365		2	2627	3250	1681	15	1.45	0
6721401																						
	124WLCX	440	12 / 31/ 19	963 B	4.8	47	6.2	2.6	c 27		0	0	32	37	0.1	0.2	152	224	26	69	2.25	0

\* Depth value here reflects the bottom of the SAMPLED INTERVAL which was different from the completed well depth



# Appendix E

Groundwater Conservation Districts Rules

The tables presented in this appendix are taken from the <u>Gonzales County Underground</u> <u>Water Conservation District Management Plan</u> and the <u>Rules of the Gonzales County</u> <u>Underground Water Conservation District</u>. They are presented to provide additional information on the conditions of the aquifers that provide groundwater to Caldwell County. Tables are listed as they are presented.

#### Gonzales County Underground Water Conservation District Management Plan

#### TABLE 5 GROUNDWATER RECHARGE/ DISCHARGE/ FLOW GONZALES AND CALDWELL COUNTIES

Gonza	Groundwater Recharge/Discharge/Flow Gonzales and Caldwell Counties Gonzales County Underground Water Conservation District								
Aquifer or Confining Unit	Annual Recharge from Precipitation (acre-feet/yr)	Annual Discharge from Aquifer to Surface Water (acre-feet/yr)	Annual Flow Into District (acre-feet/yr)	Annual Flow Out of District (acre- feet/yr)					
Sparta	3,105	2,127	386	70					
Weches	808	521	117	35					
Queen City	7,291	3,583	1,172	126					
Reklaw	2,168	1,935	170	156					
Carrizo	6,927	6,896	8,897	5,732					
Wilcox (upper)	0	0	30	48					
Wilcox (middle)	921	31	2,031	3,488					
Wilcox (lower)	0	0	4,052	2,506					

Data from GAM 08-22 Revised

Table 5 describes the following as listed in the GCUWCD:

- 1. Precipitation Recharge this is the aerially distributed recharge sourced from precipitation falling on the outcrop areas of the aquifers (where the aquifer is exposed at the land surface) within the District.
- 2. Surface Water Outflow this is the total water existing the aquifer (outflow) to surface water features such as streams, reservoirs, and drains (springs).
- 3. Flow Into and Out of District this component describes lateral flow within the aquifer between the districts and adjacent counties.

4. Flow Between Aquifers – this describes the vertical flow, or leakage, between aquifers or confining units. Inflow to an aquifer from as overlaying aquifer will always equal the outflow from the other aquifer.

# TABLE 6GROUNDWATER NET FLOW BETWEEN AQUIFERSGONZALES & CALDWELL COUNTIES

Groundwater Net Flow Between Aquifers Gonzales and Caldwell Counties Gonzales County Underground Water Conservation District								
Aquifer or Confining Unit	Annual Net Flow Between Aquifers (acre-feet/yr)							
Weches into Sparta	4,511							
Queen City into Weches	4,183							
Reklaw into Queen City	3,190							
Carrizo into Reklaw	1,945							
Carrizo into Wilcox (upper)	649							
Wilcox (upper) into Wilcox (middle)	194							
Wilcox (lower) into Wilcox (middle)	190							

Data from GAM 08-22 Revised

#### TABLE 7 PROJECTED SURFACE WATER SUPPLY GONZALES COUNTY UNDERGROUND WATER CONSERVATION DISTRICT

			Projected Surf	ace Wa	ater Su	pply				
	Gor	nzales Cour	nty Undergrou	nd Wa	ter Co	nserva	tion Di	strict		
Water User Group	County	River Basin	Source Name	2000 ac- ft/yr	2010 ac- ft/yr	2020 ac- ft/yr	2030 ac- ft/yr	2040 ac- ft/yr	2050 ac- ft/yr	2060 ac- ft/yr
Gonzales	Gonzales	Guadalupe	Guadalupe Run-of-River	1,892	1,892	1,892	1,892	1,892	1,892	1,892
Gonzales CO WSC	Gonzales	Guadalupe	Canyon Lake/ Reservoir	0	532	532	532	532	532	532
Irrigation	Gonzales	Guadalupe	Canyon Lake/ Reservoir	0	6	6	6	6	6	6
Irrigation	Gonzales	Guadalupe	Guadalupe River Combined Run-of-River Irr.	0	1,730	1,730	1,730	1,730	1,730	1,730
Livestock	Gonzales	Lavaca	Livestock Local Supply	46	62	62	62	62	62	62
Livestock	Gonzales	Guadalupe	Livestock Local Supply	5,022	2,366	2,366	2,366	2,366	2,366	2,366
			Total Gonzales	6,960	6,588	6,588	6,588	6,588	6,588	6,588
County Other	Caldwell	Guadalupe	Guadalupe Run-of-River	0	110	110	110	110	110	110
Irrigation	Caldwell	Guadalupe	Guadalupe Run-of-River	0	73	73	73	73	73	73
Livestock	Caldwell	Guadalupe	Livestock Local Supply	31	17	17	17	17	17	17
Livestock	Caldwell	Guadalupe	Livestock Local Supply	153	84	84	84	84	84	84
Gonzales CO WSC	Caldwell	Guadalupe	Canyon Lake/Reservoir	0	5	5	5	5	5	5
			Total Caldwell	184	289	289	289	289	289	289
	Total Pro	jected Surfac	e Water Supply	7,144	6,877	6,877	6,877	6,877	6,877	6,877

Data from the TWDB 207 State Water Plan, Volume 3, Regional Water Planning Group. Apportioned values are presented in italics.

Section 8.1 of the GCUWCD Management Plan indicates that in 2010 water is expected to decrease by 267 acre-feet per year from the 2000 surface water supply estimates (Table 7). The years 2010-2060 are expected to remain stable.

Section 8.2 describes the pumping capacity of a well field and states that the projected groundwater supplies of a water user group may significantly exceed the amount of water actually used by the user because the well fields supplying the user groups have additional or redundant capacity. Overall the district is expected to decrease by 244 acre-feet/ year from 2010 to 2060 (Table 8).

_	Projected Groundwater Supply							
Ga	onzales Co	unty Undergroun	d Wate	r Conse	rvation l	District		
Water User	County	Source Name	2010	2020	2030	2040	2050	2060
Group			ac-	ac-	ac-	ac-	ac-	ac-
			ft/yr	ft/yr	ft/yr	ft/yr	ft/yr	ft/yr
Gonzales	Gonzales	Carrizo-Wilcox	403	403	403	403	403	403
Nixon	Gonzales	Carrizo-Wilcox	600	600	600	600	600	600
Waelder	Gonzales	Queen City	665	665	665	665	665	665
County Other	Gonzales	Carrizo-Wilcox	13	13	13	13	13	13
County Other	Gonzales	Carrizo-Wilcox	559	559	559	559	559	559
Manufacturing	Gonzales	Sparta	1,632	1,632	1,632	1,632	1,632	1,632
Manufacturing	Gonzales	Carrizo-Wilcox	1,786	1,786	1,786	1,786	1,786	1,786
Mining	Gonzales	Carrizo-Wilcox	3	2	2	2	2	2
Mining	Gonzales	Queen City	6	6	6	6	5	5
Mining	Sparta	5	5	5	5	5	5	
Mining	Gonzales	Carrizo-Wilcox	14	14	13	12	12	12
Irrigation	Gonzales	Queen City	47	40	35	30	26	22
Irrigation	Gonzales	Sparta	51	44	38	33	28	24
Irrigation	Gonzales	Carrizo-Wilcox	210	181	156	134	116	100
Livestock	Gonzales	Carrizo-Wilcox	26	26	26	26	26	26
Livestock	Gonzales	Queen City	805	805	805	805	805	805
Livestock	Gonzales	Sparta	329	329	329	329	329	329
Livestock	Gonzales	Carrizo-Wilcox	1,419	1,419	1,419	1,419	1,419	1,419
Gonzales CO WSC	Gonzales	Carrizo-Wilcox	1,103	1,103	1,103	1,103	1,103	1,103
		Total Gonzales	9,676	9,632	9,595	9,562	9,534	9,510
County Other	Caldwell	Carrizo-Wilcox	6	6	6	6	6	6
County Other	Caldwell	Carrizo-Wilcox	19	19	19	19	19	19
County Other	Caldwell	Queen City	121	125	129	132	135	138
Manufacturing	Caldwell	Carrizo-Wilcox	7	7	7	7	7	7
Mining	Caldwell	Carrizo-Wilcox	2	2	2	2	2	2
Mining	Caldwell	Carrizo-Wilcox	1	1	2	2	2	2
Irrigation	Caldwell	Carrizo-Wilcox	4	3	3	2	2	2
Irrigation	Caldwell	Carrizo-Wilcox	138	123	109	97	86	77
Irrigation	Caldwell	Queen City	89	81	74	68	62	56
Livestock	Caldwell	Carrizo-Wilcox	17	17	17	17	17	17
Livestock	Caldwell	Carrizo-Wilcox	84	84	84	84	84	84
Aqua WSC	Caldwell	Carrizo-Wilcox	48	48	48	48	48	48
Gonzales CO WSC	Caldwell	Carrizo-Wilcox	10	10	10	10	10	10
	526	510	494	480	468			
Total	Projected G	Total Caldwell roundwater Supply	546 10,222	10,158	10,105	10,056	10,014	9,978

# TABLE 8PROJECTED GROUNDWATER SUPPLY

**Rules of the Gonzales County Underground Water Conservation District** 

Actual pumping Capacity of Proposed Well (GPM)	Classification	Minimum Distance From Nearest Existing Well or Authorized Well Site					
		Carrizo/Wilcox	Queen City/Sparta				
Less than 17.5 GPM	Domestic	None	None				
17.5-100 GPM	А	600 Feet	2000 Feet				
101-250 GPM	В	1500 Feet	4850 Feet				
251-500 GPM	С	3000 Feet	8400 Feet				
501-1000 GPM	Domestic	6000 Feet	9600 Feet				
1001 GPM and over	Е	12000 Feet	>18,000 Feet				

#### TABLE 1 WELL CLASSIFICATION

E. Production provision:

The maximum permitted production for a tract of land shall not exceed a total of one (1) acre/foot f water per acre of land owner per year form the Carrizo aquifer or combination of the allowable production from the Queen City and Sparta and Carrizo aquifers. Production from the Queen City Aquifer shall be one (1) acre/foot per year and shall be considered part of the one (1) acre/foot total production allowed on any tract of land. Production from the Sparta aquifer shall be one (1) acre/foot per year and shall be considered part of the one (1) acre/foot total production allowed on any tract of land. Production from the Wilcox aquifer shall be one (1) acre/foot per year and shall be considered part of the one (1) acre/foot total production allowed on any tract of land. Production from the Wilcox aquifer shall be one (1) acre/foot per year and may in addition to any other production permitted for any tract of land. Production is allowed to exceed the permitted capacity by 25% in any average monthly reporting period. The actual calendar year production beginning on January 1<sup>st</sup> and ending on December 31<sup>st</sup> may not exceed the permitted pumping capacity for that year. Wells previously permitted to produce at a higher rate shall be reduced to the rate stated in this rule beginning with permits scheduled to be reissued in 2010 and all permits therein after shall be reissued at this rate.

Rule 10 – The Rate of Decline in the confined Portion or Outcrop or any Aquifer

Reductions in the allowable permitted production when levels in artesian wells exceed the levels of drawdown indicated:

# TABLE 2CARRIZO OR WILCOX AVERAGE ARTESIAN DECLINE

Carrizo	or Wilcox Average Artesian Decline
Annual Monthly Average Drawdown	Reduction in current permitted pumpage
80 feet	5% Reduction of current Ac/ft per Acre
85 feet	10% Reduction of current Ac/ft per Acre
90 feet	15% Reduction of current Ac/ft per Acre
95 feet	20% Reduction of current Ac/ft per Acre
100 feet	Reduce original permitted pumpage 10%
105 feet	Reduce original permitted pumpage 20%
110 feet	Reduce original permitted pumpage 30%
>115 feet	The Board shall apply additional 10% reductions to the permitted pumpage in addition to the 30% reduction annually.

# TABLE 3CARRIZO OUTCROP AVERAGE WATER LEVEL DECLINE

Carrizo Outcrop Average Water Level Decline							
Annual Monthly Average Water Level Decline in the Outcrop Area	Reduction in current permitted pumpage						
10% of saturated thickness	Reduce original permitted pumpage 5%						
15% of saturated thickness	Reduce permitted pumpage 10%						
20% of saturated thickness	Reduce permitted pumpage 15%						
25% of saturated thickness	Reduce permitted pumpage 20%						
30% of saturated thickness	Reduce permitted pumpage 25%						
35% of saturated thickness	Reduce permitted pumpage 30%						
40% of saturated thickness	Reduce permitted pumpage 35%						
45% of saturated thickness	Reduce permitted pumpage 40%						
>50% of saturated thickness	The Board shall apply additional 10% reductions to the permitted pumpage in addition to the 40% reduction annually.						

#### AVERAGE QUEEN CITY OR SPARTA AVERAGE ARTESIAN DECLINE

Queen Ci	Queen City or Sparta Average Artesian Decline								
Annual Monthly Average Drawdown	Reduction in current permitted pumpage								
40 feet	10% Reduction of current Ac/ft per Acre								
45 feet	20% Reduction of current Ac/ft per Acre								
50 feet	Reduce original permitted pumpage 10%								
55 feet	Reduce original permitted pumpage 20%								
60 feet	Reduce original permitted pumpage 30%								
>65 feet	The Board shall apply additional 10% reductions to the permitted pumpage in addition to the 30% reduction annually.								

# TABLE 5 QUEEN CITY OR SPARTA OUTCROP AVERAGE WATER LEVEL DECLINE

Queen City or Spart	Queen City or Sparta Outcrop Average Water Level Decline							
Annual Monthly Average Water Level Decline in the Outcrop Area	Reduction in current permitted pumpage							
5% of saturated thickness	Reduce original permitted pumpage 10%							
10% of saturated thickness	Reduce permitted pumpage 20%							
15% of saturated thickness	Reduce permitted pumpage 30%							
20% of saturated thickness	Reduce permitted pumpage 40%							
25% of saturated thickness	Reduce permitted pumpage 50%							
>30% of saturated thickness	The Board shall apply additional 10% reductions to the permitted pumpage in addition to the 50% reduction annually.							



### Appendix F

TWDB Water Use Summary Reports

APPENDIX-F

#### Historical Water Use Summary by County/Basin

Unit: Acre Feet (ACFT)

CALDWELL COUNTY           Year         Basin         Municipal         Manufacturing         Steam Electric         Irrigation         Mining         Livestock           1974         COLORADO         34         0         0         0         166         207           1974         GUADALUPE         3,069         206         0         1,660         70         1,149           1980         COLORADO         69         0         0         0         0         1,600         1,600           1980         GUADALUPE         3,964         219         0         1,600         0         1,036           1984         COLORADO         265         0         0         6         0         138           1984         GUADALUPE         4,827         240         0         688         27         696           1985         COLORADO         162         0         0         4         0         124           1985         GUADALUPE         4,268         224         0         495         27         623           1986         GUADALUPE         4,268         223         0         500         0         817	<b>Total</b> 257 5,897 <b>6,154</b> 241 6,647 <b>6,888</b>
1974       COLORADO       34       0       0       0       16       207         1974       GUADALUPE       3,035       206       0       1,660       54       942         1974       GUADALUPE       3,069       206       0       1,660       70       1,149         1980       GUADALUPE       3,964       219       0       1,600       0       864         4,033       219       0       1,600       0       864         1984       COLORADO       265       0       0       68       27       696         1984       GUADALUPE       4,827       240       0       688       27       696         1985       COLORADO       162       0       0       4       0       124         1985       GUADALUPE       4,268       224       0       495       27       623         1986       GUADALUPE       4,430       224       0       495       27       747         1986       GUADALUPE       4,412       223       0       40       136         1986       GUADALUPE       4,617       0       0       496       28       670	5,897 <b>6,154</b> 241 6,647
1974       GUADALUPE       3,035       206       0       1,660       54       942         3,069       206       0       1,660       70       1,149         1980       GUADALUPE       3,964       219       0       1,600       0       864         1984       GUADALUPE       3,964       219       0       1,600       0       864         1984       GUADALUPE       4,033       219       0       1,600       0       864         1984       GUADALUPE       4,827       240       0       668       27       6866         1984       GUADALUPE       4,827       240       0       494       0       124         1985       GUADALUPE       4,827       240       0       495       27       623         1985       GUADALUPE       4,430       224       0       495       27       747         1986       GUADALUPE       4,430       223       0       490       681         1986       GUADALUPE       4,412       223       0       496       28       670         1987       GUADALUPE       4,617       0       0       496       25<	5,897 <b>6,154</b> 241 6,647
1980       COLORADO       69       0       0       0       172         1980       GUADALUPE       3,964       219       0       1,600       0       864         1984       COLORADO       265       0       0       668       27       666         1984       GUADALUPE       4,827       240       0       668       27       636         1985       COLORADO       162       0       0       4       0       124         1985       GUADALUPE       4,268       224       0       695       27       623         1986       GUADALUPE       4,268       224       0       495       27       747         1986       COLORADO       71       0       0       4       0       136         1986       GUADALUPE       4,412       223       0       496       0       681         1986       GUADALUPE       4,617       0       0       4       0       133         1987       GUADALUPE       4,518       0       0       496       28       670         1988       COLORADO       108       0       0       496       25	241 6,647
1980         GUADALUPE         3,964         219         0         1,600         0         864           4,033         219         0         1,600         0         1,036           1984         COLORADO         265         0         0         688         27         696           1984         GUADALUPE         4,827         240         0         688         27         696           1985         COLORADO         162         0         0         4         0         124           1985         GUADALUPE         4,268         224         0         495         27         623           4,430         224         0         499         27         747           1986         GUADALUPE         4,412         223         0         496         0         681           1986         GUADALUPE         4,412         223         0         496         0         881           1987         COLORADO         71         0         0         4         0         133           1987         GUADALUPE         4,518         0         0         496         28         670           1988 <t< td=""><td>6,647</td></t<>	6,647
1980         GUADALUPE         3,964         219         0         1,600         0         864           4,033         219         0         1,600         0         1,036           1984         COLORADO         265         0         0         688         27         696           1984         GUADALUPE         4,827         240         0         688         27         696           5,092         240         0         694         27         834           1985         COLORADO         162         0         0         4         0         124           1985         GUADALUPE         4,268         224         0         495         27         623           4,430         224         0         499         27         747           1986         GUADALUPE         4,412         223         0         496         0         681           1987         COLORADO         71         0         0         4         0         133           1987         GUADALUPE         4,518         0         0         496         28         670           1988         COLORADO         108 <th< td=""><td>6,647</td></th<>	6,647
1984       COLORADO       265       0       0       6       0       138         1984       GUADALUPE       4,827       240       0       668       27       696         5,092       240       0       668       27       834         1985       COLORADO       162       0       0       4       0       124         1985       GUADALUPE       4,268       224       0       495       27       623         4,430       224       0       495       27       623         6 GUADALUPE       4,268       224       0       499       27       747         1986       COLORADO       71       0       0       4       0       136         1986       GUADALUPE       4,412       223       0       496       0       681         1987       COLORADO       99       0       0       4       0       133         1987       GUADALUPE       4,518       0       0       496       28       670         1988       COLORADO       108       0       0       496       25       701         1988       GUADALUPE	6,888
1984         GUADALUPE         4,827         240         0         688         27         696           5,092         240         0         694         27         834           1985         COLORADO         162         0         0         4         0         124           1985         GUADALUPE         4,268         224         0         495         27         623           4,430         224         0         495         27         747           1986         COLORADO         71         0         0         4         0         136           1986         GUADALUPE         4,412         223         0         496         0         681           1986         GUADALUPE         4,412         223         0         500         0         817           1987         COLORADO         99         0         0         4         0         133           1987         GUADALUPE         4,518         0         0         496         28         670           1988         COLORADO         108         0         0         440         140           1988         GUADALUPE         4,79	
1984         GUADALUPE         4,827         240         0         688         27         696           5,092         240         0         694         27         834           1985         COLORADO         162         0         0         4         0         124           1985         GUADALUPE         4,268         224         0         495         27         623           4,430         224         0         495         27         747           1986         COLORADO         71         0         0         4         0         136           1986         GUADALUPE         4,412         223         0         496         0         681           1986         GUADALUPE         4,412         223         0         500         0         817           1987         COLORADO         99         0         0         4         0         133           1987         GUADALUPE         4,518         0         0         496         28         670           1988         COLORADO         108         0         0         440         140           1988         GUADALUPE         4,79	409
1985       COLORADO       162       0       0       4       0       124         1985       GUADALUPE       4,268       224       0       495       27       623         4,430       224       0       499       27       747         1986       COLORADO       71       0       0       4       0       136         1986       GUADALUPE       4,412       223       0       496       0       681         1986       GUADALUPE       4,412       223       0       496       0       681         1987       COLORADO       99       0       0       4       0       133         1987       GUADALUPE       4,518       0       0       496       28       670         1987       COLORADO       99       0       0       496       28       670         1987       GUADALUPE       4,517       0       0       496       25       701         1988       COLORADO       108       0       0       496       25       701         1988       GUADALUPE       4,629       0       0       11,188       27       690 <td>6,478</td>	6,478
1985       GUADALUPE       4,268       224       0       495       27       623         4,430       224       0       499       27       747         1986       COLORADO       71       0       0       4       0       136         1986       GUADALUPE       4,412       223       0       496       0       681         1986       GUADALUPE       4,483       223       0       500       0       817         1987       COLORADO       99       0       0       4       0       133         1987       GUADALUPE       4,518       0       0       496       28       670         1988       COLORADO       108       0       0       4       0       140         1988       GUADALUPE       4,796       0       0       25       701         4,904       0       0       30       25       841         1988       GUADALUPE       4,629       0       0       137         1989       GUADALUPE       4,629       0       0       1,188       27       690         1990       COLORADO       216       0	6,887
1985       GUADALUPE       4,268       224       0       495       27       623         4,430       224       0       499       27       747         1986       COLORADO       71       0       0       4       0       136         1986       GUADALUPE       4,412       223       0       496       0       681         1986       GUADALUPE       4,483       223       0       500       0       817         1987       COLORADO       99       0       0       4       0       133         1987       GUADALUPE       4,518       0       0       496       28       670         1988       COLORADO       108       0       0       4       0       140         1988       GUADALUPE       4,796       0       0       25       701         4,904       0       0       30       25       841         1988       GUADALUPE       4,629       0       0       137         1989       GUADALUPE       4,629       0       0       1,188       27       690         1990       COLORADO       216       0	290
1986       COLORADO       71       0       0       44       0       136         1986       GUADALUPE       4,412       223       0       496       0       681         4,483       223       0       500       0       817         1987       COLORADO       99       0       0       4       0       133         1987       GUADALUPE       4,518       0       0       496       28       670         1987       GUADALUPE       4,518       0       0       496       28       670         1987       GUADALUPE       4,617       0       0       500       28       803         1988       COLORADO       108       0       0       4       0       140         1988       GUADALUPE       4,796       0       0       496       25       701         1989       COLORADO       226       0       0       1,188       27       690         1989       GUADALUPE       4,629       0       0       1,188       27       690         1990       GUADALUPE       4,629       0       0       1,355       27       681	5,637
1986         GUADALUPE         4,412         223         0         496         0         681           4,483         223         0         500         0         817           1987         COLORADO         99         0         0         4         0         133           1987         GUADALUPE         4,518         0         0         496         28         670           4,617         0         0         500         28         803           1988         COLORADO         108         0         0         44         0         140           1988         GUADALUPE         4,796         0         0         496         25         701           1988         GUADALUPE         4,796         0         0         496         25         701           1989         COLORADO         226         0         0         1,188         27         690           1989         GUADALUPE         4,629         0         0         1,188         27         690           1989         GUADALUPE         4,629         0         0         1,188         27         827           1990         COLOR	5,927
1986         GUADALUPE         4,412         223         0         496         0         681           4,483         223         0         500         0         817           1987         COLORADO         99         0         0         4         0         133           1987         GUADALUPE         4,518         0         0         496         28         670           4,617         0         0         500         28         803           1988         COLORADO         108         0         0         44         0         140           1988         GUADALUPE         4,796         0         0         496         25         701           1988         GUADALUPE         4,796         0         0         496         25         701           1989         COLORADO         226         0         0         1,188         27         690           1989         GUADALUPE         4,629         0         0         1,188         27         690           1989         GUADALUPE         4,629         0         0         1,188         27         827           1990         COLOR	211
1987       COLORADO       99       0       0       4       0       133         1987       GUADALUPE       4,518       0       0       496       28       670         4,617       0       0       500       28       803         1988       COLORADO       108       0       0       4       0       140         1988       GUADALUPE       4,796       0       0       496       25       701         1988       GUADALUPE       4,796       0       0       496       25       701         1988       GUADALUPE       4,904       0       0       496       25       701         1989       COLORADO       226       0       0       10       0       137         1989       GUADALUPE       4,629       0       0       1,188       27       690         4,855       0       0       1,198       27       827         1990       COLORADO       216       0       0       1,355       27       681         1990       GUADALUPE       4,715       0       0       1,375       27       681         1990 <t< td=""><td>5,812</td></t<>	5,812
1987         GUADALUPE         4,518         0         0         496         28         670           4,617         0         0         500         28         803           1988         COLORADO         108         0         0         4         0         140           1988         GUADALUPE         4,796         0         0         496         25         701           4,904         0         0         500         25         841           1989         COLORADO         226         0         0         10         0         137           1989         GUADALUPE         4,629         0         0         1,188         27         690           1989         GUADALUPE         4,629         0         0         1,188         27         690           1989         GUADALUPE         4,629         0         0         1,318         27         827           1990         COLORADO         216         0         0         20         0         135           1990         GUADALUPE         4,715         0         0         1,355         27         681           1990         GUADAL	6,023
1987         GUADALUPE         4,518         0         0         496         28         670           4,617         0         0         500         28         803           1988         COLORADO         108         0         0         4         0         140           1988         GUADALUPE         4,796         0         0         496         25         701           4,904         0         0         500         25         841           1989         COLORADO         226         0         0         10         0         137           1989         GUADALUPE         4,629         0         0         1,188         27         690           1989         GUADALUPE         4,629         0         0         1,188         27         690           1989         GUADALUPE         4,629         0         0         1,318         27         827           1990         COLORADO         216         0         0         20         0         135           1990         GUADALUPE         4,715         0         0         1,355         27         681           1990         GUADAL	236
1988       COLORADO       108       0       0       4       0       140         1988       GUADALUPE       4,796       0       0       496       25       701         1988       GUADALUPE       4,904       0       0       500       25       841         1989       COLORADO       226       0       0       10       0       137         1989       GUADALUPE       4,629       0       0       1,188       27       690         1989       GUADALUPE       4,855       0       0       1,198       27       827         1990       COLORADO       216       0       0       20       0       135         1990       GUADALUPE       4,715       0       0       1,355       27       681         1990       GUADALUPE       4,931       0       0       1,375       27       816	5,712
1988       GUADALUPE       4,796       0       0       496       25       701         4,904       0       0       500       25       841         1989       COLORADO       226       0       0       10       0       137         1989       GUADALUPE       4,629       0       0       1,188       27       690         1989       GUADALUPE       4,629       0       0       1,198       27       827         1990       COLORADO       216       0       0       20       0       135         1990       GUADALUPE       4,715       0       0       1,355       27       681         1990       GUADALUPE       4,931       0       0       1,375       27       816	5,948
1988       GUADALUPE       4,796       0       0       496       25       701         4,904       0       0       500       25       841         1989       COLORADO       226       0       0       10       0       137         1989       GUADALUPE       4,629       0       0       1,188       27       690         1989       GUADALUPE       4,629       0       0       1,198       27       827         1990       COLORADO       216       0       0       20       0       135         1990       GUADALUPE       4,715       0       0       1,355       27       681         1990       GUADALUPE       4,931       0       0       1,375       27       816	252
1989       COLORADO       226       0       0       10       0       137         1989       GUADALUPE       4,629       0       0       1,188       27       690         4,855       0       0       1,198       27       827         1990       COLORADO       216       0       0       20       0       135         1990       GUADALUPE       4,715       0       0       1,355       27       681         4,931       0       0       1,375       27       816	6,018
1989       GUADALUPE       4,629       0       0       1,188       27       690         4,855       0       0       1,198       27       827         1990       COLORADO       216       0       0       20       0       135         1990       GUADALUPE       4,715       0       0       1,355       27       681         4,931       0       0       1,375       27       816	6,270
1989       GUADALUPE       4,629       0       0       1,188       27       690         4,855       0       0       1,198       27       827         1990       COLORADO       216       0       0       20       0       135         1990       GUADALUPE       4,715       0       0       1,355       27       681         4,931       0       0       1,375       27       816	373
1990       COLORADO       216       0       0       20       0       135         1990       GUADALUPE       4,715       0       0       1,355       27       681         4,931       0       0       1,375       27       816	6,534
1990         GUADALUPE         4,715         0         0         1,355         27         681           4,931         0         0         1,375         27         816	6,907
1990         GUADALUPE         4,715         0         0         1,355         27         681           4,931         0         0         1,375         27         816	371
	6,778
	7,149
1991 COLORADO 188 0 0 0 6 140	334
1991 GUADALUPE 4,132 0 0 954 7 696	5,789
4,320 0 0 954 13 836	6,123
1992 COLORADO 192 0 0 22 6 139	359
1992 GUADALUPE 4,264 0 0 1,491 7 696	6,458
4,456 0 0 1,513 13 835	6,817
1993 COLORADO 211 0 0 9 6 129	355
1993 GUADALUPE 4,614 2 0 1,118 6 640	6,380
4,825 2 0 1,127 12 769	6,735
1994 COLORADO 213 0 0 10 6 149	378

CALDWELL COUNTY									
Year	Basin	Municipal	Manufacturing	Steam Electric	Irrigation	Mining	Livestock	Total	
1994	GUADALUPE	4,505	11	0	1,351	6	741	6,614	
		4,718	11	0	1,361	12	890	6,992	
1995	COLORADO	255	0	0	13	6	151	425	
1995	GUADALUPE	4,500	10	0	1,683	6	756	6,955	
		4,755	10	0	1,696	12	907	7,380	
1996	COLORADO	282	0	0	14	6	133	435	
1996	GUADALUPE	4,904	12	0	1,728	6	668	7,318	
		5,186	12	0	1,742	12	801	7,753	
1997	COLORADO	254	0	0	12	6	146	418	
1997	GUADALUPE	4,330	10	0	1,548	6	723	6,617	
		4,584	10	0	1,560	12	869	7,035	
1998	COLORADO	270	0	0	42	6	137	455	
1998	GUADALUPE	4,543	8	0	1,663	6	679	6,899	
		4,813	8	0	1,705	12	816	7,354	
1999	COLORADO	268	0	0	36	6	153	463	
1999	GUADALUPE	4,550	8	0	1,585	6	757	6,906	
		4,818	8	0	1,621	12	910	7,369	
2000	COLORADO	268	0	0	4	6	154	432	
2000	GUADALUPE	4,661	11	0	985	6	763	6,426	
		4,929	11	0	989	12	917	6,858	
2001	COLORADO	31	0	0	7	3	149	190	
2001	GUADALUPE	4,503	200	0	1,583	3	739	7,028	
		4,534	200	0	1,590	6	888	7,218	
2002	COLORADO	30	0	0	7	3	161	201	
2002	GUADALUPE	4,281	6	0	1,583	3	797	6,670	
		4,311	6	0	1,590	6	958	6,871	
2003	COLORADO	34	0	0	4	3	162	203	
2003	GUADALUPE	4,944	0	0	1,061	3	803	6,811	
		4,978	0	0	1,065	6	965	7,014	
2004	COLORADO	34	0	0	5	3	176	218	
2004	GUADALUPE	4,736	1	0	178	3	875	5,793	
		4,770	1	0	183	6	1,051	6,011	

#### Historical Water Use Summary by Groundwater (GW) and Surface Water (SW)

Unit: Acre Feet (ACFT)

	CALDWELL COUNTY											
Year	Source	Municipal	Manufacturing	Steam Electric	Irrigation	Mining	Livestock	Total				
1974	GW	3,069	206	0	97	70	253	3,695				
1974	SW	0	0	0	1,563	0	896	2,459				
	Total	3,069	206	0	1,660	70	1,149	6,154				
1980	GW	2,679	34	0	100	0	169	2,982				
1980	SW	1,354	185	0	1,500	0	867	3,906				
	Total	4,033	219	0	1,600	0	1,036	6,888				
1984	GW	3,662	37	0	205	3	82	3,989				
1984	SW	1,430	203	0	489	24	752	2,898				
	Total	5,092	240	0	694	27	834	6,887				
1985	GW	3,252	38	0	144	27	74	3,535				
1985	SW	1,178	186	0	355	0	673	2,392				
	Total	4,430	224	0	499	27	747	5,927				
1986	GW	3,392	38	0	145	0	81	3,656				
1986	SW	1,091	185	0	355	0	736	2,367				
	Total	4,483	223	0	500	0	817	6,023				
1987	GW	3,298	0	0	145	28	80	3,551				
1987	SW	1,319	0	0	355	0	723	2,397				
	Total	4,617	0	0	500	28	803	5,948				
1988	GW	3,345	0	0	145	25	84	3,599				
1988	SW	1,559	0	0	355	0	757	2,671				
	Total	4,904	0	0	500	25	841	6,270				
1989	GW	3,406	0	0	147	27	82	3,662				
1989	SW	1,449	0	0	1,051	0	745	3,245				
	Total	4,855	0	0	1,198	27	827	6,907				
1990	GW	3,589	0	0	674	27	81	4,371				
1990	SW	1,342	0	0	701	0	735	2,778				
	Total	4,931	0	0	1,375	27	816	7,149				
1991	GW	3,106	0	0	0	13	84	3,203				
1991	SW	1,214	0	0	954	0	752	2,920				
	Total	4,320	0	0	954	13	836	6,123				
1992	GW	3,205	0	0	741	13	84	4,043				
1992	SW	1,251	0	0	741	0	751	2,774				
	Total	4,456	0	0	1,513	13	835	6,817				
1993	GW	3,491	2	0	147	12	77	3,729				
1993	SW	3,491 1,334	0	0	980	0	692	3,729				
1000	Total	4,825	2	0	1,127	12	769	6, <b>735</b>				
1004												
1994	GW	3,441	11	0	147	12	89	3,700				

	CALDWELL COUNTY											
Year	Source	Municipal	Manufacturing	Steam Electric	Irrigation	Mining	Livestock	Tota				
1994	SW	1,277	0	0	1,214	0	801	3,292				
	Total	4,718	11	0	1,361	12	890	6,992				
1995	GW	3,408	10	0	220	12	91	3,741				
1995	SW	1,347	0	0	1,476	0	816	3,639				
	Total	4,755	10	0	1,696	12	907	7,380				
1996	GW	3,970	12	0	227	12	80	4,301				
1996	SW	1,216	0	0	1,515	0	721	3,452				
	Total	5,186	12	0	1,742	12	801	7,753				
1997	GW	3,561	10	0	203	12	87	3,873				
1997	SW	1,023	0	0	1,357	0	782	3,162				
	Total	4,584	10	0	1,560	12	869	7,035				
1998	GW	3,794	8	0	716	12	82	4,612				
1998	SW	1,019	0	0	989	0	734	2,742				
	Total	4,813	8	0	1,705	12	816	7,354				
1999	GW	3,768	8	0	616	12	91	4,495				
1999	SW	1,050	0	0	1,005	0	819	2,874				
	Total	4,818	8	0	1,621	12	910	7,369				
2000	GW	3,743	11	0	137	12	91	3,994				
2000	SW	1,186	0	0	852	0	826	2,864				
	Total	4,929	11	0	989	12	917	6,858				
2001	GW	3,224	200	0	223	6	64	3,717				
2001	SW	1,310	0	0	1,367	0	824	3,501				
	Total	4,534	200	0	1,590	6	888	7,218				
2002	GW	3,065	6	0	223	6	69	3,369				
2002	SW	1,246	0	0	1,367	0	889	3,502				
	Total	4,311	6	0	1,590	6	958	6,871				
2003	GW	3,540	0	0	129	6	69	3,744				
2003	SW	1,438	0	0	936	0	896	3,270				
	Total	4,978	0	0	1,065	6	965	7,014				
2004	GW	3,391	1	0	159	6	75	3,632				
2004	SW	1,379	0	0	24	0	976	2,379				
	Total	4,770	1	0	183	6	1,051	6,011				



# Appendix G

Caldwell County Water Rights and Database Dictionary

Data Dictionary - Water Rights Database							
(last updated: July 14, 2008)							
Field Name Description							
WRNo	Water Right Number; identifier for w	Water Right Number; identifier for water rights.					
WRType	Water Right Type; any of the following 1 = Application/Permit 2 = Claim 3 = Certified Filing 4 = Returned or Withdrawn 5 = Dismissed/Rejected 6 = Certificate of Adjudication 8 = Temporary Permit 9 = Contract/Contractual Person	ion					
WRSeq	Water Right Sequence Number; num	bers the lines of data in each water right.					
AppNo		Indicates the Application number associated with the Permit number (water right number). Use this number to request a Central Records Permit file.					
WRIssueDate	Indicates the date the water right was issued by the TCEQ or predecessors.						
AmendmentLetter	Unique identifier for amendments to	water rights.					
CancelledStatusCode	Indicates water right status; any of th R = Dismissed/Rejected/Co T = Totally Cancelled A = Adjudicated P = Partially Cancelled Blank = Current	-					
Owner Name	Indicates the water right owner name	ð.					
OwnerTypeCode	Indicates type of owner; any of the form 1 = Individual 2 = Organization 3 = Et Ux 4 = Et Al 5 = Estate or Trust 6 = Et Vir	ollowing: 7 = Individual Unverified 8 = Organization Unverified 9 = Estate or Trust Unverified 10 = Archive 11 = Et Ux Unverified 12 = Et Al Unverified					
DivAmountValue	Indicates the amount of water author	ized for diversion per year, in acre-feet.					
WMCode	Indicates the Watermaster Area in wh CR = Concho River ST = South Texas RG = Rio Grande blank = not in a Watermaster Area	hich the water right is located, as follows:					

UseCode	2 = Industrial 3 = Irrigation 4 = Mining	water right; any of the following: 7 = Recreation 8 = Other 9 = Recharge 11 = Domestic & Livestock Only 13 = Storage				
Priority Date	Indicates the original date of the origin water right. In the Rio Grande basin, (Priority Class Code).	nal use of the water allocated under that priority is instead indicated by class				
Priority Month, Priority Day, Priority Year (three fields)	Priority date parsed into three column	s. Use these columns to sort.				
PriorityClassCode	Indicates the priority of the water right highest to lowest priority: M or D (municipal or domest A B	nt in the Rio Grande basin. In order of tic and livestock)				
DateCancelled	Indicates the date the water right was	cancelled, per order of the TCEQ.				
ExpireRemarks	Indicates the date the water right or co	ontract is scheduled to expire.				
Acreage	With use 3 (irrigation) data, indicates the number of acres authorized for irrigation.					
ResName, ResCap (two fields)	Reservoir Name and Reservoir Capac reservoir and the amount of impoundr	ity in Acre-Feet: Indicates the name of the ment authorized by the water right.				
SiteName	Indicates the facility/plant name assoc	ciated with the water right.				
BasinCode	Indicates river basin where the base ri 1 = Canadian 2 = Red 3 = Sulphur 4 = Cypress 5 = Sabine 6 = Neches 7 = Neches-Trinity 8 = Trinity 9 = Trinity-San Jacinto 10 = San Jacinto 11 = San Jacinto-Brazos 12 = Brazos	ight is located; any of the following: 13 = Brazos-Colorado 14 = Colorado 15 = Colorado-Lavaca 16 = Lavaca 17 = Lavaca-Guadalupe 18 = Guadalupe 19 = San Antonio 20 = San Antonio-Nueces 21 = Nueces 22 = Nueces-Rio Grande 23 = Rio Grande				
RiverOrderNo		git number assigned by the Application ocates the diversion point in relation to				

RegionCodeIndicates the Regional Water Planning Group region(s) where the water located, or to which the water right is related.							
	A = Panhandle B = Region B C = Region C D = North East Texas E = Far West Texas F = Region F G = Brazos H = Region H	I = East Texas J = Plateau K = Lower Colorado L = South Central M = Rio Grande N = Coastal Bend O = Llano-Estacado P = Lavaca					
SWRACode	<ul> <li>Indicates the Special Water Resource Area where the water right is located, or to which a water supply contract is related; any of the following:</li> <li>1 = Meredith</li> <li>2 = Alan Henry</li> <li>3 = Chapman (Cooper)</li> <li>4 = Tawakoni</li> <li>5 = Lake Fork</li> <li>6 = Athens</li> <li>7 = Palestine</li> <li>8 = Cherokee</li> <li>9 = Oak Creek</li> <li>10 = Ivie</li> <li>11 = Travis</li> <li>12 = Amistad</li> <li>13 = Medina</li> <li>14 = Canyon</li> </ul>	<ul> <li>15 = Texana</li> <li>16 = Greenbelt</li> <li>17 = Possum Kingdom</li> <li>18 = Granbury</li> <li>19 = Whitney</li> <li>20 = Aquilla</li> <li>21 = Proctor</li> <li>22 = Belton</li> <li>23 = Stillhouse Hollow</li> <li>24 = Georgetown</li> <li>25 = Granger</li> <li>26 = Somerville</li> <li>27 = Limestone</li> </ul>					
UnnamedTrib	When Y (Yes), indicates that the Diversion point is located on an <u>unnamed</u> <u>tributary of 'stream name'</u> , the next field in the database; for example: UnnamedTributary of the Trinity River.When N (No) or blank, indicates that the Diversion point is located directly on'stream name', the next field in the database; for example: Trinity River.						
StreamName	Indicates the stream where the divers	sion point for the water right is located.					
OtherStreamName	Indicates the stream where the addition located.	ional diversion point for the water right is					

C N	1 - Andorson	52 - Cross	102 - Hantlary	$154 - M_0 Cullech$	205 - San Patricia
CountyName	1 = Anderson 2 = Andrews	52 = Crane 53 = Crockett	103 = Hartley 104 = Haskell	154 = McCulloch 155 = McLennan	205 = San Patricio 206 = San Saba
	3 = Angelina	54 = Crosby	104 = Hasken 105 = Hays	156 = McMullen	200 = Subsurf 207 = Schleicher
	4 = Aransas	55 = Culberson	106 = Hemphill	157 = Madison	208 = Scurry
	5 = Archer	56 = Dallam	107 = Henderson	158 = Marion	209 = Shackelford
	6 = Armstrong	57 = Dallas	108 = Hidalgo	159 = Martin	210 = Shelby
	7 = Atascosa	58 = Dawson	109 = Hill	160 = Mason	211 = Sherman
	8 = Austin	59 = Deaf Smith	110 = Hockley	161 = Matagorda	212 = Smith
	9 = Bailey	60 = Delta	111 = Hood	162 = Maverick	213 = Somervell
	10 = Bandera 11 = Bastrop	61 = Denton 62 = De Witt	112 = Hopkins 113 = Houston	163 = Medina 164 = Menard	214 = Starr
	11 = Bastrop 12 = Baylor	63 = Dickens	113 = Houston 114 = Howard	164 = Midland	215 = Stephens 216 = Sterling
	12 = Baylor 13 = Bee	64 = Dimmit	114 = Howard 115 = Hudspeth	166 = Milam	210 = Sterning 217 = Stonewall
	14 = Bell	65 = Donley	116 = Hunt	167 = Mills	218 = Sutton
	15 = Bexar	66 = Duval	117 = Hutchinson	168 = Mitchell	219 = Swisher
	16 = Blanco	67 = Eastland	118 = Irion	169 = Montague	220 = Tarrant
	17 = Borden	68 = Ector	119 = Jack	170 = Montgomery	221 = Taylor
	18 = Bosque	69 = Edwards	120 = Jackson	171 = Moore	222 = Terrell
	19 = Bowie	70 = Ellis	121 = Jasper	172 = Morris	223 = Terry
	20 = Brazoria	71 = El Paso	122 = Jeff Davis	173 = Motley	224 = Throckmorton
	21 = Brazos	72 = Erath	123 = Jefferson	174 = Nacogdoches	225 = Titus
	22 = Brewster 23 = Briscoe	73 = Falls 74 = Fannin	124 = Jim Hogg 125 = Jim Wells	175 = Navarro 176 = Newton	226 = Tom Green 227 = Travis
	23 = Briscoe 24 = Brooks	74 = Pannin75 = Fayette	125 = Johnson 126 = Johnson	170 = Newton 177 = Nolan	228 = Trinity
	25 = Brown	76 = Fisher	120 = Johnson 127 = Johnson	177 = Nueces	229 = Tyler
	26 = Burleson	77 = Floyd	128 = Karnes	179 = Ochiltree	230 = Upshur
	27 = Burnet	78 = Foard	129 = Kaufman	180 = Oldham	231 = Upton
	28 = Caldwell	79 = Fort Bend	130 = Kendall	181 = Orange	232 = Uvalde
	29 = Calhoun	80 = Franklin	131 = Kenedy	182 = Palo Pinto	233 = Val Verde
	30 = Callahan	81 = Freestone	132 = Kent	183 = Panola	234 = Van Zandt
	31 = Cameron	82 = Frio	133 = Kerr	184 = Parker	235 = Victoria
	32 = Camp	83 = Gaines	134 = Kimble	185 = Parmer	236 = Walker
	33 = Carson 34 = Cass	84 = Galveston 85 = Garza	135 = King 136 = Kinney	186 = Pecos 187 = Polk	237 = Waller 238 = Ward
	34 = Cass 35 = Castro	86 = Gillespie	130 = Kliney 137 = Kleberg	187 = 10 k $188 = Potter$	239 = Washington
	36 = Chambers	87 = Glasscock	137 = Knoss 138 = Knoss	189 = Presidio	240 = Webb
	37 = Cherokee	88 = Goliad	139 = Lamar	190 = Rains	241 = Wharton
	38 = Childress	89 = Gonzales	140 = Lamb	191 = Randall	242 = Wheeler
	39 = Clay	90 = Gray	141 = Lampasas	192 = Reagan	243 = Wichita
	40 = Cochran	91 = Grayson	142 = La Salle	193 = Real	244 = Wilbarger
	41 = Coke	92 = Gregg	143 = Lavaca	194 = Red River	245 = Willacy
	42 = Coleman	93 = Grimes	144 = Lee	195 = Reeves	246 = Williamson
	43 = Collin	94 = Guadalupe	145 = Leon	196 = Refugio 197 = Roberts	247 = Wilson 248 = Winkler
	44 = Collingswort 45 = Colorado	96 = Hall	146 = Liberty 147 = Limestone	197 = Roberts 198 = Robertson	248 = Winkler 249 = Wise
	45 = Colorado 46 = Comal	90 = Hamilton	147 = Linestone 148 = Lipscomb	198 = Robertson 199 = Rockwall	249 = Wise 250 = Wood
	47 = Comanche	98 = Hansford	149 = Live Oak	200 = Runnels	251 = Yoakum
	48 = Concho	99 = Hardeman	150 = Llano	201 = Rusk	252 = Young
	49 = Cooke	100 =Hardin	151 = Loving	202 = Sabine	253 = Zapata
	50 = Coryell	101 = Harris	152 = Lubbock	203 = San Augustine	
	51 = Cottle	102 = Harrison	153 = Lynn	204 = San Jacinto	
Remarks	right. Once use	ed for display	ing amendment	• •	r define the water ecial Condition, rvice Site.
BaseWRNo and Type	-				number and type.
• 1		· • •	11	•	• 1
(two fields)			-	-	the Base Water Right
	and Type is 00	1008-6, Color	ado River MW	D.	
	<u> </u>	,			

	APPENDIX G TCEQ SURFACE WATER RIGHTS DATABASE FOR CALDWELL COUNTY									
WR No	WR Type	WR Seq	Owner Name	Owner Type Code	Div Amt Value	Priority Date	Basin Code	Region Code	StreamName	
3906	6	1	TEXAS PARKS & WILDLIFE DEPT	2	12	2/22/1972	18	L	CLEAR FRK PLUM CRK	
3906	6	2	TEXAS PARKS & WILDLIFE DEPT	2	63	11/26/1979	18	L	CLEAR FRK PLUM CRK	
3906	6	3	TEXAS PARKS & WILDLIFE DEPT	2		11/26/1979	18	L	CLEAR FRK PLUM CRK	
3905	6	1	ALLAN C ASHCRAFT ET AL	4		9/28/1964	18	L	DRY CRK	
3904	6	1	SPENCEWOOD INC	2	28	12/31/1951	18	L	ELM CRK	
4213	1	1	BEN B TWIDWELL ET UX	3	120	11/20/1984	18	L	PLUM CRK	
3719	1	1	MIGUEL CALZADA URQUIZA ET UX	3	45	7/30/1979	18	L	SALT CRK	
3719	1	2	SCHMIDT RANCH LLC	2	623	7/30/1979	18	L	SALT CRK	
3594	1	1	ROBERT M KIEHN	1	144	1/30/1978	18	L	SAN MARCOS RIVER	
3724	1	1	ROBERT GLASS LANGFORD	1	149	1/28/1980	18	L	SAN MARCOS RIVER	
3742	1	1	GEORGE PARTNERSHIP LTD	2	300	3/17/1980	18	L	SAN MARCOS RIVER	
3787	1	1	BEN O CORPORATION	2	104	10/6/1980	18	L	SAN MARCOS RIVER	
3812	1	1	VNS & CLS PARTNERS LTD	2	240	3/30/1981	18	L	SAN MARCOS RIVER	
4057	1	1	CHRISTOPHER G SEEKER ET UX	2	300	6/13/1983	18	L	SAN MARCOS RIVER	
4242	1	1	ROBERT L BOOTHE	1	240	5/29/1985	18	L	SAN MARCOS RIVER	
4253	1	1	HYDRACO POWER INC	2	15,000	9/25/1984	18	L	SAN MARCOS RIVER	
4287	1	1	JOHN T O'BANION JR ET AL	4	320	7/30/1985	18	L	SAN MARCOS RIVER	
5092	1	1	CITY OF SAN MARCOS	2	150	9/2/1986	18	L	SAN MARCOS RIVER	
5234	1	1	GUADALUPE-BLANCO RIVER AUTHORITY	2	1,022	5/12/1989	18	L	SAN MARCOS RIVER	
5857	1	1	GENE MILLIGAN	1	1	10/18/2004	18	L	SAN MARCOS RIVER	
3724	1	2	GAYLE LANGFORD TURNER	1	106	1/28/1980	18	L	SAN MARCOS RIVER	
3787	1	2	BEN O CORPORATION	2	250	9/6/1985	18	L	SAN MARCOS RIVER	
4057	1	2	CHRISTOPHER G SEEKER ET UX	2	300	3/4/1986	18	L	SAN MARCOS RIVER	
4242	1	2	DON B MORGAN ET UX	3		5/29/1985	18	L	SAN MARCOS RIVER	
5234	1	2	GUADALUPE-BLANCO RIVER AUTHORITY	2		8/6/2003	18	L	SAN MARCOS RIVER	
5857	1	2	GENE MILLIGAN	1		10/18/2004	18	L	SAN MARCOS RIVER	
3724	1	3	JEARL LEDBETTER ET UX	3	194	1/28/1980	18	L	SAN MARCOS RIVER	
3787	1	3	MICHAEL W OHLENDORF ET UX	3	21	10/6/1980	18	L	SAN MARCOS RIVER	
5234	1	3	GUADALUPE-BLANCO RIVER AUTHORITY	2		8/6/2003	18	L	SAN MARCOS RIVER	
3724	1	4	JEROME V MILLER ET UX	3	1	1/28/1980	18	L	SAN MARCOS RIVER	

	APPENDIX G TCEQ SURFACE WATER RIGHTS DATABASE FOR CALDWELL COUNTY										
WR No	WR Type	WR Seq	Owner Name	Owner Type Code	Div Amt Value	Priority Date	Basin Code	Region Code	StreamName		
3787	1	4	MICHAEL W OHLENDORF ET UX	3	50	9/6/1985	18	L	SAN MARCOS RIVER		
3889	6	1	CANYON REGIONAL WATER AUTHORITY	2	24	6/23/1914	18	L	SAN MARCOS RIVER		
3890	6	1	GEORGE PARTNERSHIP LTD	2	50	8/9/1971	18	L	SAN MARCOS RIVER		
3891	6	1	TRI-COMMUNITY WSC	2	500	12/29/1922	18	L	SAN MARCOS RIVER		
3895	6	1	EBL INC DEF BEN PENSION PLAN & TRUST	5	580	3/21/1977	18	L	SAN MARCOS RIVER		
3896	6	1	GUADALUPE-BLANCO RIVER AUTHORITY	2	1,500	10/12/1976	18	L	SAN MARCOS RIVER		
3897	6	1	LULING ECONOMIC DEVELOPMENT CORP	4		6/22/1914	18	L	SAN MARCOS RIVER		
3898	6	1	CITY OF LULING	2	20	8/16/1976	18	L	SAN MARCOS RIVER		
3899	6	1	SCHMIDT RANCH LLC	2	1,180	3/21/1977	18	L	SAN MARCOS RIVER		
3900	6	1	DAVID NEAL PAPE ET AL	4		2/12/1973	18	L	SAN MARCOS RIVER		
3895	6	2	EBL INC DEF BEN PENSION PLAN & TRUST	5		3/21/1977	18	L	SAN MARCOS RIVER		
3896	6	2	GUADALUPE-BLANCO RIVER AUTHORITY	2		1/7/1980	18	L	SAN MARCOS RIVER		
3900	6	2	ESTATE OF JAMES D JAMISON	5	750	2/12/1973	18	L	SAN MARCOS RIVER		
3895	6	3	EBL INC DEF BEN PENSION PLAN & TRUST	5		3/21/1977	18	L	SAN MARCOS RIVER		
3896	6	3	GUADALUPE-BLANCO RIVER AUTHORITY	2	1,300	1/31/1983	18	L	SAN MARCOS RIVER		



### Appendix H

Water Conservation Measures

#### WATER CONSERVATION MEASURES

#### Introduction

Water conservation will provide benefits not only to customers in cost but to society by preserving the environment and our resources by reducing demands on water and wastewater systems. The objective of the Caldwell County Conservation Plan will be to provide on brief overview of current measures undertaken by water utilities and to promote and implement water conservation.

Water conservation has been identified by Region L as a measure to meet future water demands. As growth occurs and new developments flourish, it will be helpful to consider having a list of action items to be implemented to accommodate the increase in customers without a substantial increase in water demands.

#### Water Supply System Conservation Measures

The water supply systems that currently serve Caldwell County responded in a survey as having implemented the following measures to encourage water conservation:

- Increasing water rates
- Prohibit landscaping between the hours of 10 am to 8 pm
- Biannual newsletters with conservation tips
- Increasing rate blocks
- Install accurate metering devices
- Universal metering
- Meter testing and replacement programs
- Record management system
- Water audits
- Public Education
- Non-promotional water rates
- Leak detection and replacement

- Annual presentations
- Conservation water rate
- Strict Plumbing code enforcement
- Mail updates and conservation mail from groundwater districts

Measures under consideration by water supply systems to encourage water conservation:

- Education
- Reducing per capita consumption by 3%
- Joined SWAP
- Replace meters on schedule to reduce water loss
- Leak monitoring program to identify and repair leaks
- Encourage xeriscaping
- Implement year round water restriction
- Mail out information on a percent basis

As conservation measures are implemented, communicating the benefits of the strategy is one of the best ways to encourage other water suppliers to do likewise. Not only will Conservation Programs slow groundwater drawdown but also reduce cost of water treatment plants by eliminating or delaying expansion resulting in considerable financial savings.

#### **Record Management System**

Maintaining accurate and updated records of water distribution and sales are essential record keeping tools needed for operation and management of a profitable water business. Establishing a central system which is able to segregate water sales and water uses for various user classes can provide data quickly and efficiently for review of systems. User classes can include; single-family, multifamily, commercial, industrial, schools, and irrigation.

#### Water Rate Structure

An increasing water rate structure can motivate customers to reduce water use and practice conservation measures. Establishing an average monthly consumption rate for all classes of users and gradually increasing charge will encourage limits on watering and use. Peak seasonal rates and City Limit boundary considerations should also be included in the rate structure.

#### Water Audits

Although it is impractical to attain 0% loss in water systems, it can be substantially minimized with monthly, quarterly, semi-annual, or annual audits. Audits require accountability and responsibility for substantial loss is a system. Improvements are required and goals should be established to decrease the losses in a system and kept to a minimum. Larger cities than those in Caldwell have recorded water loss under 10%. Long-term planning at the city level should develop goals of minimum and maximum water loss with action plans ready to be implemented in the event goals are not met.

HB 3338 Water Auditing Reporting Information was enacted in the 78<sup>th</sup> Legislature in 2003. The bill requires "each retail public utility that provides potable water to conduct a water loss audit once every five years and to report the results of the audit to the Texas Water Development Board (TWDB). The water audit addresses four main points of water loss: loss from distribution lines; inaccuracies in meters; deficiencies in accounting practices; and, theft of service." Submission of the 2006 deadline for the report has resulted in a response rate under 50%.

#### Metering

Metering all the customer base is the only tool available that can account for water use. Proper calibration and routine testing can increase accuracy of measurements. It would be

beneficial to test every meter before installation and develop a frequent routine to test installed meters. Proper metering for use is important to reduce cost and errors in billings.

#### Reuse

Reuse/ reclaimed waste water can be utilized for non-potable water uses. Several customers from residential to commercial can utilize the water. Reuse can be considered for the following:

- Schools
- Athletic fields
- Manufacturing businesses
- Gold courses
- Parks
- Apartment/ various housing complexes

Components of the water system to consider would include transmission mains, storage tanks, and pump stations. These systems need to be reviewed further to consider a benefit and cost

#### **Plumbing Fixtures**

Rebate Programs and Replacement Programs for single family homes to include toilets, sinks, and shower heads. Eligible fixtures should demonstrate a 20% or more efficiency in water use. Water efficient clothes washers can also be included in the program.



#### Leak Detection and Repair

Sound detection of leaks is the most common practice to locate faulty joints and broken sections of pipe. Once located, a log should be maintained for repair and a database established and utilized.

#### Water Efficient Landscaping

As water resources become scarce and rates continue increase other viable solutions for customers include rain water harvesting. The TWDB has published a series of technical guides on rainwater harvesting to promote use. Participation in workshops, seminars, and conference can further the education of local customers.



- Soil Composition
- Depth of soil
- Depth of mulch

#### **Rainwater Harvesting Systems**



Rainwater harvesting has gained popularity as different sizes and shapes of tanks are emerging. Below ground rainwater tanks and smaller cisterns are available to offset municipal water use. The water from the cisterns can be for potable and non-potable use.

The TWDB presented a report to the Legislature

in 2006 to on recommendations for minimum water quality standards for indoor potable and non-potable use, treatment methods, conjunctive use with municipal water systems,

and ways in which the state can further promote rainwater harvesting. Additional information can be obtained at http://www.twdb.state.tx.us/iwt/rainwater.asp.

#### Agricultural Irrigation

Irrigation of agriculture is one the greatest water consumers and currently accounts for a significant amount of the water use in Texas. Surface, sprinkler and drip irrigation art the basic types of irrigation. Drip irrigation has been found to be the most efficient for certain crops.

Establishing schedules based on the crop's needs and monitoring soil moisture and weather help determine the amount of water to apply. Proper grading of the land for use and irrigation practice can be a natural way to reduce water use. Additional conservation methods include:

- Furrow Dinking
- Conservation Tillage
- Tail water Reuse
- Surge Flow
- Low Elevation Spray Application Systems (LESA)
- Canal and Conveyance System Management

#### **Public Education**

There are several modes of informing and educating the public that can be utilized. Water conservation education can be transmitted through the following:

- Public Service Announcements
- Workshops and Seminars
- Pamphlets
- Outreach programs
- Schools
- Awards and Recognition
- Creative Competitions (Drawing, Photo, and Essay)



# <u>Appendix I</u>

### Plum Creek Watershed Protection Plan Best Management

Practices

**APPENDIX-I** 

#### APPENDIX I

#### **BEST MANAGEMENT PRACTICES**

Best Management Practices listed in the Plum Creek Watershed Protection Plan to be implemented.

#### **Urban Stormwater Measures**

#### **Common Goals**

- Implement non-structural components of MS4 permits on a voluntary basis in advance of program requirements
- Conduct stormwater engineering analyses and city-wide assessments to determine placement of structural management measures in individual cities
- Pet waste management, including passage or modification of ordinances and installation and management of pet waste stations

#### Lockhart

- Enact a pet waste ordinance
- Install 10 pet waste stations and signage
- Nutrient/irrigation water management in park areas
- Manage/periodically relocate duck population at City Park
- Continue/expand existing street sweeping program

#### Luling

- Reconstruct Cottonwood Creek stormwater retention pond
- Enact a pet waste ordinance
- Install 6 pet waste stations and signage
- Continue/expand existing street sweeping program

#### Wastewater Management Measures

#### Wastewater Treatment Facilities

- Promote signing of the East Hays County Wastewater Compact, a key interlocal agreement between multiple entities in the region.
- All WWTFs agree to work toward treatment levels of 5-5-2-1 (BOD/TSS/NH<sub>3</sub>/TP) by way of permits for new facilities and voluntary action by existing plants.
- All WWTFs will begin monthly self-monitoring of effluent for bacteria and nutrients.
- All WWTF operators will demonstrate the appropriate licenses and certifications and be current on continuing education opportunities.

#### APPENDIX I

• The cities of Kyle, Lockhart, and Luling will evaluate costs and feasibility in an effort to implement phosphorous removal techniques for all effluent entering Plum Creek.

#### Wastewater Infrastructure

- Cities will continue or initiate daily inspections of lift stations and equip all stations with dialers and/or Supervisory Control and Data Acquisition (SCADA) systems.
- Cities will continue to apply for grants to replace old clay pipe sewer lines, and clean and maintain existing sewer lines.
- Cities will work to locate any septic systems that may still be within the city limits and connect those residences to central wastewater treatment.

#### **Cropland Operations Management Measures**

To focus management plan development and implementation, management measures, addressing bacteria and nutrient issues will be encouraged and given top priority. Based on site-specific characteristics, plans should include one or more of the following management practices to reduce pollutant loads from agricultural lands:

- Prescribed Grazing: Manages the controlled harvest of vegetation with grazing animals to improve or maintain the desired species composition and vigor of plant communities, which improves surface and subsurface water quality and quantity.
- Riparian Herbaceous Buffers: Establishes an area of grasses, glasslike plants, and forbs along water courses to improve and protect water quality by reducing sediment and other pollutants in runoff as well as nutrients and chemicals in shallow groundwater.
- Grasses Waterways: Natural or constructed channel-shaped or graded and established with suitable vegetation to protect and improve water quality.
- Riparian Forest Buffers: Establishes area dominated by trees and shrubs located adjacent to and up-gradient from watercourses to reduce excess amounts of sediment, organic material, nutrients, and pesticides in surface runoff and excess nutrients and other chemicals in shallow groundwater flow.
- Watering Facilities: Places a device (tank, trough, or other watertight container) that provides animal access to water and protects streams, ponds, and water supplies from contamination through alternative access to water.
- Field Borders: Establishes a strip of permanent vegetation at the edge or around the perimeter of a field to protect soil and water quality.

#### APPENDIX I

- Filter Strips: Establishes a strip or area of herbaceous vegetation between agricultural lands and environmentally sensitive areas to reduce pollutant loading in runoff.
- Nutrient Management: Manages the amount, source, placement, form, and timing of the application of plant nutrients and soil amendments to minimize agricultural nonpoint source pollution of surface and groundwater resources.
- Conservation Cover: Establishes permanent vegetative cover to protect soil and water.
- Stream Crossings: Creates a stabilized area or structure constructed across a stream to provide a travel way for people, livestock, equipment, or vehicles, improving water quality by reducing sediment, nutrient, organic, and inorganic loading of the stream.
- Alternative Shade: Although not currently an approved cost-share practice, creation of shade reduces time spent loafing in streams and riparian areas, thus reducing pollutant loading. Efforts will be made to include this practice as a component of livestock management plans.



## Appendix J

### Plum Creek Watershed Protection Plan Management

Measures and Outreach Activities

Klotz Associates Project No. 0972.000.000 January 2010

#### Management Measures as described in the Plum Creek Watershed Protection Plan

	Responsible		Numbe	er Imple			
Management Measure	Party	Unit Cost		Year		Total Cost	
			1-3	4-6	7-10		
Urban Stormwater Man	agement Measu	ires	r				
Pet Waste Collection Stations	City of Lockhart	\$620/station installation \$85 annual/station	10	4	4	\$22,040	
Pet Waste Collection Stations	City of Luling	\$620/station installation \$85 annual/station	6	2	2	\$12,475	
Comprehensive Urban Stormwater Assessment	City of Lockhart	\$25,000/survey	1			\$25,000	
Manage Urban Waterfowl Populations	City of Lockhart					N/A	
Comprehensive Urban Stormwater Assessment	City of Luling	\$20,000/survey	1			\$20,000	
Rehabilitate Stormwater Retention Pond	City of Luling	\$500,000/pond	1			\$500,000	
Wastewater Management	Measures						
Wastewater Upgrade (TSS Reduction)	WWTF Operators	\$500,000/ 1 MGD facility		3	7	\$6,000	
Wastewater Upgrade (Phosphorous Removal)	WWTF Operators	\$60,000/facility (includes material costs)		3	7	\$600,000	
Voluntary Monthly E. coli Monitoring	WWTF Operators	\$22/monthly/facility				\$31,000	
Voluntary Monthly Phosphorous Monitoring	WWTF Operators	\$25/monthly/facility				\$35,000	
Wastewater Management	Measures (contin	nued)					
Sanitary Sewer Pipe Replacement	City of Lockhart	\$320,000/year	1,800 ft	1,800 ft	2,400 ft	\$3,200,00 <sup>3</sup>	
Initiate Sanitary Sewer Inspection Program	City of Luling	\$17,000/camera	1			\$17,000 <sup>2</sup>	
Sanitary Sewer Pipe Replacement	City of Luling	\$100,000/year	2,400 ft	2,400 ft	3,200 ft	\$10,000,000 <sup>3</sup>	
Lift Station SCADA Installation	City of Luling	\$12,000/station	4	1		\$60,000	

# Management Measures as described in the Plum Creek Watershed Protection Plan

	Responsible	onsible		er Imple		
Management Measure	Party	Unit Cost		Year 1-3 4-6 7-10		Total Cost
			1-3			
Septic System Inspection/ Enforcement (New Position)	Caldwell County	\$50,000/year		2		\$1,000,000
Septic System Repair	Caldwell/ Hays Cos.	\$5,000/system	300	300	400	\$5,000,000
Septic System Replacement	Caldwell/ Hays Cos.	\$10,000/system	150	150	200	\$5,000,000
Septic System Connection to Sewer	City of Uhland	\$2,000/system	100	100	150	\$700,000
Agricultural Management	Measures					
WQMP Technician (New Position)	SWCD	\$75,000/year	1		\$750,000	
Livestock Water Quality Management Plans	SWCD	\$10,000/plan	65	70	100	\$2,350,000
Cropland Water Quality Management Plans	SWCD	\$10,000/plan	6	9	9	\$240,000
Non-Domestic Animal and	l Wildlife Manage	ement Measures	•			
Feral Hog Control (New Position)	TWDMS	\$90,000/year		1		\$900,000
Feral Hog Control (Equipment)	TWDMS					\$5,000
Monitoring Component						
Targeted Water Quality Monitoring	GBRA		1			\$142,000 <sup>4</sup>
Comprehensive Stream Assessment	GBRA	\$1,500/assessment	12	12	16	\$60,000
Bacterial Source Tracking	TAMU		1			\$200,000

# Outreach Activities as described in the Plum Creek Watershed Protection Plan

Outreach Activity	<b>Responsible Party</b>		Year		Total Cost	
· ·	• •	1-3	4-6	7-10		
<b>Broad-Based Programs</b>						
Texas Watershed Steward Training Sessions	Extension	3	2	1	N/A	
Elementary School Water Quality Project	GBRA				\$25,000	
Plum Creek Watershed Protection Brochure	GBRA				\$15,000 <sup>1</sup>	
Tributary and Watershed Roadway Signage	PCW Partnership	60			\$6,000	
Displays at Local Events	Extension/TSSWCB	9	9	9	\$5,400	
Watershed Billboards PCW Partnership		1 si	gn bienni	ially	\$30,000	
Urban Programs		1	1	•		
Pet Waste Programs	Cities/TCEQ/ Extension				\$35,000	
NEMO Workshops		2				
Fats, Oils, and Grease Workshop	GBRA/TCEQ/ Extension	2			$$20,000^{1}$	
Municipal Site Assessment Visits		4				
Urban Sector Nutrient Education	Extension	3	3	3	N/A	
Sports and Athletic Field Education (SAFE)	Extension	3	3	3	N/A	
Wastewater Programs						
Develop Septic System Online Training Modules	GBRA	4			\$30,000 <sup>1</sup>	
Septic System Workshops and Assistance	Extension/ GBRA	4	3	3	\$25,000 <sup>1</sup>	
Agricultural Programs						
Soil and Water Testing Campaigns	Extension	3	3	3	N/A	
Agricultural Nutrient Management Education	Extension	3	3	3	N/A	
Crop Management Seminars	Extension	3	3	3	N/A	
Agricultural Waste Pesticide Collection Days	TCEQ	1	1	1	\$75,000	

# Outreach Activities as described in the Plum Creek Watershed Protection Plan

Outreach Activity	Responsible Party		Year	<b>Total Cost</b>	
		1-3	4-6	7-10	
Agricultural Programs (continued)					
Livestock Grazing Management Education	Extension	3	3	3	N/A
Non-Domestic Animal and Wildlife Programs					
Feral Hog Management Workshop	Extension	2	1	2	N/A
Stream and Rparian Workshops	Extension	2	1	2	N/A
Additional Programs					
Illegal Dumping Site Targeted Cleanup	GBRA	3	3	3	\$40,000 <sup>1</sup>
Community Stream Cleanup Events	ODKA	2	3	3	φ <del>4</del> 0,000
Rainwater Harvesting Education/Demonstration	Extension	2	1	2	\$25,000



# Appendix K

**Regional Compact** 

APPENDIX-K

# APPENDIX K

Whereas the parties to this compact, the cities of Lockhart, Luling, Martindale, Niederwald, Uhland and the Guadalupe-Blanco River Authority (GBRA) all function in Caldwell County and

Whereas all parties share the responsibility to:

- 1. To promote the development, use, and conservation of the water resources in the county
- 2. To plan for the welfare of all local governments and make it possible for all communities to utilize public works services
- 3. To promote and implement feasible conservation measures established
- 4. To balance development in the region and promote sustainable designs
- 5. To develop water quality management measures that will ensure the future use and quality of groundwater and surface water
- 6. To minimizing reliance on On-Site Sewage Facilities (OSSFs)
- 7. To develop inter local agreements and cooperation for the purpose of developing water and wastewater facilities to serve the future population of Caldwell

and whereas all parties recognize that much of the future water and wastewater infrastructure in Caldwell will have to be provided initially by the private sector in new developments, and whereas all parties understand that the common interests will be served by adopting a uniform approach, the parties jointly enter into this compact. The key elements to the compact are:

- 1. The parties recognize that protection of the water resources in Caldwell will require a regional cooperative effort. The overutilization of natural resources is not a sustainable practice and conservation and reuse measures practices will be implemented.
- 2. The parties agree jointly to participate, to the extent desired, in the review of new proposed projects and plans, and in special studies involving rates or other issues. Development of a Good Neighbor Policy to share ideas and plan conservation of resources on a regional basis will provide benefits to the region as a whole.
- 3. The parties will develop and agree on specific conditions that will determine the number of housing units needed for a central wastewater system, but as an initial target agree that OSSFs would not be appropriate for developments of 10 or more homes.
- 4. The parties believe that domestic wastewater treatment is an important public service, with the potential to affect citizens outside of the immediate project area. The parties also recognize that proper operation and maintenance of wastewater infrastructure is essential to the public welfare. Because it is important to the public, the parties agree that central wastewater facility operations should be a public function, and that future wastewater facilities in Caldwell County should

# APPENDIX K

be operated by a public rather than a private entity. The parties recognize that the private sector must be involved in the design, permitting and construction of wastewater facilities to serve new developments, but the parties anticipate that these new developments will at some future time become a part of a municipality. As such, the parties agree that central wastewater facilities associated with new developments should be jointly permitted (e.g. private developer and public entity) and operated by the public entity.

- 5. An important aspect of wastewater operations is the quality of the water produced. The parties agree that a high quality effluent that is discharged to surface waters is important and will encourage the level represented by the Texas Commission on Environmental Quality's (TCEQ) 5-5-2-1 effluent set will be the goal for all new facilities. That is operating at full flow with a monthly average effluent quality of BOD5 OF 5MG/l, tss OF 5 MG/l, AMMONIA-Nitrogen of 2 mg/L and total Phosphorus of 1 mg/L. The parties recognize that this goal can be met in several ways including direct treatment, treating to a different level, and meeting the goal by use of an offsetting amount of effluent for irrigation, or through wetland polishing.
- 6. The parties recognize that Caldwell County has limited water resources supplies and that providing good quality water to serve future growth will be a challenge. To conserve water supplies to the extent practical, the parties jointly desire new developments to include provisions to minimize potable water use in irrigation. This can include a purple pipe system for irrigation and/or cisterns for providing water for toilet flushing and lawn irrigation.
- 7. All parties agree to participate in supporting the core provisions of the Compact. For examples, this could include opposing a private permit applicant in the TCEQ hearing process that refused to follow the central treatment, effluent quality, or reuse provisions of the Compact.



# Appendix L

# Public Meeting Comments on Report and Responses to

Comments

APPENDIX-L

	klotz	klotz 📢 associates 7550 IH-10 West
SIGN-IN SHEET		Northwest Center, Suite 300 San Antonio, Texas 78229 T 210.736.0425 F 210.736.0405 sanantonio.office@klotz.com
Project Name: Caldwell County Regional Water and Wastewater Planning Study	Water and Wastewater Planning Study	
Job No.: 0972.001.000		
Date: August 3, 2009 Meeting Type: Stakcholder Group Meeting #3	3 #3	
Name	Organization/Title	Phone/Fax/Cell
DAVID MENU 11em	Waxwell WSE	holh 252 215
Doug Spillmenn	Maxwell WSC	512 227 2241
MARK SPEED	CRYSTAL CLEAR IN SC	830 372 1031
Town Coundit	AECOM	612.457-7766
ALA	UAN/HURVA	512-396-4040
Rarry Miller	Gowardes Co WSC	830-672-6579
Daniel Meyer	PCCD	512-398-2383
Daniel R. Haideman	couty kine SUD	512-738-2073
OSCAR H. FRALE	GRRA	512-376-9950
MICION CIURY	CNOR	830-379-5872
Contraction of the second	Lookhab	
	Gity of Lockhart	1-512-376-8149
	Plum Creek Cons. Dist.	572-398-2-383

k l o t z () a s s o c i a t e s 7550 IH-10 West Northwest Center, Suite 300 San Antonio, Texas 78229 T 210.736.0425 F 210.736.0405 sanantonio.office@klotz.com		Phone/Fax/Cell (e30)3795823(w) (830)373-575(fax) 379-5823 ext 313 512 776 75570	
erional Water and Wastewater Dlanning Study	Meeting #3	Guadalupe-Blanco River Multronty 	
SIGN-IN SHEET	Job No.: 0972.001.000 Date: August 3, 2009 Meeting Type: Stakeholder Group Meeting #3	Name Debbie Magin Gi Lie Sedleeek MAT NEESon	

klotz 🕻 associates

7550 IH-10 West San Antonio, Texas 78229 210.736.0425

# COMMENTS PUBLIC MEETING CALDWELL COUNTY WATER AND WASTEWATER PLANNING STUDY AUGUST 3, 2009

In the space below please provide input or comments regarding the recommendations in the report.

SUDE STATED 8,845 AFAR MANARLEN GROUNDWATER MITHIN THE COUNTY IN ZOYO, YET VERSALLY STATES Z3,000 AFTAR IS AVALAGUE. WHAT WAS THE SAVECES OF THE DATA (PINM CREW CONSERVATION DISMUT ? OTHER?) ? HOW ARE THESE THO NUMBERS JUSTIFIED?

SUGGEST IN THE REPORT THAT THE SAME CHANGES ASSOCIATED WITH THE HAYS CALONON PUA PROJECT ARE CHANENGES FOR AN OF THE GROUND WATER PROJECTS DISCUSSED.

M MOORE
96-4040
X Yes 🗆 No

klotz 📢 associates

7550 IH-10 West San Antonio, Texas 78229 210.736.0425

# COMMENTS PUBLIC MEETING CALDWELL COUNTY WATER AND WASTEWATER PLANNING STUDY AUGUST 3, 2009

In the space below please provide input or comments regarding the recommendations in the report.

I think the report in	a right sutanot. De	thich
The mid bain projec	as right on larget. De	ale
for now.	0	
Name: Johnie Halliburt	DN	
Phone: 512-398-2383		
Can we contact you?  Yes	🗆 No	

# **RESPONSE TO WRITTEN COMMENT BY GRAHAM MOORE**

We agree that the groundwater portions of the GBRA Mid-Basin Project will face the same challenges as the HCPUA Project and have modified the report to reflect that information.

# **RESPONSE TO WRITTEN COMMENT BY JOHNIE HALLIBURTON**

The report recommends the GBRA Mid-Basin Project as one of the strategies to be pursued. No changes were made to the report.



# Appendix M

# Water Treatment Facilities Cost Estimate

Wastewater Treatment Facilities Cost Estimates

APPENDIX-M

### Caldwell County Regional Water and Wastewater Planning Study **Regional Water Planning** Water Transmission Line Options Prepared June 2009

### **PROJECT COST SUMMARY WITH 12" DISTRIBUTION SYSTEM**

ITEM NO.	ITEM DESCRIPTION	AMOUNT
1	Line 1A - Groundwater Source Route to Lockhart	\$33,800,000
2	Line 1B - Groundwater Source Route to Luling	\$30,200,000
3	Line 1C - Surface Water Source Route to Luling	\$51,300,000
4	Line 2 - SH 130 North Route	\$10,221,128
5	Line 3 - Northwest Route to Uhland	\$6,282,922
6	Line 4 - SH 130 West	\$8,608,917

### Level of Cost Projection:

 $\square$ No Design Completed

Preliminary Design

Final Design

The engineer has no control over the cost of labor, materials, or equipment, or over the Contractor's methods of determining prices, or over competitive bidding or market conditions. As a result, this opinion of probable construction cost is based on the

#### Caldwell County Regional Water and Wastewater Planning Study Regional Water Planning Water Transmission Line Options Prepared June 2009

#### Transmission Line 1A

ITEM NO.	ITEM DESCRIPTION	UNIT	QTY	UNIT PRICE	AMOUNT		
1	MOBILIZATION (10%)	LS	1	\$2,152,524.28	\$2,152,524		
2	SITE PREPARATION (7%)	LS	1	\$1,506,767.00	\$1,506,767		
3	SEDIMENTATION AND EROSION CONTROL (5%)	LS	1	\$1,076,262.14	\$1,076,262		
4	TRAFFIC MAINTENANCE (1.0%)	LS	1	\$215,252.43	\$215,252		
5	REPLACING ASPHALT PAVEMENT	SY	93	\$90.00	\$8,400		
6	DRIVEWAY REPLACEMENT (AVG)	SY	1,667	\$60.00	\$100,000		
7	REMOVE AND REPLACE FENCING (5%)	LF	5,500	\$50.00	\$275,000		
8	FILTER FABRIC	LF	109,869	\$1.20	\$131,843		
9	INSTALLATION OF CATHODIC TEST STATIONS	LS	1	\$10,000.00	\$10,000		
		-	ESTIMAT	ED SUB TOTAL	\$5,500,000		

#### WELL DEVELOPMENT

ITEM NO.	ITEM DESCRIPTION	UNIT	QTY	UNIT PRICE	AMOUNT
1	PUMPS (1,000 GPM) & INSTALLATION	EA	6	\$15,000.00	\$90,000
2	FIELD WELL DEVELOPMENT	LS	1	\$5,000,000.00	\$5,000,000
3	LAND PURCHASE COST	LS	1	\$75,000.00	\$75,000
			ESTIMAT	ED SUB TOTAL	\$5,200,000

#### WATER FACILITIES

ITEM NO.	ITEM DESCRIPTION	UNIT	QTY	UNIT PRICE	AMOUNT
1	STORAGE TANK	GAL	1,000,000	\$0.50	\$500,000
2	WATER TREATMENT PLANT	GPD	8,000,000	\$0.50	\$4,000,000
					\$0
			ESTIMATE	ED SUB TOTAL	\$4,500,000

30-INC	H TRANSMISSION MAIN COST				
ITEM				UNIT	
NO.	ITEM DESCRIPTION	UNIT	QTY	PRICE	AMOUNT
1	MOBILIZATION	LS	1	\$84,000.00	\$84,000
2	30-INCH D.I. WATER MAIN (OPEN CUT)	LF	109,701	\$95.00	\$10,421,595
3	30-INCH D.I. WATER MAIN (BORE)	LF	168	\$150.00	\$25,200
4	4 INCH COMBINATION AIR VALVE WITH MANHOLE	EA	10	\$12,000.00	\$120,000
5	30-INCH BUTTERFLY VALVE WITH MANHOLE	EA	10	\$13,000.00	\$130,000
6	FILTER FABRIC	LF	109,869	\$1.00	\$109,869
7	CATHODE ROTECTION	LS	1	\$250,000.00	\$250,000
8	DISINFECT WATER TRANSMISSION MAIN	LF	109,869	\$0.50	\$54,935
9	INSTALLATION CATHODIC TEST STATIONS	LS	1	\$15,000.00	\$15,000
10	TRENCH SAFETY	LF	109,701	\$1.25	\$137,126
			ESTIMAT	ED SUB TOTAL	\$11.300.000

MISC					
ITEM				UNIT	
NO.	ITEM DESCRIPTION	UNIT	QTY.	PRICE	AMOUNT
1	SURVEY (1.0 %)	LS	1	\$265,000.00	\$265,000
2	ENGINEERING (10%)	LS	1	\$2,650,000.00	\$2,650,000
			ESTIMAT	ED SUB TOTAL	\$2,915,000
	Level of Cost Projection:	ΤΟΤΑΙ		JCTION COST =	\$26,500,000.00

#### Level of Cost Projection:

- No Design Completed Preliminary Design
- Final Design

TOTAL= 15% CONTINGENCY= \$4,400,000 GRAND TOTAL = \$33,800,000

\$2,900,000

\$29,400,000

TOTAL ENGINEERING COST =

The engineer has no control over the cost of labor, materials, or equipment, or over the Contractor's methods of determining prices, or over competitive bidding or market conditions. As a result, this opinion of probable construction cost is based on the engineer's experience and qualifications and represents our best judgment as design professionals familiar with the construction industry. The engineer cannot and does not guarantee the proposals, bids, or the construction cost will not vary from this opinion of probable cost.

#### Caldwell County Regional Water and Wastewater Planning Study Regional Water Planning Water Transmission Line Options Prepared June 2009

#### Transmission Line 1B

GENER								
ITEM				UNIT				
NO.	ITEM DESCRIPTION	UNIT	QTY	PRICE	AMOUNT			
1	MOBILIZATION (10%)	LS	1	\$1,923,971.00	\$1,923,971			
2	SITE PREPARATION (7%)	LS	1	\$1,346,779.70	\$1,346,780			
3	SEDIMENTATION AND EROSION CONTROL (5%)	LS	1	\$961,985.50	\$961,986			
4	TRAFFIC MAINTENANCE (1.0%)	LS	1	\$192,397.10	\$192,397			
5	REPLACING ASPHALT PAVEMENT	SY	31	\$90.00	\$2,800			
6	DRIVEWAY REPLACEMENT (AVG)	SY	250	\$60.00	\$15,000			
7	REMOVE AND REPLACE FENCING (5%)	LF	5,500	\$50.00	\$275,000			
8	INSTALLATION OF CATHODIC TEST STATIONS	LS	1	\$10,000.00	\$10,000			
	ESTIMATED SUB TOTAL							

#### WELL DEVELOPMENT

CENERAL DEVELOPMENT

ITEM				UNIT	
NO.	ITEM DESCRIPTION	UNIT	QTY	PRICE	AMOUNT
1	PUMPS (1,000 GPM) & INSTALLATION	EA	6	\$15,000.00	\$90,000
2	FIELD WELL DEVELOPMENT	LS	1	\$5,000,000.00	\$5,000,000
3	LAND PURCHASE COST	LS	1	\$45,000.00	\$45,000
			ESTIMATE	D SUB TOTAL	\$5,135,000

#### WATER FACILITIES

10

ITEM NO.	ITEM DESCRIPTION	UNIT	QTY	UNIT PRICE	AMOUNT
1	STORAGE TANK	GAL	1,000,000	\$0.50	\$500,000
2	WATER TREATMENT PLANT	GPD	8,000,000	\$0.50	\$4,000,000
					\$0
			ESTIMATE	D SUB TOTAL	\$4,500,000

30-INCH TRANSMISSION MAIN COST								
ITEM				UNIT				
NO.	ITEM DESCRIPTION	UNIT	QTY	PRICE	AMOUNT			
1	MOBILIZATION	LS	1	\$84,000.00	\$84,000			
2	30-INCH D.I. WATER MAIN (OPEN CUT)	LF	89,688	\$95.00	\$8,520,360			
3	30-INCH D.I. WATER MAIN (BORE)	LF	72	\$150.00	\$10,800			
4	4 INCH COMBINATION AIR VALVE WITH MANHOLE	EA	7	\$12,000.00	\$84,000			
5	30 INCH BUTTERFLY VALVE WITH MANHOLE	EA	7	\$13,000.00	\$91,000			
6	FILTER FABRIC	LF	89,760	\$1.00	\$89,760			
7	CATHODE PROTECTION	LS	1	\$250,000.00	\$250,000			
8	DISINFECT WATER TRANSMISSION MAIN	LF	89,760	\$0.50	\$44,880			
9	INSTALLATION CATHODE TEST STATIONS	LS	1	\$15,000.00	\$15,000			

MISC					
ITEM NO.	ITEM DESCRIPTION	UNIT	QTY.	UNIT PRICE	AMOUNT
-		-	GIT.		
-	SURVEY (1.0 %)	LS	1	\$236,648.43	\$236,648
2	ENGINEERING (10%)	LS	1	\$2,366,484.33	\$2,366,484
			ESTIMATE	ED SUB TOTAL	\$2,603,133

Level of Cost Projection:

No Design Completed

V Preliminary Design

TRENCH SAFETY

Final Design

TOTAL CONSTRUCTION COST = \$23,664,843.30 TOTAL ENGINEERING COST =

ESTIMATED SUB TOTAL

89,688

1 F

\$2,603,133 TOTAL= \$26,267,976

\$112,110

\$9,301,910

15% CONTINGENCY= \$3,940,196 GRAND TOTAL = \$30,200,000

\$1.25

The engineer has no control over the cost of labor, materials, or equipment, or over the Contractor's methods of determining prices, or over competitive bidding or market conditions. As a result, this opinion of probable construction cost is based on the engineer's experience and qualifications and represents our best judgment as design professionals familiar with the construction industry. The engineer cannot and does not guarantee the proposals, bids, or the construction cost will not vary from this opinion of probable cost.

#### Caldwell County Regional Water and Wastewater Planning Study Regional Water Planning Water Transmission Line Options Prepared June 2009

#### Transmission Line 1C

GENEF	GENERAL DEVELOPMENT								
ITEM				UNIT					
NO.	ITEM DESCRIPTION	UNIT	QTY	PRICE	AMOUNT				
1	MOBILIZATION (10%)	LS	1	\$3,266,540.00	\$3,266,540				
2	SITE PREPARATION (7%)	LS	1	\$2,286,578.00	\$2,286,578				
3	SEDIMENTATION AND EROSION CONTROL (5%)	LS	1	\$1,633,270.00	\$1,633,270				
4	TRAFFIC MAINTENANCE (1.0%)	LS	1	\$326,654.00	\$326,654				
5	REPLACING ASPHALT PAVEMENT	SY	31	\$90.00	\$2,800				
6	DRIVEWAY REPLACEMENT (AVG)	SY	250	\$60.00	\$15,000				
7	REMOVE AND REPLACE FENCING	LF	4,752	\$50.00	\$237,600				
8	INSTALLATION OF CATHODIC TEST STATIONS	LS	1	\$10,000.00	\$10,000				
			ESTIMAT	ED SUB TOTAL	\$7,800,000				

#### WATER FACILITIES

ITEM				UNIT		
NO.	ITEM DESCRIPTION	UNIT	QTY	PRICE	AMOUNT	
1	STORAGE TANK	GAL	1,000,000	\$0.50	\$500,000	
2	WATER TREATMENT PLANT	GPD	8,000,000	\$2.75	\$22,000,000	
3	PUMPS (1,000 GPM) & INSTALLATION	EA	6	\$12,000.00	\$72,000	
4	LAND PURCHASE COST	LS	1	\$30,000.00	\$30,000	
	ESTIMATED SUB TOTAL					

#### **30-INCH TRANSMISSION MAIN COST**

ITEM				UNIT	
NO.	ITEM DESCRIPTION	UNIT	QTY	PRICE	AMOUNT
1	MOBILIZATION	LS	1	\$84,000.00	\$84,000
2	30-INCH D.I. WATER MAIN (OPEN CUT)	LF	94,956	\$95.00	\$9,020,820
3	30-INCH D.I. WATER MAIN (BORE)	LF	84	\$150.00	\$12,600
4	4 INCH COMBINATION AIR VALVE WITH MANHOLE		7	\$12,000.00	\$84,000
5	30 INCH BUTTERFLY VALVE WITH MANHOLE	EA	7	\$13,000.00	\$91,000
6	FILTER FABRIC	LF	95,040	\$1.00	\$95,040
7	CATHODE PROTECTION	LS	1	\$250,000.00	\$250,000
8	DISINFECT WATER TRANSMISSION MAIN	LF	95,040	\$0.50	\$47,520
9	INSTALLATION CATHODIC TEST STATIONS	LS	1	\$15,000.00	\$15,000
10	TRENCH SAFETY	LF	94,956	\$1.25	\$118,695
		\$9,800,000			

N	Л	1	2	c
n	"	•	9	v

ITEM NO.	ITEM DESCRIPTION	UNIT	QTY.	UNIT PRICE	AMOUNT
1	SURVEY (1.0 %)	LS	1	\$402,000.00	\$402,000
2	ENGINEERING (10%)	LS	1	\$4,020,000.00	\$4,020,000
			ESTIMAT	ED SUB TOTAL	\$4,400,000

#### Level of Cost Projection:

- $\checkmark$ No Design Completed
  - Preliminary Design
- Final Design

TOTAL CONSTRUCTION COST = \$40,200,000.00 TOTAL ENGINEERING COST = \$4,400,000 TOTAL= \$44,600,000

> 15% CONTINGENCY= \$6,700,000 GRAND TOTAL = \$51,300,000

The engineer has no control over the cost of labor, materials, or equipment, or over the Contractor's methods of determining prices, or over competitive bidding or market conditions. As a result, this opinion of probable construction cost is based on the engineer's experience and qualifications and represents our best judgment as design professionals familiar with the construction industry. The engineer cannot and does not guarantee the proposals, bids, or the construction cost will not vary from this opinion of probable cost.

#### Caldwell County Regional Water and Wastewater Planning Study Regional Water Planning Water Transmission Line Options Prepared June 2009

### Transmission Line 2

#### **GENERAL DEVELOPMENT**

ITEM				UNIT		
NO.	ITEM DESCRIPTION	UNIT	QTY	PRICE	AMOUNT	
1	MOBILIZATION (10%)	LS	1	\$650,987.90	\$650,988	
2	SITE PREPARATION (7%)	LS	1	\$455,691.53	\$455,692	
3	SEDIMENTATION AND EROSION CONTROL (5%)	LS	1	\$325,493.95	\$325,494	
4	TRAFFIC MAINTENANCE (1.0%)	LS	1	\$65,098.79	\$65,099	
5	REPLACING ASPHALT PAVEMENT	SY	202	\$90.00	\$18,200	
6	DRIVEWAY REPLACEMENT (AVG)	SY	1,000	\$60.00	\$60,000	
7	REMOVE AND REPLACE FENCING	LF	3,168	\$50.00	\$158,400	
8	INSTALLATION OF CATHODIC TEST STATIONS	LS	1	\$10,000.00	\$10,000	
	ESTIMATED SUB TOTAL					

#### **30-INCH TRANSMISSION MAIN COST**

ITEM				UNIT	
NO.	ITEM DESCRIPTION	UNIT	QTY	PRICE	AMOUNT
1	MOBILIZATION	LS	1	\$569,389.00	\$569,389
2	12-INCH D.I. WATER MAIN (OPEN CUT)	LF	63,080	\$80.00	\$5,046,400
3	12-INCH D.I. WATER MAIN (BORE)	LF	280	\$120.00	\$33,600
4	4 INCH COMBINATION AIR VALVE WITH MANHOLE	EA	7	\$12,000.00	\$84,000
5	12 INCH BUTTERFLY VALVE WITH MANHOLE	EA	7	\$13,000.00	\$91,000
6	FILTER FABRIC	LF	63,360	\$1.00	\$63,360
7	CATHODE PROTECTION	LS	1	\$250,000.00	\$250,000
8	DISINFECT WATER TRANSMISSION MAIN	LF	63,360	\$0.50	\$31,680
9	INSTALLATION CATHODIC TEST STATIONS	LS	1	\$15,000.00	\$15,000
10	TRENCH SAFETY	LF	63,080	\$1.25	\$78,850
		-	ESTIMATI	ED SUB TOTAL	\$6,263,279

MISC					
ITEM NO.	ITEM DESCRIPTION	UNIT	QTY.	UNIT PRICE	AMOUNT
1	SURVEY (1.0 %)	LS	1	\$80,071.51	\$80,072
2	ENGINEERING (10%)	LS	1	\$800,715.12	\$800,715
			ESTIMATI	ED SUB TOTAL	\$880,787
	Level of Cost Projection:	TOTAL	CONSTRU	ICTION COST =	\$8,007,151.17

### Level of Cost Projection:

1	No Design Completed

Preliminary Design

Final Design 15% CONTINGENCY= \$1,333,191

TOTAL=

\$880,787

\$8,887,938

TOTAL ENGINEERING COST =

GRAND TOTAL = \$10	221,128
	, -

The engineer has no control over the cost of labor, materials, or equipment, or over the Contractor's methods of determining prices, or over competitive bidding or market conditions. As a result, this opinion of probable construction cost is based on the

#### Caldwell County Regional Water and Wastewater Planning Study Regional Water Planning Water Transmission Line Options Prepared June 2009

# Transmission Line 3

#### GENERAL DEVELOPMENT

ITEM				UNIT	
NO.	ITEM DESCRIPTION	UNIT	QTY	PRICE	AMOUNT
1	MOBILIZATION (10%)	LS	1	\$400,161.90	\$400,162
2	SITE PREPARATION (7%)	LS	1	\$280,113.33	\$280,113
3	SEDIMENTATION AND EROSION CONTROL (5%)	LS	1	\$200,080.95	\$200,081
4	TRAFFIC MAINTENANCE (1.0%)	LS	1	\$40,016.19	\$40,016
5	REPLACING ASPHALT PAVEMENT	SY	156	\$90.00	\$14,000
6	DRIVEWAY REPLACEMENT (AVG)	SY	417	\$60.00	\$25,000
7	REMOVE AND REPLACE FENCING	LF	1,848	\$50.00	\$92,400
8	INSTALLATION OF CATHODIC TEST STATIONS	LS	1	\$10,000.00	\$10,000
	ESTIMATED SUB TOTAL				

#### **30-INCH TRANSMISSION MAIN COST**

ITEM				UNIT	
NO.	ITEM DESCRIPTION	UNIT	QTY	PRICE	AMOUNT
1	MOBILIZATION	LS	1	\$350,929.00	\$350,929
2	12-INCH D.I. WATER MAIN (OPEN CUT)	LF	36,680	\$80.00	\$2,934,400
3	12-INCH D.I. WATER MAIN (BORE)	LF	280	\$120.00	\$33,600
4	4 INCH COMBINATION AIR VALVE WITH MANHOLE	EA	7	\$12,000.00	\$84,000
5	12 INCH BUTTERFLY VALVE WITH MANHOLE	EA	7	\$13,000.00	\$91,000
6	FILTER FABRIC	LF	36,960	\$1.00	\$36,960
7	CATHODE PROTECTION	LS	1	\$250,000.00	\$250,000
8	DISINFECT WATER TRANSMISSION MAIN	LF	36,960	\$0.50	\$18,480
9	INSTALLATION CATHODIC TEST STATIONS	LS	1	\$15,000.00	\$15,000
10	TRENCH SAFETY	LF	36,680	\$1.25	\$45,850
			ESTIMATI	ED SUB TOTAL	\$3,860,219

MISC					
ITEM NO.	ITEM DESCRIPTION	UNIT	QTY.	UNIT PRICE	AMOUNT
1	SURVEY (1.0 %)	LS	1	\$49,219.91	\$49,220
2	ENGINEERING (10%)	LS	1	\$492,199.14	\$492,199
			ESTIMATE	D SUB TOTAL	\$541,419
	Level of Cost Projection:	TOTAL	CONSTRU	ICTION COST =	\$4,921,991.37

vel of Cost Projection:	TOTAL CONSTRUCTION COST =	\$4,921,991.37
No Design Completed	TOTAL ENGINEERING COST $=$	\$541,419
Preliminary Design	TOTAL=	\$5,463,410
Final Design		
	15% CONTINGENCY=	\$819,512

15% CONTINGENCIE	\$019,51Z
GRAND TOTAL =	\$6,282,922
-	

The engineer has no control over the cost of labor, materials, or equipment, or over the Contractor's methods of determining prices, or over competitive bidding or market conditions. As a result, this opinion of probable construction cost is based on the

#### Caldwell County Regional Water and Wastewater Planning Study Regional Water Planning Water Transmission Line Options Prepared June 2009

# Transmission Line 4

#### **GENERAL DEVELOPMENT**

ITEM				UNIT	
NO.	ITEM DESCRIPTION	UNIT	QTY	PRICE	AMOUNT
1	MOBILIZATION (10%)	LS	1	\$548,305.50	\$548,306
2	SITE PREPARATION (7%)	LS	1	\$383,813.85	\$383,814
3	SEDIMENTATION AND EROSION CONTROL (5%)	LS	1	\$274,152.75	\$274,153
4	TRAFFIC MAINTENANCE (1.0%)	LS	1	\$54,830.55	\$54,831
5	REPLACING ASPHALT PAVEMENT	SY	156	\$90.00	\$14,000
6	DRIVEWAY REPLACEMENT (AVG)	SY	417	\$60.00	\$25,000
7	REMOVE AND REPLACE FENCING	LF	2,640	\$50.00	\$132,000
8	INSTALLATION OF CATHODIC TEST STATIONS	LS	1	\$10,000.00	\$10,000
	ESTIMATED SUB TOTAL				

#### **30-INCH TRANSMISSION MAIN COST**

ITEM				UNIT	
NO.	ITEM DESCRIPTION	UNIT	QTY	PRICE	AMOUNT
1	MOBILIZATION	LS	1	\$482,005.00	\$482,005
2	12-INCH D.I. WATER MAIN (OPEN CUT)	LF	52,520	\$80.00	\$4,201,600
3	12-INCH D.I. WATER MAIN (BORE)	LF	280	\$120.00	\$33,600
4	4 INCH COMBINATION AIR VALVE WITH MANHOLE	EA	7	\$12,000.00	\$84,000
5	12 INCH BUTTERFLY VALVE WITH MANHOLE	EA	7	\$13,000.00	\$91,000
6	FILTER FABRIC	LF	52,800	\$1.00	\$52,800
7	CATHODE PROTECTION	LS	1	\$250,000.00	\$250,000
8	DISINFECT WATER TRANSMISSION MAIN	LF	52,800	\$0.50	\$26,400
9	INSTALLATION CATHODIC TEST STATIONS	LS	1	\$15,000.00	\$15,000
10	TRENCH SAFETY	LF	52,520	\$1.25	\$65,650
			ESTIMATI	ED SUB TOTAL	\$5,302,055

MISC						
ITEM				UNIT		
NO.	ITEM DESCRIPTION	UNIT	QTY.	PRICE	AMOUNT	
1	SURVEY (1.0 %)	LS	1	\$67,441.58	\$67,442	
2	ENGINEERING (10%)	LS	1	\$674,415.77	\$674,416	
			ESTIMATI	ED SUB TOTAL	\$741,857	
	Level of Cost Projection:	TOTAL	CONSTRL	ICTION COST =	\$6,744,157.65	
	✓ No Design Completed	TOTAL ENGINEERING COST = \$741,857				
	Preliminary Design			TOTAL=	\$7,486,015	

No Design completed	
Preliminary Design	TOTAL=
Final Design	

15% CONTINGENCY=	\$1,122,902
GRAND TOTAL =	\$8,608,917

The engineer has no control over the cost of labor, materials, or equipment, or over the Contractor's methods of determining prices, or over competitive bidding or market conditions. As a result, this opinion of probable construction cost is based on the

### Caldwell County Regional Water and Wastewater Planning Study Regional Wastewater Planning Package Treatment Plants

Extended Aeration Package Treatment Plant Planning Cost Estimate in Millions of Dollars												
Population Projections		2010		2020				2030		2040		
		46,308			65,057			86,902		100,000		
Wastewater Flows		4.723		6.636			8.864			10.200		
Proposed Plant Size	0.015 MGD	0.04 MGD	1.0 MGD	0.015 MGD	0.04 MGD	1.0 MGD	0.015 MGD	0.04 MGD	1.0 MGD	0.015 MGD	0.04 MGD	1.0 MGD
Estimated Cost Per Gallon	\$10.0 \$7.0 \$1.3		\$10.0	\$7.0	\$1.3	\$10.0	\$7.0	\$1.3	\$10.0	\$7.0	\$1.3	
Estimated Number of Plants	ed Number of Plants 315 94 5		442	133	7	591	177	9	680	204	10	
Estimated Total Cost	47.23	33.06	6.14	66.36	46.45	8.63	88.64	62.05	11.52	102.00	71.40	13.26

Sequencing Batch Reactor (SBR) Package Treatment Plant Planning Cost Estimate in Millions of Dollars												
Population Projections	2010			2020				2030		2040		
	46,308			65,057			86,902			100,000		
Wastewater Flows		4.723		6.636			8.864			10.200		
Proposed Plant Size	0.01 MGD	0.20 MGD	1.0 MGD	0.01 MGD	0.20 MGD	1.0 MGD	0.01 MGD	0.20 MGD	1.0 MGD	0.01 MGD	0.20 MGD	1.0 MGD
Estimated Cost Per Gallon	\$4.50 \$0.70 \$0.25		\$0.25	\$4.50	\$0.70	\$0.25	\$4.50	\$0.70	\$0.25	\$4.50	\$0.70	\$0.25
Estimated Number of Plants	mated Number of Plants 3149 945 47 4424 1327		1327	66	5909	1773	89	6800	2040	102		
Estimated Total Cost	21.26	3.31	1.18	29.86	4.65	1.66	39.89	6.20	2.22	45.90	7.14	2.55

Notes:

Population estimates based on this study

Estimated cost per gallon based on EPA Wastewater Technology Fact Sheet Package Plants

# Caldwell County Regional Water and Wastewater Planning Study Regional Wastewater Planning Multiple Regional Treatment Facilities

Multiple Regional Treatment Facility Planning Cost Estimate												
Service Area	Year	Population	Total Wastewate r Flow (MGD)	Percent of Flow	Total Treated Flow (MGD)	Cost Per Gallon (\$)	Plant Cost	Line Length (ft)	Pipeline Cost (\$/ft)	Total Line Cost	Total Plant Cost	
	2010	46,308	4.723	40%	1.89	\$3.75	\$7,084,500	168,289	\$125	\$21,036,125	\$28,120,625	
Lockhart	2020	65,057	6.636	40%	2.65	\$3.75	\$9,954,000	168,289	\$125	\$21,036,125	\$30,990,125	
LOCKIAI	2030	86,902	8.864	40%	3.55	\$3.75	\$13,296,000	168,289	\$125	\$21,036,125	\$34,332,125	
	2040	100,000	10.200	40%	4.08	\$3.75	\$15,300,000	168,289	\$125	\$21,036,125	\$36,336,125	
	2010	46,308	4.723	35%	1.65	\$3.75	\$6,198,938	160,972	\$125	\$20,121,500	\$26,320,438	
Luling	2020	65,057	6.636	35%	2.32	\$3.75	\$8,709,750	160,972	\$125	\$20,121,500	\$28,831,250	
Lanng	2030	86,902	8.864	35%	3.10	\$3.75	\$11,634,000	160,972	\$125	\$20,121,500	\$31,755,500	
	2040	100,000	10.200	35%	3.57	\$3.75	\$13,387,500	160,972	\$125	\$20,121,500	\$33,509,000	
	2010	46,308	4.723	20%	0.94	\$3.75	\$3,542,250	56,173	\$125	\$7,021,625	\$10,563,875	
Martindale	2020	65,057	6.636	20%	1.33	\$3.75	\$4,977,000	56,173	\$125	\$7,021,625	\$11,998,625	
Martinuale	2030	86,902	8.864	20%	1.77	\$3.75	\$6,648,000	56,173	\$125	\$7,021,625	\$13,669,625	
	2040	100,000	10.200	20%	2.04	\$3.75	\$7,650,000	56,173	\$125	\$7,021,625	\$14,671,625	
	2010	46,308	4.723	5%	0.24	\$3.75	\$885,563	45,676	\$125	\$5,709,500	\$6,595,063	
Peach	2020	65,057	6.636	5%	0.33	\$3.75	\$1,244,250	45,676	\$125	\$5,709,500	\$6,953,750	
Creek	2030	86,902	8.864	5%	0.44	\$3.75	\$1,662,000	45,676	\$125	\$5,709,500	\$7,371,500	
	2040	100,000	10.200	5%	0.51	\$3.75	\$1,912,500	45,676	\$125	\$5,709,500	\$7,622,000	

Notes:

Population estimates based on this study

Estimated cost per gallon based on EPA Wastewater Technology Fact Sheet Package Plants



# Appendix N

# Texas Water Development Board Comment Letter Regarding Draft Report and Response to Comments

# TEXAS WATER DEVELOPMENT BOARD COMMENT LETTER DATED SEPTEMBER 28, 2009 AND KLOTZ ASSOCIATES RESPONSES TO COMMENTS

TEXAS WATER DEVELOPMENT BOARI

James E. Herring, *Chairman* Lewis H. McMahan, *Member* Edward G. Vaughan, *Member* 

J. Kevin Ward Executive Administrator Jack Hunt, Vice Chairman Thomas Weir Labatt III, Member Joe M. Crutcher, Member

DEVELO

RECEI

September 28, 2009

William West General Manager Guadalupe-Blanco RA 933 E. Court Street Seguin, Texas 78155

Re: Regional Facility Planning Grant Contract between the Texas Water Development Board (TWDB) and the Guadalupe-Blanco River Authority (GBRA), TWDB Contract No. 0804830843, Draft Final Report Comments

Dear Mr. West:

Staff members of the TWDB have completed a review of the draft report prepared under the abovereferenced contract. ATTACHMENT I provides the comments resulting from this review. As stated in the TWDB contract, GBRA will consider incorporating draft report comments from the EXECUTIVE ADMINISTRATOR as well as other reviewers into the final report. In addition, GBRA will include a copy of the EXECUTIVE ADMINISTRATOR's draft report comments in the Final Report.

The TWDB looks forward to receiving one (1) electronic copy of the entire Final Report in Portable Document Format (PDF) and six (6) bound double-sided copies. GBRA shall also submit one (1) electronic copy of any computer programs or models, and, if applicable, an operations manual developed under the terms of this Contract.

If you have any questions concerning the contract, please contact Matt Nelson, the TWDB's designated Contract Manager for this project at (512) 936-3550.

Sincerely,

Van Harken

Carolyn L. Brittin Deputy Executive Administrator Water Resources Planning and Information

Enclosures

c: Matt Nelson, TWDB

*Our Mission* To provide leadership, planning, financial assistance, information, and education for the conservation and responsible development of water for Texas.

> P.O. Box 13231 • 1700 N. Congress Avenue • Austin, Texas 78711-3231 Telephone (512) 463-7847 • Fax (512) 475-2053 • 1-800-RELAYTX (for the hearing impaired) www.twdb.state.tx.us • info@twdb.state.tx.us TNRIS - Texas Natural Resources Information System • www.tnris.state.tx.us *A Member of the Texas Geographic Information Council (TGIC)*



# ATTACHMENT 1

# TWDB Contract No. 0804830843

## Guadalupe-Blanco River Authority

# Caldwell County Regional Water and Wastewater Planning Study

### TWDB Comments on Draft Final Report:

- 1. Pages with figures/exhibits are missing page numbers while the numbering of the remaining pages overlooks the exhibit pages (e.g. exhibit 11-2). Please number each report page, including figures, consecutively.
- 2. Report does not include information on existing impervious cover in the county or show the locations of existing WTPs and proposed WTPs & WWTPs as required by contract scope of work Task 1.a. Please include this information in report.
- 3. Report does not include information regarding the locations of major power lines as required by contract scope of work Task 1.c. Please include this information in report.
- 4. Page ES-3: Please note within the Executive Summary that the population and water demand projections used in the study were higher than those approved by TWDB for regional water planning purposes.
- 5. Section 7: The Caldwell County Water CCN Utility Map should be labeled 7-1, not 2-4.
- 6. Page 8-7: Report does not appear to specify whether and/or how per capita water demands varied from regional and state water planning per capita water demand estimates. Please discuss whether and/or how per capita water demands varied from TWDB approved per capita demands and whether and/or how this may have further amplified the total water demand projections used in the study considering that higher population projections (due to a higher migration rate) were also being used.
- 7. Page 12-6, Table 12-5: Please provide the basis for the costs estimates presented in the table.

- 8. Exhibit 12-1 (no page): The key to the figure is missing. Please include a key that also indicates which are planned projects.
- 9. Page 13-9, Table 13-3: Please provide the basis for the costs estimates presented in the table.
- 10. Exhibit 13-4: Figure Legend does not explain what the black-outlined orange lines indicate. Please include this symbol in the legend.
- 11. Page 14-1: The 5-page Regional Water Quality Protection Plan appears to be a standard list of common practices. Please prepare a water quality protection plan specific to Caldwell County's existing characteristics and needs.
- 12. Report does not clearly present in one place the preferred general facilities plan for regionalization of water and wastewater treatment that is required by contract scope of work, Task 6. Please present the preferred water and wastewater plan(s), more clearly in one place in the report including associated map(s), and indicate whether consensus was achieved on its selection per contract scope of work Task 6.

# KLOTZ ASSOCIATES RESPONSES TO COMMENTS FROM TEXAS WATER DEVELOPMENT BOARD COMMENT LETTER DATED SEPTEMBER 28, 2009

## Klotz Associates, Inc. Responses to Texas Water Development Board Comments Dated September 28, 2009

### TWDB Comments on Draft Final Report:

1. Pages with figures/exhibits are missing page numbers while the numbering of the remaining pages overlooks the exhibit pages (e.g. exhibit 11-2). Please number each report page, including figures, consecutively.

## Klotz Associates Response:

## All Figures and Exhibits have been assigned page numbers.

2. Report does not include information on existing impervious cover in the county or show the locations of existing WTPs and proposed WTPs & WWTPs as required by contract scope of work Task 1.a. Please include this information in report.

## Klotz Associates Response:

The following items have been added to the Report:

- *a. Impervious Cover Exhibit 2-8*
- b. Exhibit 7-1 has been revised to illustrate the locations of existing WTP
- c. Exhibit 7-2 has been added to illustrate the locations of existing WWTP
- *d. Exhibit 12-1 has been revised to illustrate the locations of the proposed WTP*
- *e. Exhibit 13-2 has been revised to illustrate the locations of the proposed WWTF*
- 3. Report does not include information regarding the locations of major power lines as required by contract scope of work Task 1.c. Please include this information in report.

## Klotz Associates Response:

*Exhibit* 2-7 *has been added to include the approximate location of the major power lines.* 

4. Page ES-3: Please note within the Executive Summary that the population and water demand projections used in the study were higher than those approved by TWDB for regional water planning purposes.

# Klotz Associates Response:

We have noted in the Executive Summary that the population and water demands for our study are higher than the approved values used in TWDB planning studies.

5. Section 7: The Caldwell County Water CNN Utility Map should be labeled 7-1, not 2-4.

# Klotz Associates Response:

*The Caldwell County Water CCN Map has been labeled Exhibit 7-1, Water Production Facilities.* 

6. Page 8-7: Report does not appear to specify whether and/or how per capita water demands varied from regional and state water planning per capita water demand estimates. Please discuss whether and/or how per capita water demands varied from TWDB approved per capita demands and whether and/or how this may have further amplified the total water demand projections used in the study considering that higher population projections (due to a higher migration rate) were also being used.

## Klotz Associates Response:

We have added a discussion to the report explaining the source of our per capita water demands and why and how they differ from TWDB values.

7. Page 12-6, Table 12-5: Please provide the basis for the costs estimates presented in the table.

## Klotz Associates Response:

Basis for cost estimates presented in Table 12-5 have been added in Appendix M.

8. Exhibit 12-1 (no page): The key to the figure is missing. Please include a key that also indicates which are planned projects.

## Klotz Associates Response:

A legend has been added to Exhibit 12-1 that includes planned projects.

9. Page 13-9, Table 13-3: Please provide the basis for the costs estimates presented in the table.

## Klotz Associates Response:

A paragraph has been added to Section 13.7 to elaborate on the basis for the cost estimates presented in the Table 13-3.

10. Exhibit 13-4: Figure Legend does not explain what the black-outlined orange lines indicate. Please include this symbol in the legend.

# Klotz Associates Response:

Exhibit 13-4 Legend has been revised to address the black-outlined orange lines.

11. Page 14-1: The 5-page Regional Water Quality Protection Plan appears to be a standard list of common practices. Please prepare a water quality protection plan specific to Caldwell County's existing characteristics and needs.

# Klotz Associates Response:

A Water Quality Protection Plan for Caldwell County has been added. The Plan includes upgrading of wastewater treatment plant facilities to produce higher quality effluent; reuse of reclaimed water, use of vegetated filter strips along waterways, water quality basins to treat runoff from areas with impervious cover and periodic inspection and recertification of OSSF systems.

12. Report does not clearly present in one place the preferred general facilities plan for regionalization of water and wastewater treatment that is required by contract scope of work, Task 6. Please present the preferred water and wastewater plan(s), more clearly in one place in the report including associated map(s), and indicate whether consensus was achieved on its selection per contract scope of work Task 6.

## Klotz Associates Response:

Section 16 has been added to the Report to illustrate in one place the preferred facilities plan with a discussion on consensus.

# REFERENCES

Texas Water Development Board. (2007). *Water for Texas 2007* (Document No. GP-8-1)

Texas Water Development Board. (2006). 2006 South Central Texas Regional Water Plan. Volume I & II.

Matt Berg, Mark McFarland and Nikki Dictson. (2008). *Plum Creek Watershed Protection Plan*. College Station, Texas: Plum Creek Watershed Partnership.

Follet, C.R. (1975) *Groundwater Resources of Caldwell County, Texas*. (Report 12, 3<sup>rd</sup> Printing). Austin, Texas: Texas Water Development Board.

Thorkildsen David & Price, Robert D. (1991). *Ground-Water Resources of the Carrizo-Wilcox Aquifer in the Central Texas Region*. (Report 332). Texas Water Development Board.

Guadalupe Blanco River Authority. (2008). *The 2008 Comprehensive Annual Financial Report* 

*Distribution System Requirements for fire Protection.* American Water Works Association. 1990.

Steven M. Haubner. Implementation of Watershed management requirements and Model Ordinances

Graham M. Moore. *Plumbing Plan Prepared for: Hays Caldwell Public Utility Agency*. Lockwood, Andrews, & Newnam, Inc. September 2007

Rules of the Gonzales County Underground Water Conservation District

Management Plan of the Gonzales County Underground Water Conservation District

Plum Creek Conservation District Groundwater Management & Protection Rules. Adopted December 16, 2003.

Canyon Regional Water Authority website <u>http://www.crwa.com/index.html</u>

Guadalupe-Blanco River Authority website <a href="http://www.gbra.org/About/Default.aspx">http://www.gbra.org/About/Default.aspx</a>

The Portal to Texas History Inventory of the county archives of Texas; Caldwell County, No. 28 http://texashistory.unt.edu/data/UNT/County\_Inventory/meta-pth-25254.tkl



# REFERENCES

Final Report Predicting Effects of Urban Development on Water Quality in the Cities of New Braunfels, San Marcos, Seguin and Victoria. Prepared by PBSJ. November 2000

REF-2